

This drawing shall not be scaled. Work only from the dimensions stated on the drawing or given in the relevant specification.

CDM Pre-Construction Information
The following information is provided in pursuance of Regulations 11 (a) of the CDM Regulations 2015:

- 1.0 REFER TO QED LIGHTING CALCULATIONS, PROVIDED AS PART OF THE PLANNING APPLICATION.
- 2.0 REFER TO QED LUMINARIES SCHEDULE, PROVIDED AS PART OF PLANNING APPLICATION.
- 3.0 EXTERNAL LIGHTING IS TO BE CONTROLLED VIA PHOTOCELL + TIME CLOCK, RESTRICTED TO BETWEEN 08:00 - 18:00
- 4.0 ALL FITTINGS TO BE 3000K CCT TO MINIMISE THE IMPACT OF EXTERNAL LIGHTING TO LOCAL ECOSYSTEMS

KEY

Isolines

- 0.1 lx
- 0.5 lx
- 1.0 lx
- 2.0 lx
- 4.0 lx
- 5.0 lx

- N 900 HIGH LOW-LEVEL LIGHTING BOLLARD
- P1 POST-TOP LANTERN ON 4.0m COLUMN (ARROW SHOWS DIRECTION OF POLE TOP LANTERN)
- P2 POST-TOP LANTERN ON 4.0m COLUMN (NON DIRECTIONAL)
- LED BULKHEAD LIGHT
- LED DOWNLIGHT

17.12.21	P3	TT	Preliminary
Date	Rev	By	Comments

PRELIMINARY



Unit 2
Bokeway Farm
Widmore
Somerset
BS28 4JB
Tel: 01934 713003
email: info@qed-engineering.com
www.qed-engineering.com

QED ENGINEERING LIMITED

project	Bognor Regis Crematorium, Gravett's Ln West, BN17 0LA		
client	Crematoria Management Ltd		
drawing	External Isoline Drawing	scale	1:500@A1
start date	MAY 2021	cod	TT
drawing no.	QD2965/EO001	chkd.	CT
		app.	DL
		rev.	P3