



Planning and Development Services
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Jc
ARUN DISTRICT COUNCIL

9 - JUL 2012

RECEIVED

ATKINS

Atkins Limited
Anglo St James House
39A Southgate Street
Winchester
Hampshire SO23 9EH

Telephone +44 (0)1962 858688
Fax +44 (0)1962 810296

winchester.enquiries@atkinsglobal.com
www.atkinsglobal.com

Your Ref
Y/22/12/
Our Ref
PLAN-000545
Date
06/07/2012

Dear Sir,

Proposal: Erection of single storey flat roof extension to rear of property to provide family room.

Site: 35 Briar Close, Church Road, Yapton BN18 0ES.
Y/22/12/

Thank you for your letter of 13/06/2012.


Any new connections will require a formal application for a connection to the public sewer to be made by the applicant or developer.

We request that should this application receive planning approval, the following informative is attached to the consent: "A formal application for connection to the public sewerage system is required in order to service this development, please contact *Atkins Ltd, Anglo St James House, 39A Southgate Street, Winchester, SO23 9EH (Tel 01962 858688), or www.southernwater.co.uk*".

Southern Water's current sewerage records do not show any public sewers to be crossing the above site. However, due to changes in legislation that came in to force on 1st October 2011 regarding the future ownership of sewers it is possible that a sewer now deemed to be public could be crossing the above property. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its condition, the number of properties served, and potential means of access before any further works commence on site.

The applicant is advised to discuss the matter further with *Atkins Ltd, Anglo St James House, 39A Southgate Street, Winchester, SO23 9EH (Tel 01962 858688)*.

Yours faithfully,



Developer Services