

[REDACTED]

Please upload the above and below to the above application; further information



[REDACTED]

Good Morning Maria

Our lighting consultant has confirmed, : 'Light intrusion into residential windows shall not exceed 10 Lux between 07:00 and 21:00 hours and 5 Lux between 21:00 and 07:00 hours, measured as Vertical Illuminance (EV) normal to glazing. The Sky Glow (Upward Light Ratio) shall not exceed 5.0%


As shown in the attached drawings the light level is no more than 5 lux beyond the perimeter of the site and the Upward light ratio is 0.01, which equates to 1%.

Please can you forward to the EHO for comments.

If you need anything further, please let me know.

Best regards
Susan

Susan Leeson B.Sc, M.Phil
Associate



Company Registration No. 07164666. Registered Office is at 1 & 2 The Barn, West Stoke Road, Chichester, West Sussex, PO18 9AA.

This email and any attachments are strictly confidential and intended solely for the addressee. It may contain information which is privileged. If you are not the intended addressee, you must not disclose, forward, copy or take any action in reliance of this email or any attachments.

DISCLAIMER

Neame Sutton Ltd has taken precautions to minimise the risk of transmitting software viruses, however, this email and any attachments may contain software viruses which could damage your system. We cannot accept liability for any damage which you sustain as a result of software viruses and advise that you carry out your own virus check.