



from

**Southern
Water**

Mr Kazys Narbutas
Kazys Narbutas Consulting Limited
Unit 5B, Tanners Court
Tanners Lane
East Wellow
Romsey
Hampshire
SO51 6DP

Your ref

Our ref
DS_CPS-122274

Date
24 February 2021



Dear Mr Narbutas,

Application to Connect to the Public Sewerage System - Section 106 Water Industry Act 1991.
Location: Cinders Nursery, Land at Southern End of Cinders Lane, Cinders Lane, Yapton, Arundel,
West Sussex, BN18 0JJ – Phase 2.

We refer to your application to connect to the public foul sewer at the above location. We are pleased to advise that your proposal, as shown on your drawing 502-03 Revision A dated 08/11/2019, is approved subject to:

This review is for the purpose of approval to permit communication to be made to the public sewer, under Section 106 of the Water Industry Act 1991. **It is to the means and mode of construction only.**

S106 approval does not confirm that public sewer network capacity is available for the proposed development. The availability of capacity may be assessed through the Pre-planning enquiry process.

This letter should not be considered as approval by Southern Water to the discharge of any relevant Planning Conditions relating to drainage. This is a separate matter which will be reviewed under a consultation from the Planning Authority.

If connection is to be made through land under the ownership of other Parties, then you are advised to obtain the Landowners consent before carrying out any works.

In approving this application, it is assumed that you have obtained any necessary Building Regulations Approval and /or Highway Authority Road Opening License.

Please note that as there could be a risk issue, please ensure that you install vent on the storage tank to prevent H₂S&CH₄.

Southern Water, Southern House, Yeoman Road, Worthing, West Sussex BN13 3NX
southernwater.co.uk

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing BN13 3NX Registered in England No. 2366670

This approval is given based on the information provided in support of this application and the assumption of the final discharge point being to the public foul sewer. If this is different, then this approval becomes invalid.

If as noted above, there is any change in the approved connection point, then you must provide us with revised drawings and details and obtain our approval for the changes prior to the connection being made.

Please note that surface water must not communicate with the public foul sewers.

Connection to an existing manhole and the arrangement of pipe junctions within any new manholes should be in accordance with the new Design and Construction Guidance manual ("the Code") and Southern Water's guidance documentation.

water.org.uk/sewerage-sector-guidance-approved-documents/

We refer you to Southern Water Health and Safety Advisory that can be viewed in the Developer and Builders section of the Southern Water website as the link below:

southernwater.co.uk/developing-building/health-and-safety

This approval is given on the basis that you will review this Advisory and take the necessary actions concerning Health and Safety.

Please contact Mick Vince our Assistant Adoption Manager for this area [REDACTED] giving at least two full working days' notice, for a mutually convenient date and time for the inspection of the works to be arranged.

Yours sincerely,

[REDACTED]

Ashley Marshman
Head of Business Channels
Business Channels