


FOR CONTINUATION REFER TO DRAWING 24-217/235



FW PUMP STATION EMERGENCY STORAGE -
 BASED ON 121 CONTRIBUTING DWELLINGS
 TO SSG - 121 * 180 (DWELLING) = 194 cu.m
 TO BDG REGS (ASSUMING 5 PEOPLE PER
 DWELLING) - 121 * 150 (HEADWAY) * 5 = 906 cu.m

NOTES

1. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER RELATED DRAWINGS ISSUED BY THE ARCHITECT AND ENGINEER.
2. THIS DRAWING IS FOR PLANNING PURPOSES ONLY.
3. DO NOT SCALE FROM THIS DRAWING.
4. PROPOSED LAYOUT BASED UPON PLACE BY DESIGN ARCHITECT'S DRAWING NUMBER 2138-1100B RECEIVED 27.08.25.

LEGEND:

- SITE BOUNDARY
- EXISTING FOUL WATER SEWER AND MANHOLE
- EXISTING SURFACE WATER SEWER AND MANHOLE
- EXISTING PUMP STATION
- SURVEYED LOCATION OF GAS MAIN WITH 3 m BUFFER
- PROPOSED FOUL WATER (FW) PUMP STATION (PS) WITH 15 m BUFFER TO SSG (FOR PS TYPE 3)
- PROPOSED CONCEPT FOUL WATER SEWER AND MANHOLE
- PROPOSED FOUL WATER RISING MAIN

NOT FOR CONSTRUCTION -
SUBJECT TO APPROVAL

| | | | | | |
|-----|---|----|-----|-----|----------|
| C | UPDATED TO SUIT LATEST LAYOUT AND LPA COMMENTS | LG | JK | LG | 28.08.25 |
| B | UPDATED TO SUIT LATEST LAYOUT AND LPA COMMENTS | LG | JK | BAC | 30.06.25 |
| A | UPDATED TO SUIT LATEST LAYOUT AND REDROW COMMENTS | EW | LG | BAC | 16.04.25 |
| Rev | Amendments | Dm | Chk | App | Date |

ODYSSEY

Unit 1 Pucknall Farm
Dores Lane
Bramfield
Romsey SO51 0DZ

Telephone: 01794 537980
Fax: 01266 331134
E: info@odysseyconsult.co.uk
W: www.odysseyconsult.co.uk

Job Title
**BILSHAM ROAD,
 YAPTON**

Drawing Title
**PROPOSED FOUL WATER
 DRAINAGE LAYOUT, SHEET 8 OF 8**

Client
REDROW

| | | |
|--------------------|--------------------------|-----------------|
| Scale 1:200 @A1 | Date APR 25 | Designed LG |
| Drawn EW | Checked LG | Approved BAC |
| Job No 24-217 | Drawing No 24-217-237 | Rev C |