

From: [REDACTED]
Sent: 22 January 2019 09:28
To: Simon Davis <Simon.Davis@arun.gov.uk> [REDACTED]
Subject: RE: Y/49/18/PL - Proposed Pre Commencement Conditions


Ellie

I am happy with these – Thank you

Kind regards

Kevin

Kevin Wawman
Director
Crayfern Homes Ltd



Victoria House, 14 St Johns Road, Hedge End, Southampton SO30 4AB





From: Simon Davis <Simon.Davis@arun.gov.uk>
Sent: 21 January 2019 17:06
To: [REDACTED]
Cc: [REDACTED]
Subject: Y/49/18/PL - Proposed Pre Commencement Conditions

Dear Ellie,

In starting the committee report, I have been able to draw up a list of the pre-commencement conditions as already requested by consultees (WSCC, Tree Officer, Drainage Engineers) and I now provide this for you as I will need your approval to attach these to the decision. Please let me know whether you can agree to these conditions.

1	No development shall take place, including any works of demolition, until a Construction Management Plan has been submitted to and approved in writing by the Local Planning Authority. Thereafter the approved Plan shall be implemented and adhered to throughout the entire construction period. The Plan shall provide details as appropriate but not necessarily be restricted to the following matters, - the anticipated number, frequency and types of vehicles used during construction, - the method of access and routing of vehicles during construction, - the parking of vehicles by site operatives and visitors, - the loading and unloading of plant, materials and waste, - the storage of plant and materials used in construction of the development, - the erection and maintenance of security hoarding, - the provision of wheel washing facilities and other works required to mitigate the impact of construction upon the public highway (including the provision of temporary Traffic Regulation Orders), - details of public engagement both prior to and during construction works. Reason: In the interests of highway safety and the amenities of the area in accordance with policies D DM1 and T SP1 of the Arun Local Plan and the National Planning Policy Framework. This is required to be a pre-commencement condition because it is necessary to have the site set-up agreed prior to access by construction traffic.
2	Prior to the commencement of construction/demolition work or any works to site levels, the developer must ensure that the protective fencing as described is correctly installed as per the Tree Protection Plan, ref. 18062-BT1. Reason: To comply with BS5837 and policy ENV DM4 to ensure that retained trees are afforded due respect and appropriate levels of protection such that their ongoing health and vitality is not compromised and they can continue to enhance the landscape and amenity of the area. This is required to be a pre-commencement condition because it is necessary to ensure the protection of the protected and otherwise significant trees prior to any change to the surface of the site.
3	Development shall not commence until full details of the proposed surface water drainage scheme have been submitted to and approved in writing by the Local Planning Authority. The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, the recommendations of the SUDS Manual produced by CIRIA.

	Winter groundwater monitoring to establish highest annual ground water levels and Percolation testing to BRE 365, or similar approved, will be required to support the design of any Infiltration drainage. No building shall be occupied until the complete surface water drainage system serving the property has been implemented in accordance with the agreed details and the details so agreed shall be maintained in good working order in perpetuity. Reason: To ensure that the proposed development is satisfactorily drained in accordance with policies W SP1, W DM1, W DM2 and W DM3 of the Arun Local Plan. This is required to be a pre-commencement condition because it is necessary to implement the surface water drainage system prior to commencing any building works.
4	Development shall not commence until full details of the maintenance and management of the surface water drainage system is set out in a site-specific maintenance manual and submitted to, and approved in writing, by the Local Planning Authority. The manual is to include details of financial management and arrangements for the replacement of major components at the end of the manufacturer's recommended design life. Upon completed construction of the surface water drainage system, the owner of management company shall strictly adhere to and implement the recommendations contained within the manual. Reason: To ensure that the proposed development is satisfactorily drained in accordance with policies W DM1, W DM2 and W DM3 of the Arun Local Plan. It is considered necessary for this to be a pre-commencement condition to ensure that the future maintenance and funding arrangements for the surface water disposal scheme are agreed before construction commences.

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk
Please note that I typically work from home on Thursdays when I am unreachable on my work phone

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.
