

RSK LDE		Page 1
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions Network 2018.1.1		

STORM SEWER DESIGN by the Modified Rational Method

Design Criteria for Surface Network 1

Pipe Sizes STANDARD Manhole Sizes STANDARD

FEH Rainfall Model

Return Period (years)	100
FEH Rainfall Version	1999
Site Location GB 497500 102350 SU 97500 02350	
C (1km)	-0.025
D1 (1km)	0.390
D2 (1km)	0.245
D3 (1km)	0.403
E (1km)	0.310
F (1km)	2.321
Maximum Rainfall (mm/hr)	50
Maximum Time of Concentration (mins)	30
Foul Sewage (l/s/ha)	0.000
Volumetric Runoff Coeff.	0.750
PIMP (%)	100
Add Flow / Climate Change (%)	40
Minimum Backdrop Height (m)	0.200
Maximum Backdrop Height (m)	1.500
Min Design Depth for Optimisation (m)	1.200
Min Vel for Auto Design only (m/s)	1.00
Min Slope for Optimisation (1:X)	500

Designed with Level Soffits

Time Area Diagram for Surface Network 1

Time (mins)	Area (ha)	Time (mins)	Area (ha)	Time (mins)	Area (ha)	Time (mins)	Area (ha)	Time (mins)	Area (ha)	Time (mins)	Area (ha)
0-4	0.015	8-12	0.566	16-20	0.873	24-28	0.844	32-36	0.011	40-44	0.012
4-8	0.363	12-16	0.841	20-24	0.573	28-32	0.216	36-40	0.000	44-48	0.016

Total Area Contributing (ha) = 4.331

Total Pipe Volume (m³) = 165.176

Network Design Table for Surface Network 1

« - Indicates pipe capacity < flow

PN Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design
------------------	-------------	----------------	----------------	----------------	--------------------	-----------	-------------	-------------	--------------	----------------

Network Results Table

©1982-2018 Innovyze

RSK LDE		Page 2																								
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data																									
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by																									
XP Solutions	Network 2018.1.1																									
<u>Network Design Table for Surface Network 1</u> <table><tr><td>PN</td><td>Rain</td><td>T.C.</td><td>US/IL</td><td>Σ I</td><td>Area</td><td>Σ Base</td><td>Foul</td><td>Add Flow</td><td>Vel</td><td>Cap</td><td>Flow</td></tr><tr><td></td><td>(mm/hr)</td><td>(mins)</td><td>(m)</td><td></td><td>(ha)</td><td>Flow (l/s)</td><td>(l/s)</td><td>(l/s)</td><td>(m/s)</td><td>(l/s)</td><td>(l/s)</td></tr></table>			PN	Rain	T.C.	US/IL	Σ I	Area	Σ Base	Foul	Add Flow	Vel	Cap	Flow		(mm/hr)	(mins)	(m)		(ha)	Flow (l/s)	(l/s)	(l/s)	(m/s)	(l/s)	(l/s)
PN	Rain	T.C.	US/IL	Σ I	Area	Σ Base	Foul	Add Flow	Vel	Cap	Flow															
	(mm/hr)	(mins)	(m)		(ha)	Flow (l/s)	(l/s)	(l/s)	(m/s)	(l/s)	(l/s)															
©1982-2018 Innovyze																										

RSK LDE										Page 3	
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT					Drove Lane, Yapton Surface Water Network Calculations - FEH Data						
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...					Designed by AMuthusami Checked by						
XP Solutions					Network 2018.1.1						
<u>Network Design Table for Surface Network 1</u>											
PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design
1.000	79.638	0.000	0.0	0.028	5.00	0.0	0.600	o	150	Pipe/Conduit	
1.001	3.896	0.050	77.9	0.009	0.00	0.0	0.600	o	150	Pipe/Conduit	
1.002	31.170	0.240	129.9	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
1.003	7.034	0.070	100.5	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
1.004	34.423	0.000	0.0	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit	
2.000	48.100	0.370	130.0	0.016	5.00	0.0	0.600	o	150	Pipe/Conduit	
2.001	6.496	0.050	129.9	0.021	0.00	0.0	0.600	o	150	Pipe/Conduit	
2.002	9.686	0.075	129.1	0.014	0.00	0.0	0.600	o	150	Pipe/Conduit	
2.003	32.873	0.270	121.8	0.041	0.00	0.0	0.600	o	150	Pipe/Conduit	
2.004	2.949	0.040	73.7	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
2.005	2.131	0.010	213.1	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
1.005	49.746	0.100	497.5	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit	
3.000	7.158	0.060	119.3	0.015	5.00	0.0	0.600	o	150	Pipe/Conduit	
3.001	5.290	0.080	66.1	0.047	0.00	0.0	0.600	o	150	Pipe/Conduit	
3.002	3.462	0.040	86.6	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
3.003	23.754	0.000	0.0	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
3.004	11.051	0.075	147.3	0.018	0.00	0.0	0.600	o	150	Pipe/Conduit	
3.005	6.763	0.050	135.3	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
<u>Network Results Table</u>											
PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)	
1.000	50.00	19.32	5.600	0.028	0.0	0.0	1.5	0.09	1.6«	5.3	
1.001	50.00	19.38	6.200	0.037	0.0	0.0	2.0	1.14	20.1	7.0	
1.002	50.00	19.97	6.150	0.037	0.0	0.0	2.0	0.88	15.6	7.0	
1.003	50.00	20.08	5.910	0.037	0.0	0.0	2.0	1.00	17.7	7.0	
1.004	50.00	23.94	5.250	0.037	0.0	0.0	2.0	0.15	10.5	7.0	
2.000	50.00	5.91	6.325	0.016	0.0	0.0	0.9	0.88	15.5	3.0	
2.001	50.00	6.03	5.955	0.037	0.0	0.0	2.0	0.88	15.6	7.0	
2.002	50.00	6.22	5.905	0.051	0.0	0.0	2.8	0.88	15.6	9.7	
2.003	50.00	6.82	5.830	0.092	0.0	0.0	5.0	0.91	16.1«	17.4	
2.004	50.00	6.86	5.560	0.092	0.0	0.0	5.0	1.17	20.7	17.4	
2.005	50.00	6.91	5.520	0.092	0.0	0.0	5.0	0.68	12.1«	17.4	
1.005	50.00	25.12	5.250	0.129	0.0	0.0	7.0	0.70	49.4	24.5	
3.000	50.00	5.13	5.880	0.015	0.0	0.0	0.8	0.92	16.2	2.8	
3.001	50.00	5.20	5.820	0.062	0.0	0.0	3.4	1.24	21.9	11.8	
3.002	50.00	5.25	5.740	0.062	0.0	0.0	3.4	1.08	19.1	11.8	
3.003	50.00	9.53	5.700	0.062	0.0	0.0	3.4	0.09	1.6«	11.8	
3.004	50.00	9.75	6.115	0.080	0.0	0.0	4.3	0.83	14.6«	15.2	
3.005	50.00	9.88	6.040	0.080	0.0	0.0	4.3	0.86	15.2	15.2	
©1982-2018 Innovyze											

RSK LDE										Page 4	
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT					Drove Lane, Yapton Surface Water Network Calculations - FEH Data						
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...					Designed by AMuthusami Checked by						
XP Solutions					Network 2018.1.1						
Network Design Table for Surface Network 1											
PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design
4.000	14.266	0.110	129.7	0.021	5.00	0.0	0.600	o	150	Pipe/Conduit	
3.006	14.865	0.110	135.1	0.038	0.00	0.0	0.600	o	150	Pipe/Conduit	
3.007	9.626	0.230	41.9	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
5.000	3.524	0.000	0.0	0.028	5.00	0.0	0.600	o	150	Pipe/Conduit	
5.001	3.983	0.000	0.0	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
5.002	23.848	0.120	198.7	0.000	0.00	0.0	0.600	o	225	Pipe/Conduit	
6.000	6.882	0.204	33.7	0.068	5.00	0.0	0.600	o	150	Pipe/Conduit	
3.008	27.083	0.097	279.2	0.026	0.00	0.0	0.600	o	300	Pipe/Conduit	
3.009	12.356	0.044	280.8	0.024	0.00	0.0	0.600	o	300	Pipe/Conduit	
3.010	11.015	0.039	282.4	0.054	0.00	0.0	0.600	o	300	Pipe/Conduit	
3.011	18.288	0.100	182.9	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit	
7.000	12.139	0.087	139.5	0.070	5.00	0.0	0.600	o	150	Pipe/Conduit	
3.012	8.479	0.040	212.0	0.030	0.00	0.0	0.600	o	300	Pipe/Conduit	
3.013	4.885	0.030	162.8	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit	
1.006	65.460	0.030	2182.0	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit	
Network Results Table											
PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)	
4.000	50.00	5.27	6.100	0.021	0.0	0.0	1.1	0.88	15.6	4.0	
3.006	50.00	10.17	5.990	0.139	0.0	0.0	7.5	0.86	15.2«	26.4	
3.007	50.00	10.27	5.880	0.139	0.0	0.0	7.5	1.56	27.6	26.4	
5.000	50.00	5.63	5.620	0.028	0.0	0.0	1.5	0.09	1.6«	5.3	
5.001	50.00	6.35	5.620	0.028	0.0	0.0	1.5	0.09	1.6«	5.3	
5.002	50.00	6.78	5.620	0.028	0.0	0.0	1.5	0.92	36.7	5.3	
6.000	50.00	5.07	5.854	0.068	0.0	0.0	3.7	1.74	30.7	12.9	
3.008	50.00	10.75	5.500	0.261	0.0	0.0	14.1	0.94	66.2	49.5	
3.009	50.00	10.97	5.403	0.285	0.0	0.0	15.4	0.93	66.0	54.0	
3.010	50.00	11.17	5.359	0.339	0.0	0.0	18.4	0.93	65.8	64.3	
3.011	50.00	11.43	5.320	0.339	0.0	0.0	18.4	1.16	82.0	64.3	
7.000	50.00	5.24	5.457	0.070	0.0	0.0	3.8	0.85	15.0	13.3	
3.012	50.00	11.56	5.220	0.439	0.0	0.0	23.8	1.08	76.1«	83.2	
3.013	50.00	11.63	5.180	0.439	0.0	0.0	23.8	1.23	86.9	83.2	
1.006	50.00	28.45	5.150	0.568	0.0	0.0	30.8	0.33	23.2«	107.7	
©1982-2018 Innovyze											

RSK LDE										Page 5		
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT						Drove Lane, Yapton Surface Water Network Calculations - FEH Data						
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...						Designed by AMuthusami Checked by						
XP Solutions						Network 2018.1.1						
<u>Network Design Table for Surface Network 1</u>												
PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design	
8.000	22.407	0.260	86.2	0.024	5.00	0.0	0.600	o	150	Pipe/Conduit		
9.000	8.117	0.060	135.3	0.050	5.00	0.0	0.600	o	150	Pipe/Conduit		
8.001	2.047	0.020	102.4	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit		
1.007	11.501	0.000	0.0	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		
1.008	2.310	0.000	0.0	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		
1.009	15.488	0.160	96.8	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit		
1.010	13.870	0.110	126.1	0.017	0.00	0.0	0.600	o	150	Pipe/Conduit		
10.000	19.391	0.150	129.3	0.016	5.00	0.0	0.600	o	150	Pipe/Conduit		
10.001	12.727	0.100	127.3	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit		
10.002	21.907	0.120	182.6	0.034	0.00	0.0	0.600	o	150	Pipe/Conduit		
10.003	6.116	0.070	87.4	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit		
10.004	20.997	0.350	60.0	0.014	0.00	0.0	0.600	o	150	Pipe/Conduit		
11.000	13.280	0.130	102.2	0.025	5.00	0.0	0.600	o	150	Pipe/Conduit		
10.005	11.443	0.110	104.0	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit		
10.006	20.944	0.150	139.6	0.037	0.00	0.0	0.600	o	150	Pipe/Conduit		
<u>Network Results Table</u>												
PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul Flow (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)		
8.000	50.00	5.34	5.550	0.024	0.0	0.0	1.3	1.08	19.1	4.5		
9.000	50.00	5.16	5.350	0.050	0.0	0.0	2.7	0.86	15.2	9.5		
8.001	50.00	5.38	5.290	0.074	0.0	0.0	4.0	0.99	17.5	14.0		
1.007	50.00	29.74	5.120	0.642	0.0	0.0	34.8	0.15	10.5«	121.7		
1.008	50.00	30.00	5.120	0.642	0.0	0.0	34.8	0.15	10.5«	121.7		
1.009	50.00	30.00	5.120	0.642	0.0	0.0	34.8	1.02	18.1«	121.7		
1.010	50.00	30.00	4.960	0.659	0.0	0.0	35.7	0.89	15.8«	124.9		
10.000	50.00	5.37	6.050	0.016	0.0	0.0	0.9	0.88	15.6	3.0		
10.001	50.00	5.60	5.900	0.016	0.0	0.0	0.9	0.89	15.7	3.0		
10.002	50.00	6.10	5.800	0.050	0.0	0.0	2.7	0.74	13.1	9.5		
10.003	50.00	6.19	5.680	0.050	0.0	0.0	2.7	1.08	19.0	9.5		
10.004	50.00	6.46	5.610	0.064	0.0	0.0	3.5	1.30	23.0	12.1		
11.000	50.00	5.22	5.390	0.025	0.0	0.0	1.4	0.99	17.6	4.7		
10.005	50.00	6.66	5.260	0.089	0.0	0.0	4.8	0.98	17.4	16.9		
10.006	50.00	7.07	5.150	0.126	0.0	0.0	6.8	0.85	15.0«	23.9		
©1982-2018 Innovyze												

RSK LDE										Page 6	
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT					Drove Lane, Yapton Surface Water Network Calculations - FEH Data						
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...					Designed by AMuthusami Checked by						
XP Solutions					Network 2018.1.1						
Network Design Table for Surface Network 1											
PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design
10.007	27.264	0.050	545.3	0.038	0.00	0.0	0.600	o	150	Pipe/Conduit	
10.008	8.359	0.050	167.2	0.017	0.00	0.0	0.600	o	150	Pipe/Conduit	
10.009	8.609	0.050	172.2	0.008	0.00	0.0	0.600	o	150	Pipe/Conduit	
1.011	5.898	0.050	118.0	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
1.012	17.211	0.086	200.1	0.036	0.00	0.0	0.600	o	225	Pipe/Conduit	
1.013	9.176	0.046	199.5	0.000	0.00	0.0	0.600	o	225	Pipe/Conduit	
12.000	28.335	0.190	149.1	0.020	5.00	0.0	0.600	o	150	Pipe/Conduit	
12.001	2.239	0.000	0.0	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
1.014	33.907	0.126	269.1	0.000	0.00	0.0	0.600	o	225	Pipe/Conduit	
1.015	27.240	0.190	143.4	0.000	0.00	0.0	0.600	o	225	Pipe/Conduit	
1.016	12.467	0.102	122.2	0.000	0.00	0.0	0.600	o	225	Pipe/Conduit	
13.000	12.825	0.140	91.6	0.052	5.00	0.0	0.600	o	150	Pipe/Conduit	
13.001	8.557	0.090	95.1	0.015	0.00	0.0	0.600	o	150	Pipe/Conduit	
13.002	12.946	0.110	117.7	0.023	0.00	0.0	0.600	o	150	Pipe/Conduit	
13.003	15.042	0.200	75.2	0.025	0.00	0.0	0.600	o	150	Pipe/Conduit	
1.017	46.870	0.050	937.4	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit	
Network Results Table											
PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)	
10.007	50.00	8.14	5.000	0.164	0.0	0.0	8.9	0.42	7.5«	31.1	
10.008	50.00	8.32	4.950	0.181	0.0	0.0	9.8	0.77	13.7«	34.3	
10.009	50.00	8.51	4.900	0.189	0.0	0.0	10.2	0.76	13.5«	35.8	
1.011	50.00	30.00	4.850	0.848	0.0	0.0	45.9	0.92	16.3«	160.8	
1.012	50.00	30.00	4.800	0.884	0.0	0.0	47.9	0.92	36.6«	167.6	
1.013	50.00	30.00	4.714	0.884	0.0	0.0	47.9	0.92	36.7«	167.6	
12.000	50.00	5.58	5.250	0.020	0.0	0.0	1.1	0.82	14.5	3.8	
12.001	50.00	5.98	5.060	0.020	0.0	0.0	1.1	0.09	1.6«	3.8	
1.014	50.00	30.00	4.668	0.904	0.0	0.0	49.0	0.79	31.5«	171.4	
1.015	50.00	30.00	4.542	0.904	0.0	0.0	49.0	1.09	43.3«	171.4	
1.016	50.00	30.00	4.352	0.904	0.0	0.0	49.0	1.18	47.0«	171.4	
13.000	50.00	5.20	4.790	0.052	0.0	0.0	2.8	1.05	18.6	9.9	
13.001	50.00	5.34	4.650	0.067	0.0	0.0	3.6	1.03	18.2	12.7	
13.002	50.00	5.58	4.560	0.090	0.0	0.0	4.9	0.93	16.4«	17.1	
13.003	50.00	5.79	4.450	0.115	0.0	0.0	6.2	1.16	20.5«	21.8	
1.017	50.00	30.00	4.250	1.019	0.0	0.0	55.2	0.51	35.7«	193.2	
©1982-2018 Innovyze											

RSK LDE										Page 7	
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT					Drove Lane, Yapton Surface Water Network Calculations - FEH Data						
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...					Designed by AMuthusami Checked by						
XP Solutions					Network 2018.1.1						
<u>Network Design Table for Surface Network 1</u>											
PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design
14.000	62.024	0.475	130.6	0.058	5.00	0.0	0.600	o	150	Pipe/Conduit	
15.000	41.672	0.330	126.3	0.041	5.00	0.0	0.600	o	150	Pipe/Conduit	
14.001	24.212	0.200	121.1	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
14.002	3.715	0.330	11.3	0.032	0.00	0.0	0.600	o	150	Pipe/Conduit	
14.003	37.147	0.290	128.1	0.026	0.00	0.0	0.600	o	300	Pipe/Conduit	
14.004	35.580	0.350	101.7	0.042	0.00	0.0	0.600	o	300	Pipe/Conduit	
16.000	19.366	0.160	121.0	0.032	5.00	0.0	0.600	o	150	Pipe/Conduit	
16.001	7.069	0.260	27.2	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
14.005	26.222	0.100	262.2	0.044	0.00	0.0	0.600	o	300	Pipe/Conduit	
14.006	5.601	0.030	186.7	0.056	0.00	0.0	0.600	o	300	Pipe/Conduit	
14.007	5.773	0.060	96.2	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit	
17.000	25.210	0.550	45.8	0.023	5.00	0.0	0.600	o	150	Pipe/Conduit	
18.000	12.463	0.280	44.5	0.023	5.00	0.0	0.600	o	150	Pipe/Conduit	
17.001	9.756	0.080	122.0	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
17.002	32.780	0.420	78.0	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
<u>Network Results Table</u>											
PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul Flow (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)	
14.000	50.00	6.18	6.185	0.058	0.0	0.0	3.1	0.88	15.5	11.0	
15.000	50.00	5.78	6.040	0.041	0.0	0.0	2.2	0.89	15.8	7.8	
14.001	50.00	6.62	5.710	0.099	0.0	0.0	5.4	0.91	16.1	18.8	
14.002	50.00	6.64	5.510	0.131	0.0	0.0	7.1	3.02	53.4	24.8	
14.003	50.00	7.09	5.030	0.157	0.0	0.0	8.5	1.39	98.1	29.8	
14.004	50.00	7.47	4.740	0.199	0.0	0.0	10.8	1.56	110.2	37.7	
16.000	50.00	5.35	4.960	0.032	0.0	0.0	1.7	0.91	16.1	6.1	
16.001	50.00	5.41	4.800	0.032	0.0	0.0	1.7	1.94	34.3	6.1	
14.005	50.00	7.92	4.390	0.275	0.0	0.0	14.9	0.97	68.3	52.1	
14.006	50.00	8.00	4.290	0.331	0.0	0.0	17.9	1.15	81.1	62.8	
14.007	50.00	8.06	4.260	0.331	0.0	0.0	17.9	1.60	113.3	62.8	
17.000	50.00	5.28	5.400	0.023	0.0	0.0	1.2	1.49	26.3	4.4	
18.000	50.00	5.14	5.130	0.023	0.0	0.0	1.2	1.51	26.7	4.4	
17.001	50.00	5.46	4.850	0.046	0.0	0.0	2.5	0.91	16.1	8.7	
17.002	50.00	5.94	4.770	0.046	0.0	0.0	2.5	1.14	20.1	8.7	
©1982-2018 Innovyze											

RSK LDE										Page 8	
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT					Drove Lane, Yapton Surface Water Network Calculations - FEH Data						
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...					Designed by AMuthusami Checked by						
XP Solutions					Network 2018.1.1						
<u>Network Design Table for Surface Network 1</u>											
PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design
1.018	6.009	0.050	120.2	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit	
1.019	10.456	0.050	209.1	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit	
1.020	31.084	0.050	621.7	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit	
1.021	34.007	0.215	158.2	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit	
19.000	13.799	0.067	206.0	0.035	5.00	0.0	0.600	o	225	Pipe/Conduit	
19.001	21.664	0.106	204.4	0.036	0.00	0.0	0.600	o	225	Pipe/Conduit	
20.000	8.199	0.061	134.4	0.024	5.00	0.0	0.600	o	150	Pipe/Conduit	
19.002	15.413	0.055	280.2	0.029	0.00	0.0	0.600	o	300	Pipe/Conduit	
19.003	20.973	0.075	279.6	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit	
19.004	27.653	0.099	279.3	0.029	0.00	0.0	0.600	o	300	Pipe/Conduit	
19.005	29.912	0.108	277.0	0.022	0.00	0.0	0.600	o	300	Pipe/Conduit	
19.006	10.054	0.045	223.4	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit	
19.007	20.595	0.087	236.7	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit	
19.008	6.292	0.028	224.7	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit	
21.000	4.298	0.000	0.0	0.067	5.00	0.0	0.600	o	150	Pipe/Conduit	
21.001	13.399	0.160	83.7	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
21.002	23.360	0.116	201.4	0.000	0.00	0.0	0.600	o	225	Pipe/Conduit	
<u>Network Results Table</u>											
PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)	
1.018	50.00	30.00	4.200	1.396	0.0	0.0	75.6	1.43	101.3	264.7	
1.019	50.00	30.00	4.150	1.396	0.0	0.0	75.6	1.08	76.6	264.7	
1.020	50.00	30.00	4.100	1.396	0.0	0.0	75.6	0.62	44.1	264.7	
1.021	50.00	30.00	4.050	1.396	0.0	0.0	75.6	1.25	88.2	264.7	
19.000	50.00	5.25	5.660	0.035	0.0	0.0	1.9	0.91	36.1	6.6	
19.001	50.00	5.65	5.593	0.071	0.0	0.0	3.8	0.91	36.2	13.5	
20.000	50.00	5.16	5.623	0.024	0.0	0.0	1.3	0.87	15.3	4.5	
19.002	50.00	5.92	5.412	0.124	0.0	0.0	6.7	0.93	66.0	23.5	
19.003	50.00	6.30	5.357	0.124	0.0	0.0	6.7	0.94	66.1	23.5	
19.004	50.00	6.79	5.282	0.153	0.0	0.0	8.3	0.94	66.1	29.0	
19.005	50.00	7.32	5.183	0.175	0.0	0.0	9.5	0.94	66.4	33.2	
19.006	50.00	7.48	5.075	0.175	0.0	0.0	9.5	1.05	74.1	33.2	
19.007	50.00	7.82	5.030	0.175	0.0	0.0	9.5	1.02	71.9	33.2	
19.008	50.00	7.92	4.943	0.175	0.0	0.0	9.5	1.04	73.8	33.2	
21.000	50.00	5.77	5.900	0.067	0.0	0.0	3.6	0.09	1.6	12.7	
21.001	50.00	5.98	5.900	0.067	0.0	0.0	3.6	1.10	19.4	12.7	
21.002	50.00	6.40	5.665	0.067	0.0	0.0	3.6	0.92	36.5	12.7	
©1982-2018 Innovyze											

RSK LDE										Page 9	
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT					Drove Lane, Yapton Surface Water Network Calculations - FEH Data						
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...					Designed by AMuthusami Checked by						
XP Solutions					Network 2018.1.1						
<u>Network Design Table for Surface Network 1</u>											
PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design
21.003	19.767	0.099	199.7	0.061	0.00	0.0	0.600	o	225	Pipe/Conduit	
21.004	10.130	0.050	202.6	0.051	0.00	0.0	0.600	o	225	Pipe/Conduit	
21.005	21.349	0.105	203.3	0.043	0.00	0.0	0.600	o	225	Pipe/Conduit	
21.006	20.837	0.101	206.3	0.000	0.00	0.0	0.600	o	225	Pipe/Conduit	
22.000	26.569	0.530	50.1	0.019	5.00	0.0	0.600	o	150	Pipe/Conduit	
22.001	3.435	0.231	14.9	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
23.000	6.758	0.381	17.7	0.010	5.00	0.0	0.600	o	150	Pipe/Conduit	
21.007	26.521	0.132	200.9	0.033	0.00	0.0	0.600	o	225	Pipe/Conduit	
21.008	10.259	0.052	197.3	0.000	0.00	0.0	0.600	o	225	Pipe/Conduit	
21.009	4.237	0.020	211.9	0.062	0.00	0.0	0.600	o	225	Pipe/Conduit	
21.010	3.485	0.000	0.0	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit	
19.009	7.791	0.000	0.0	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit	
19.010	24.064	0.165	145.8	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit	
19.011	11.457	0.000	0.0	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit	
24.000	18.358	0.150	122.4	0.019	5.00	0.0	0.600	o	150	Pipe/Conduit	
24.001	23.010	0.190	121.1	0.016	0.00	0.0	0.600	o	150	Pipe/Conduit	
24.002	11.017	0.470	23.4	0.010	0.00	0.0	0.600	o	150	Pipe/Conduit	
<u>Network Results Table</u>											
PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)	
21.003	50.00	6.76	5.549	0.128	0.0	0.0	6.9	0.92	36.6	24.3	
21.004	50.00	6.94	5.450	0.179	0.0	0.0	9.7	0.91	36.4	33.9	
21.005	50.00	7.33	5.400	0.222	0.0	0.0	12.0	0.91	36.3«	42.1	
21.006	50.00	7.71	5.295	0.222	0.0	0.0	12.0	0.91	36.0«	42.1	
22.000	50.00	5.31	6.030	0.019	0.0	0.0	1.0	1.42	25.2	3.6	
22.001	50.00	5.33	5.500	0.019	0.0	0.0	1.0	2.63	46.4	3.6	
23.000	50.00	5.05	5.650	0.010	0.0	0.0	0.5	2.40	42.5	1.9	
21.007	50.00	8.20	5.194	0.284	0.0	0.0	15.4	0.92	36.5«	53.8	
21.008	50.00	8.38	5.062	0.284	0.0	0.0	15.4	0.93	36.9«	53.8	
21.009	50.00	8.46	5.010	0.346	0.0	0.0	18.7	0.89	35.6«	65.6	
21.010	50.00	8.85	4.915	0.346	0.0	0.0	18.7	0.15	10.5«	65.6	
19.009	50.00	9.72	4.915	0.521	0.0	0.0	28.2	0.15	10.5«	98.8	
19.010	50.00	10.03	4.915	0.521	0.0	0.0	28.2	1.30	91.9«	98.8	
19.011	50.00	11.31	4.750	0.521	0.0	0.0	28.2	0.15	10.5«	98.8	
24.000	50.00	5.34	6.310	0.019	0.0	0.0	1.0	0.91	16.0	3.6	
24.001	50.00	5.76	6.160	0.035	0.0	0.0	1.9	0.91	16.1	6.6	
24.002	50.00	5.85	5.970	0.045	0.0	0.0	2.4	2.09	36.9	8.5	
©1982-2018 Innovyze											

RSK LDE										Page 10	
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT					Drove Lane, Yapton Surface Water Network Calculations - FEH Data						
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...					Designed by AMuthusami Checked by						
XP Solutions					Network 2018.1.1						
<u>Network Design Table for Surface Network 1</u>											
PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design
24.003	10.252	0.500	20.5	0.009	0.00	0.0	0.600	o	150	Pipe/Conduit	
19.012	25.858	0.110	235.1	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit	
25.000	17.917	0.050	358.3	0.048	5.00	0.0	0.600	o	150	Pipe/Conduit	
25.001	17.329	0.020	866.5	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
25.002	33.286	0.030	1109.5	0.059	0.00	0.0	0.600	o	150	Pipe/Conduit	
25.003	6.308	0.000	0.0	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
25.004	18.925	0.010	1892.5	0.021	0.00	0.0	0.600	o	150	Pipe/Conduit	
25.005	8.662	0.000	0.0	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
25.006	18.362	0.020	918.1	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
25.007	6.116	0.010	611.6	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
26.000	46.370	0.050	927.4	0.055	5.00	0.0	0.600	o	300	Pipe/Conduit	
26.001	9.129	0.150	60.9	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
26.002	16.992	0.050	339.8	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
26.003	8.356	0.000	0.0	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
26.004	12.917	0.090	143.5	0.056	0.00	0.0	0.600	o	150	Pipe/Conduit	
27.000	17.312	0.115	150.5	0.019	5.00	0.0	0.600	o	150	Pipe/Conduit	
19.013	15.685	0.040	392.1	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit	
<u>Network Results Table</u>											
PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	I.Area (ha)	Base Flow (l/s)	Foul Flow (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)	
24.003	50.00	5.92	5.500	0.054	0.0	0.0	2.9	2.23	39.5	10.2	
19.012	50.00	11.73	4.750	0.575	0.0	0.0	31.1	1.02	72.2«	109.0	
25.000	50.00	5.57	6.050	0.048	0.0	0.0	2.6	0.53	9.3	9.1	
25.001	50.00	6.43	6.000	0.048	0.0	0.0	2.6	0.33	5.9«	9.1	
25.002	50.00	8.32	5.980	0.107	0.0	0.0	5.8	0.29	5.2«	20.3	
25.003	50.00	9.46	5.950	0.107	0.0	0.0	5.8	0.09	1.6«	20.3	
25.004	50.00	10.87	5.950	0.128	0.0	0.0	6.9	0.22	3.9«	24.3	
25.005	50.00	12.43	5.940	0.128	0.0	0.0	6.9	0.09	1.6«	24.3	
25.006	50.00	13.38	5.940	0.128	0.0	0.0	6.9	0.32	5.7«	24.3	
25.007	50.00	13.63	5.920	0.128	0.0	0.0	6.9	0.40	7.1«	24.3	
26.000	50.00	6.52	6.100	0.055	0.0	0.0	3.0	0.51	35.9	10.4	
26.001	50.00	6.64	6.200	0.055	0.0	0.0	3.0	1.29	22.8	10.4	
26.002	50.00	7.16	6.050	0.055	0.0	0.0	3.0	0.54	9.5«	10.4	
26.003	50.00	8.67	6.000	0.055	0.0	0.0	3.0	0.09	1.6«	10.4	
26.004	50.00	8.92	6.000	0.111	0.0	0.0	6.0	0.84	14.8«	21.0	
27.000	50.00	5.35	6.025	0.019	0.0	0.0	1.0	0.82	14.4	3.6	
19.013	50.00	13.96	4.640	0.833	0.0	0.0	45.1	0.79	55.7«	157.9	
©1982-2018 Innovyze											

RSK LDE										Page 11		
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT					Drove Lane, Yapton Surface Water Network Calculations - FEH Data							
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...					Designed by AMuthusami Checked by							
XP Solutions					Network 2018.1.1							
<u>Network Design Table for Surface Network 1</u>												
PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section	Type	Auto Design
28.000	9.451	0.090	105.0	0.034	5.00	0.0	0.600	o	150	Pipe/Conduit		
28.001	9.804	0.190	51.6	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit		
19.014	34.119	0.140	243.7	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		
29.000	7.073	0.190	37.2	0.033	5.00	0.0	0.600	o	150	Pipe/Conduit		
29.001	13.576	0.120	113.1	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit		
29.002	8.815	0.290	30.4	0.078	0.00	0.0	0.600	o	150	Pipe/Conduit		
19.015	23.076	0.000	0.0	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		
30.000	9.323	0.840	11.1	0.015	5.00	0.0	0.600	o	150	Pipe/Conduit		
19.016	15.391	0.060	256.5	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		
31.000	10.092	0.450	22.4	0.028	5.00	0.0	0.600	o	150	Pipe/Conduit		
19.017	14.640	0.000	0.0	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		
32.000	19.257	0.150	128.4	0.032	5.00	0.0	0.600	o	150	Pipe/Conduit		
32.001	21.001	0.160	131.3	0.011	0.00	0.0	0.600	o	150	Pipe/Conduit		
<u>Network Results Table</u>												
PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)		
28.000	50.00	5.16	5.880	0.034	0.0	0.0	1.8	0.98	17.3	6.4		
28.001	50.00	5.28	5.790	0.034	0.0	0.0	1.8	1.40	24.8	6.4		
19.014	50.00	14.53	4.600	0.867	0.0	0.0	47.0	1.00	70.9«	164.4		
29.000	50.00	5.07	5.310	0.033	0.0	0.0	1.8	1.65	29.2	6.3		
29.001	50.00	5.31	5.120	0.033	0.0	0.0	1.8	0.94	16.7	6.3		
29.002	50.00	5.39	5.000	0.111	0.0	0.0	6.0	1.83	32.4	21.0		
19.015	50.00	17.11	4.460	0.978	0.0	0.0	53.0	0.15	10.5«	185.4		
30.000	50.00	5.05	5.550	0.015	0.0	0.0	0.8	3.04	53.7	2.8		
19.016	50.00	17.37	4.460	0.993	0.0	0.0	53.8	0.98	69.1«	188.3		
31.000	50.00	5.08	5.100	0.028	0.0	0.0	1.5	2.14	37.7	5.3		
19.017	50.00	19.01	4.400	1.021	0.0	0.0	55.3	0.15	10.5«	193.6		
32.000	50.00	5.36	5.280	0.032	0.0	0.0	1.7	0.89	15.6	6.1		
32.001	50.00	5.76	5.130	0.043	0.0	0.0	2.3	0.88	15.5	8.2		
©1982-2018 Innovyze												

RSK LDE										Page 12																																																																																																																																																																																																																																																																																																																																			
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT					Drove Lane, Yapton Surface Water Network Calculations - FEH Data																																																																																																																																																																																																																																																																																																																																								
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...					Designed by AMuthusami Checked by																																																																																																																																																																																																																																																																																																																																								
XP Solutions					Network 2018.1.1																																																																																																																																																																																																																																																																																																																																								
<u>Network Design Table for Surface Network 1</u> <table><tr><th>PN</th><th>Length (m)</th><th>Fall (m)</th><th>Slope (1:X)</th><th>I.Area (ha)</th><th>T.E. (mins)</th><th>Base Flow (l/s)</th><th>k (mm)</th><th>HYD SECT</th><th>DIA (mm)</th><th>Section Type</th><th>Auto Design</th></tr><tr><td>32.002</td><td>6.741</td><td>0.060</td><td>112.4</td><td>0.000</td><td>0.00</td><td>0.0</td><td>0.600</td><td>o</td><td>150</td><td>Pipe/Conduit</td><td></td></tr><tr><td>33.000</td><td>20.846</td><td>0.378</td><td>55.1</td><td>0.024</td><td>5.00</td><td>0.0</td><td>0.600</td><td>o</td><td>150</td><td>Pipe/Conduit</td><td></td></tr><tr><td>32.003</td><td>7.942</td><td>0.260</td><td>30.5</td><td>0.028</td><td>0.00</td><td>0.0</td><td>0.600</td><td>o</td><td>150</td><td>Pipe/Conduit</td><td></td></tr><tr><td>19.018</td><td>11.784</td><td>0.250</td><td>47.1</td><td>0.000</td><td>0.00</td><td>0.0</td><td>0.600</td><td>o</td><td>300</td><td>Pipe/Conduit</td><td></td></tr><tr><td>34.000</td><td>56.564</td><td>0.470</td><td>120.3</td><td>0.125</td><td>5.00</td><td>0.0</td><td>0.600</td><td>o</td><td>150</td><td>Pipe/Conduit</td><td></td></tr><tr><td>35.000</td><td>4.645</td><td>0.450</td><td>10.3</td><td>0.048</td><td>5.00</td><td>0.0</td><td>0.600</td><td>o</td><td>150</td><td>Pipe/Conduit</td><td></td></tr><tr><td>34.001</td><td>18.478</td><td>0.220</td><td>84.0</td><td>0.017</td><td>0.00</td><td>0.0</td><td>0.600</td><td>o</td><td>300</td><td>Pipe/Conduit</td><td></td></tr><tr><td>34.002</td><td>12.434</td><td>0.070</td><td>177.6</td><td>0.020</td><td>0.00</td><td>0.0</td><td>0.600</td><td>o</td><td>300</td><td>Pipe/Conduit</td><td></td></tr><tr><td>34.003</td><td>14.555</td><td>0.090</td><td>161.7</td><td>0.025</td><td>0.00</td><td>0.0</td><td>0.600</td><td>o</td><td>300</td><td>Pipe/Conduit</td><td></td></tr><tr><td>34.004</td><td>22.413</td><td>0.120</td><td>186.8</td><td>0.069</td><td>0.00</td><td>0.0</td><td>0.600</td><td>o</td><td>300</td><td>Pipe/Conduit</td><td></td></tr><tr><td>36.000</td><td>20.257</td><td>0.270</td><td>75.0</td><td>0.046</td><td>5.00</td><td>0.0</td><td>0.600</td><td>o</td><td>150</td><td>Pipe/Conduit</td><td></td></tr><tr><td>19.019</td><td>4.632</td><td>0.030</td><td>154.4</td><td>0.000</td><td>0.00</td><td>0.0</td><td>0.600</td><td>o</td><td>300</td><td>Pipe/Conduit</td><td></td></tr><tr><td>37.000</td><td>9.059</td><td>0.305</td><td>29.7</td><td>0.023</td><td>5.00</td><td>0.0</td><td>0.600</td><td>o</td><td>150</td><td>Pipe/Conduit</td><td></td></tr></table> <u>Network Results Table</u> <table><tr><th>PN</th><th>Rain (mm/hr)</th><th>T.C. (mins)</th><th>US/IL (m)</th><th>Σ I.Area (ha)</th><th>Σ Base Flow (l/s)</th><th>Foul (l/s)</th><th>Add Flow (l/s)</th><th>Vel (m/s)</th><th>Cap (l/s)</th><th>Flow (l/s)</th></tr><tr><td>32.002</td><td>50.00</td><td>5.88</td><td>4.970</td><td>0.043</td><td>0.0</td><td>0.0</td><td>2.3</td><td>0.95</td><td>16.7</td><td>8.2</td></tr><tr><td>33.000</td><td>50.00</td><td>5.26</td><td>5.288</td><td>0.024</td><td>0.0</td><td>0.0</td><td>1.3</td><td>1.36</td><td>24.0</td><td>4.5</td></tr><tr><td>32.003</td><td>50.00</td><td>5.95</td><td>4.910</td><td>0.095</td><td>0.0</td><td>0.0</td><td>5.1</td><td>1.83</td><td>32.3</td><td>18.0</td></tr><tr><td>19.018</td><td>50.00</td><td>19.10</td><td>4.400</td><td>1.116</td><td>0.0</td><td>0.0</td><td>60.4</td><td>2.30</td><td>162.3«</td><td>211.6</td></tr><tr><td>34.000</td><td>50.00</td><td>6.03</td><td>5.270</td><td>0.125</td><td>0.0</td><td>0.0</td><td>6.8</td><td>0.91</td><td>16.2«</td><td>23.7</td></tr><tr><td>35.000</td><td>50.00</td><td>5.02</td><td>5.100</td><td>0.048</td><td>0.0</td><td>0.0</td><td>2.6</td><td>3.15</td><td>55.7</td><td>9.1</td></tr><tr><td>34.001</td><td>50.00</td><td>6.21</td><td>4.650</td><td>0.190</td><td>0.0</td><td>0.0</td><td>10.3</td><td>1.72</td><td>121.3</td><td>36.0</td></tr><tr><td>34.002</td><td>50.00</td><td>6.39</td><td>4.430</td><td>0.210</td><td>0.0</td><td>0.0</td><td>11.4</td><td>1.18</td><td>83.2</td><td>39.8</td></tr><tr><td>34.003</td><td>50.00</td><td>6.58</td><td>4.360</td><td>0.235</td><td>0.0</td><td>0.0</td><td>12.7</td><td>1.23</td><td>87.2</td><td>44.6</td></tr><tr><td>34.004</td><td>50.00</td><td>6.91</td><td>4.270</td><td>0.304</td><td>0.0</td><td>0.0</td><td>16.5</td><td>1.15</td><td>81.1</td><td>57.6</td></tr><tr><td>36.000</td><td>50.00</td><td>5.29</td><td>4.570</td><td>0.046</td><td>0.0</td><td>0.0</td><td>2.5</td><td>1.16</td><td>20.5</td><td>8.7</td></tr><tr><td>19.019</td><td>50.00</td><td>19.16</td><td>4.150</td><td>1.466</td><td>0.0</td><td>0.0</td><td>79.4</td><td>1.26</td><td>89.3«</td><td>277.9</td></tr><tr><td>37.000</td><td>50.00</td><td>5.08</td><td>4.575</td><td>0.023</td><td>0.0</td><td>0.0</td><td>1.2</td><td>1.85</td><td>32.8</td><td>4.4</td></tr></table> ©1982-2018 Innovyze												PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design	32.002	6.741	0.060	112.4	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit		33.000	20.846	0.378	55.1	0.024	5.00	0.0	0.600	o	150	Pipe/Conduit		32.003	7.942	0.260	30.5	0.028	0.00	0.0	0.600	o	150	Pipe/Conduit		19.018	11.784	0.250	47.1	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		34.000	56.564	0.470	120.3	0.125	5.00	0.0	0.600	o	150	Pipe/Conduit		35.000	4.645	0.450	10.3	0.048	5.00	0.0	0.600	o	150	Pipe/Conduit		34.001	18.478	0.220	84.0	0.017	0.00	0.0	0.600	o	300	Pipe/Conduit		34.002	12.434	0.070	177.6	0.020	0.00	0.0	0.600	o	300	Pipe/Conduit		34.003	14.555	0.090	161.7	0.025	0.00	0.0	0.600	o	300	Pipe/Conduit		34.004	22.413	0.120	186.8	0.069	0.00	0.0	0.600	o	300	Pipe/Conduit		36.000	20.257	0.270	75.0	0.046	5.00	0.0	0.600	o	150	Pipe/Conduit		19.019	4.632	0.030	154.4	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		37.000	9.059	0.305	29.7	0.023	5.00	0.0	0.600	o	150	Pipe/Conduit		PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)	32.002	50.00	5.88	4.970	0.043	0.0	0.0	2.3	0.95	16.7	8.2	33.000	50.00	5.26	5.288	0.024	0.0	0.0	1.3	1.36	24.0	4.5	32.003	50.00	5.95	4.910	0.095	0.0	0.0	5.1	1.83	32.3	18.0	19.018	50.00	19.10	4.400	1.116	0.0	0.0	60.4	2.30	162.3«	211.6	34.000	50.00	6.03	5.270	0.125	0.0	0.0	6.8	0.91	16.2«	23.7	35.000	50.00	5.02	5.100	0.048	0.0	0.0	2.6	3.15	55.7	9.1	34.001	50.00	6.21	4.650	0.190	0.0	0.0	10.3	1.72	121.3	36.0	34.002	50.00	6.39	4.430	0.210	0.0	0.0	11.4	1.18	83.2	39.8	34.003	50.00	6.58	4.360	0.235	0.0	0.0	12.7	1.23	87.2	44.6	34.004	50.00	6.91	4.270	0.304	0.0	0.0	16.5	1.15	81.1	57.6	36.000	50.00	5.29	4.570	0.046	0.0	0.0	2.5	1.16	20.5	8.7	19.019	50.00	19.16	4.150	1.466	0.0	0.0	79.4	1.26	89.3«	277.9	37.000	50.00	5.08	4.575	0.023	0.0	0.0	1.2	1.85	32.8	4.4
PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design																																																																																																																																																																																																																																																																																																																																		
32.002	6.741	0.060	112.4	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit																																																																																																																																																																																																																																																																																																																																			
33.000	20.846	0.378	55.1	0.024	5.00	0.0	0.600	o	150	Pipe/Conduit																																																																																																																																																																																																																																																																																																																																			
32.003	7.942	0.260	30.5	0.028	0.00	0.0	0.600	o	150	Pipe/Conduit																																																																																																																																																																																																																																																																																																																																			
19.018	11.784	0.250	47.1	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit																																																																																																																																																																																																																																																																																																																																			
34.000	56.564	0.470	120.3	0.125	5.00	0.0	0.600	o	150	Pipe/Conduit																																																																																																																																																																																																																																																																																																																																			
35.000	4.645	0.450	10.3	0.048	5.00	0.0	0.600	o	150	Pipe/Conduit																																																																																																																																																																																																																																																																																																																																			
34.001	18.478	0.220	84.0	0.017	0.00	0.0	0.600	o	300	Pipe/Conduit																																																																																																																																																																																																																																																																																																																																			
34.002	12.434	0.070	177.6	0.020	0.00	0.0	0.600	o	300	Pipe/Conduit																																																																																																																																																																																																																																																																																																																																			
34.003	14.555	0.090	161.7	0.025	0.00	0.0	0.600	o	300	Pipe/Conduit																																																																																																																																																																																																																																																																																																																																			
34.004	22.413	0.120	186.8	0.069	0.00	0.0	0.600	o	300	Pipe/Conduit																																																																																																																																																																																																																																																																																																																																			
36.000	20.257	0.270	75.0	0.046	5.00	0.0	0.600	o	150	Pipe/Conduit																																																																																																																																																																																																																																																																																																																																			
19.019	4.632	0.030	154.4	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit																																																																																																																																																																																																																																																																																																																																			
37.000	9.059	0.305	29.7	0.023	5.00	0.0	0.600	o	150	Pipe/Conduit																																																																																																																																																																																																																																																																																																																																			
PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)																																																																																																																																																																																																																																																																																																																																			
32.002	50.00	5.88	4.970	0.043	0.0	0.0	2.3	0.95	16.7	8.2																																																																																																																																																																																																																																																																																																																																			
33.000	50.00	5.26	5.288	0.024	0.0	0.0	1.3	1.36	24.0	4.5																																																																																																																																																																																																																																																																																																																																			
32.003	50.00	5.95	4.910	0.095	0.0	0.0	5.1	1.83	32.3	18.0																																																																																																																																																																																																																																																																																																																																			
19.018	50.00	19.10	4.400	1.116	0.0	0.0	60.4	2.30	162.3«	211.6																																																																																																																																																																																																																																																																																																																																			
34.000	50.00	6.03	5.270	0.125	0.0	0.0	6.8	0.91	16.2«	23.7																																																																																																																																																																																																																																																																																																																																			
35.000	50.00	5.02	5.100	0.048	0.0	0.0	2.6	3.15	55.7	9.1																																																																																																																																																																																																																																																																																																																																			
34.001	50.00	6.21	4.650	0.190	0.0	0.0	10.3	1.72	121.3	36.0																																																																																																																																																																																																																																																																																																																																			
34.002	50.00	6.39	4.430	0.210	0.0	0.0	11.4	1.18	83.2	39.8																																																																																																																																																																																																																																																																																																																																			
34.003	50.00	6.58	4.360	0.235	0.0	0.0	12.7	1.23	87.2	44.6																																																																																																																																																																																																																																																																																																																																			
34.004	50.00	6.91	4.270	0.304	0.0	0.0	16.5	1.15	81.1	57.6																																																																																																																																																																																																																																																																																																																																			
36.000	50.00	5.29	4.570	0.046	0.0	0.0	2.5	1.16	20.5	8.7																																																																																																																																																																																																																																																																																																																																			
19.019	50.00	19.16	4.150	1.466	0.0	0.0	79.4	1.26	89.3«	277.9																																																																																																																																																																																																																																																																																																																																			
37.000	50.00	5.08	4.575	0.023	0.0	0.0	1.2	1.85	32.8	4.4																																																																																																																																																																																																																																																																																																																																			

RSK LDE										Page 13		
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT						Drove Lane, Yapton Surface Water Network Calculations - FEH Data						
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...						Designed by AMuthusami Checked by						
XP Solutions						Network 2018.1.1						
<u>Network Design Table for Surface Network 1</u>												
PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design	
38.000	6.094	0.180	33.9	0.017	5.00	0.0	0.600	o	150	Pipe/Conduit		
19.020	11.644	0.000	0.0	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		
19.021	32.158	0.155	207.5	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		
19.022	6.651	0.080	83.1	0.036	0.00	0.0	0.600	o	300	Pipe/Conduit		
39.000	5.810	0.300	19.4	0.032	5.00	0.0	0.600	o	150	Pipe/Conduit		
39.001	14.385	0.150	95.9	0.019	0.00	0.0	0.600	o	150	Pipe/Conduit		
39.002	7.928	0.085	93.3	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit		
40.000	6.955	0.060	115.9	0.035	5.00	0.0	0.600	o	225	Pipe/Conduit		
19.023	4.513	0.016	282.1	0.022	0.00	0.0	0.600	o	300	Pipe/Conduit		
19.024	8.201	0.034	241.2	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		
1.022	17.390	0.000	0.0	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		
1.023	48.402	0.000	0.0	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		
1.024	38.318	0.115	333.2	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		
41.000	11.954	0.120	99.6	0.023	5.00	0.0	0.600	o	150	Pipe/Conduit		
<u>Network Results Table</u>												
PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)		
38.000	50.00	5.06	4.450	0.017	0.0	0.0	0.9	1.74	30.7	3.2		
19.020	50.00	20.46	4.120	1.506	0.0	0.0	81.6	0.15	10.5«	285.5		
19.021	50.00	20.96	4.120	1.506	0.0	0.0	81.6	1.09	76.9«	285.5		
19.022	50.00	21.02	3.965	1.542	0.0	0.0	83.5	1.73	122.0«	292.3		
39.000	50.00	5.04	4.570	0.032	0.0	0.0	1.7	2.30	40.6	6.1		
39.001	50.00	5.28	4.270	0.051	0.0	0.0	2.8	1.03	18.1	9.7		
39.002	50.00	5.40	4.120	0.051	0.0	0.0	2.8	1.04	18.4	9.7		
40.000	50.00	5.10	4.020	0.035	0.0	0.0	1.9	1.21	48.2	6.6		
19.023	50.00	21.10	3.885	1.650	0.0	0.0	89.4	0.93	65.8«	312.8		
19.024	50.00	21.24	3.869	1.650	0.0	0.0	89.4	1.01	71.2«	312.8		
1.022	50.00	30.00	3.835	3.046	0.0	0.0	165.0	0.15	10.5«	577.5		
1.023	50.00	30.00	3.835	3.046	0.0	0.0	165.0	0.15	10.5«	577.5		
1.024	50.00	30.00	3.835	3.046	0.0	0.0	165.0	0.86	60.5«	577.5		
41.000	50.00	5.20	4.280	0.023	0.0	0.0	1.2	1.01	17.8	4.4		
©1982-2018 Innovyze												

RSK LDE										Page 14	
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT					Drove Lane, Yapton Surface Water Network Calculations - FEH Data						
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...					Designed by AMuthusami Checked by						
XP Solutions					Network 2018.1.1						
<u>Network Design Table for Surface Network 1</u>											
PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design
42.000	7.349	0.560	13.1	0.019	5.00	0.0	0.600	o	150	Pipe/Conduit	
41.001	22.295	0.172	129.6	0.024	0.00	0.0	0.600	o	150	Pipe/Conduit	
43.000	6.317	0.260	24.3	0.023	5.00	0.0	0.600	o	150	Pipe/Conduit	
43.001	6.785	0.052	130.5	0.018	0.00	0.0	0.600	o	150	Pipe/Conduit	
41.002	11.709	0.058	201.9	0.000	0.00	0.0	0.600	o	225	Pipe/Conduit	
41.003	27.011	0.135	200.1	0.020	0.00	0.0	0.600	o	225	Pipe/Conduit	
44.000	6.461	0.050	129.2	0.051	5.00	0.0	0.600	o	150	Pipe/Conduit	
41.004	6.311	0.000	0.0	0.014	0.00	0.0	0.600	o	225	Pipe/Conduit	
1.025	20.213	0.020	1010.7	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit	
1.026	20.756	0.000	0.0	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit	
45.000	15.268	0.250	61.1	0.043	5.00	0.0	0.600	o	150	Pipe/Conduit	
45.001	17.732	0.136	130.4	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
45.002	13.608	0.105	129.6	0.022	0.00	0.0	0.600	o	150	Pipe/Conduit	
45.003	19.402	0.149	130.2	0.011	0.00	0.0	0.600	o	150	Pipe/Conduit	
45.004	6.955	0.155	44.9	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
<u>Network Results Table</u>											
PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)	
42.000	50.00	5.04	4.720	0.019	0.0	0.0	1.0	2.80	49.4	3.6	
41.001	50.00	5.62	4.160	0.066	0.0	0.0	3.6	0.88	15.6	12.5	
43.000	50.00	5.05	4.300	0.023	0.0	0.0	1.2	2.05	36.3	4.4	
43.001	50.00	5.18	4.040	0.041	0.0	0.0	2.2	0.88	15.5	7.8	
41.002	50.00	5.83	3.913	0.107	0.0	0.0	5.8	0.92	36.4	20.3	
41.003	50.00	6.32	3.855	0.127	0.0	0.0	6.9	0.92	36.6	24.1	
44.000	50.00	5.12	3.845	0.051	0.0	0.0	2.8	0.88	15.6	9.7	
41.004	50.00	7.18	3.720	0.192	0.0	0.0	10.4	0.12	4.9«	36.4	
1.025	50.00	30.00	3.720	3.238	0.0	0.0	175.4	0.49	34.4«	613.9	
1.026	50.00	30.00	3.700	3.238	0.0	0.0	175.4	0.15	10.5«	613.9	
45.000	50.00	5.20	6.150	0.043	0.0	0.0	2.3	1.29	22.8	8.2	
45.001	50.00	5.53	5.900	0.043	0.0	0.0	2.3	0.88	15.5	8.2	
45.002	50.00	5.79	5.764	0.065	0.0	0.0	3.5	0.88	15.6	12.3	
45.003	50.00	6.16	5.659	0.076	0.0	0.0	4.1	0.88	15.5	14.4	
45.004	50.00	6.24	5.510	0.076	0.0	0.0	4.1	1.51	26.6	14.4	
©1982-2018 Innovyze											

RSK LDE										Page 15		
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT					Drove Lane, Yapton Surface Water Network Calculations - FEH Data							
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...					Designed by AMuthusami Checked by							
XP Solutions					Network 2018.1.1							
<u>Network Design Table for Surface Network 1</u>												
PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design	
46.000	12.734	0.098	129.9	0.011	5.00	0.0	0.600	o	150	Pipe/Conduit		
45.005	14.384	0.120	119.9	0.022	0.00	0.0	0.600	o	225	Pipe/Conduit		
45.006	24.977	0.200	124.9	0.039	0.00	0.0	0.600	o	225	Pipe/Conduit		
45.007	8.469	0.080	105.9	0.000	0.00	0.0	0.600	o	225	Pipe/Conduit		
45.008	6.810	0.030	227.0	0.009	0.00	0.0	0.600	o	225	Pipe/Conduit		
45.009	9.471	0.030	315.7	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		
45.010	11.295	0.040	282.4	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		
45.011	11.386	0.030	379.5	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		
47.000	11.315	0.160	70.7	0.023	5.00	0.0	0.600	o	150	Pipe/Conduit		
47.001	3.838	0.400	9.6	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit		
45.012	18.379	0.120	153.2	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		
45.013	18.447	0.130	141.9	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		
48.000	14.874	0.390	38.1	0.036	5.00	0.0	0.600	o	150	Pipe/Conduit		
49.000	7.319	0.690	10.6	0.010	5.00	0.0	0.600	o	150	Pipe/Conduit		
48.001	14.874	0.190	78.3	0.029	0.00	0.0	0.600	o	150	Pipe/Conduit		
<u>Network Results Table</u>												
PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)		
46.000	50.00	5.24	5.453	0.011	0.0	0.0	0.6	0.88	15.6	2.1		
45.005	50.00	6.44	5.280	0.109	0.0	0.0	5.9	1.19	47.4	20.7		
45.006	50.00	6.79	5.160	0.148	0.0	0.0	8.0	1.17	46.5	28.1		
45.007	50.00	6.90	4.960	0.148	0.0	0.0	8.0	1.27	50.5	28.1		
45.008	50.00	7.04	4.880	0.157	0.0	0.0	8.5	0.86	34.3	29.8		
45.009	50.00	7.22	4.850	0.157	0.0	0.0	8.5	0.88	62.2	29.8		
45.010	50.00	7.42	4.820	0.157	0.0	0.0	8.5	0.93	65.8	29.8		
45.011	50.00	7.65	4.780	0.157	0.0	0.0	8.5	0.80	56.6	29.8		
47.000	50.00	5.16	5.560	0.023	0.0	0.0	1.2	1.20	21.2	4.4		
47.001	50.00	5.18	5.400	0.023	0.0	0.0	1.2	3.27	57.8	4.4		
45.012	50.00	7.90	4.750	0.180	0.0	0.0	9.7	1.27	89.6	34.1		
45.013	50.00	8.13	4.630	0.180	0.0	0.0	9.7	1.32	93.2	34.1		
48.000	50.00	5.15	5.400	0.036	0.0	0.0	1.9	1.63	28.9	6.8		
49.000	50.00	5.04	5.700	0.010	0.0	0.0	0.5	3.11	55.0	1.9		
48.001	50.00	5.37	5.010	0.075	0.0	0.0	4.1	1.14	20.1	14.2		
©1982-2018 Innovyze												

RSK LDE										Page 16	
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT					Drove Lane, Yapton Surface Water Network Calculations - FEH Data						
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...					Designed by AMuthusami Checked by						
XP Solutions					Network 2018.1.1						
<u>Network Design Table for Surface Network 1</u>											
PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design
48.002	12.797	0.170	75.3	0.014	0.00	0.0	0.600	o	150	Pipe/Conduit	
48.003	7.578	0.060	126.3	0.027	0.00	0.0	0.600	o	150	Pipe/Conduit	
48.004	4.811	0.090	53.5	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
45.014	23.863	0.050	477.3	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit	
50.000	14.888	0.250	59.6	0.004	5.00	0.0	0.600	o	150	Pipe/Conduit	
50.001	12.946	0.150	86.3	0.019	0.00	0.0	0.600	o	150	Pipe/Conduit	
50.002	8.198	0.300	27.3	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
50.003	6.381	0.050	127.6	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
45.015	22.453	0.370	60.7	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit	
51.000	11.028	0.090	122.5	0.020	5.00	0.0	0.600	o	150	Pipe/Conduit	
52.000	25.533	0.315	81.1	0.056	5.00	0.0	0.600	o	150	Pipe/Conduit	
51.001	8.644	0.050	172.9	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	
51.002	5.990	0.035	171.1	0.000	0.00	0.0	0.600	o	225	Pipe/Conduit	
51.003	20.542	0.120	171.2	0.049	0.00	0.0	0.600	o	225	Pipe/Conduit	
53.000	6.398	0.665	9.6	0.039	5.00	0.0	0.600	o	150	Pipe/Conduit	
<u>Network Results Table</u>											
PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul Flow (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)	
48.002	50.00	5.55	4.820	0.089	0.0	0.0	4.8	1.16	20.5	16.9	
48.003	50.00	5.69	4.650	0.116	0.0	0.0	6.3	0.89	15.8	22.0	
48.004	50.00	5.75	4.590	0.116	0.0	0.0	6.3	1.38	24.4	22.0	
45.014	50.00	8.69	4.500	0.296	0.0	0.0	16.0	0.71	50.4	56.1	
50.000	50.00	5.19	5.200	0.004	0.0	0.0	0.2	1.31	23.1	0.8	
50.001	50.00	5.39	4.950	0.023	0.0	0.0	1.2	1.08	19.1	4.4	
50.002	50.00	5.46	4.800	0.023	0.0	0.0	1.2	1.93	34.2	4.4	
50.003	50.00	5.58	4.500	0.023	0.0	0.0	1.2	0.89	15.7	4.4	
45.015	50.00	8.87	4.450	0.319	0.0	0.0	17.3	2.02	142.9	60.5	
51.000	50.00	5.20	5.650	0.020	0.0	0.0	1.1	0.91	16.0	3.8	
52.000	50.00	5.38	5.875	0.056	0.0	0.0	3.0	1.12	19.7	10.6	
51.001	50.00	5.57	5.560	0.076	0.0	0.0	4.1	0.76	13.5	14.4	
51.002	50.00	5.67	5.435	0.076	0.0	0.0	4.1	1.00	39.6	14.4	
51.003	50.00	6.01	5.400	0.125	0.0	0.0	6.8	1.00	39.6	23.7	
53.000	50.00	5.03	6.020	0.039	0.0	0.0	2.1	3.27	57.7	7.4	
©1982-2018 Innovyze											

RSK LDE										Page 17		
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT						Drove Lane, Yapton Surface Water Network Calculations - FEH Data						
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...						Designed by AMuthusami Checked by						
XP Solutions						Network 2018.1.1						
<u>Network Design Table for Surface Network 1</u>												
PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section	Type	Auto Design
51.004	25.121	0.135	186.1	0.039	0.00	0.0	0.600	o	225	Pipe/Conduit		
54.000	7.911	0.110	71.9	0.015	5.00	0.0	0.600	o	150	Pipe/Conduit		
51.005	14.419	0.120	120.2	0.034	0.00	0.0	0.600	o	300	Pipe/Conduit		
55.000	5.913	0.130	45.5	0.021	5.00	0.0	0.600	o	150	Pipe/Conduit		
51.006	35.195	0.440	80.0	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		
56.000	4.517	0.040	112.9	0.023	5.00	0.0	0.600	o	150	Pipe/Conduit		
51.007	23.594	0.250	94.4	0.059	0.00	0.0	0.600	o	300	Pipe/Conduit		
51.008	9.979	0.060	166.3	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		
51.009	5.909	0.100	59.1	0.034	0.00	0.0	0.600	o	300	Pipe/Conduit		
51.010	4.450	0.020	222.5	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		
45.016	22.062	0.000	0.0	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		
57.000	6.067	0.040	151.7	0.016	5.00	0.0	0.600	o	300	Pipe/Conduit		
57.001	4.644	0.020	232.2	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		
<u>Network Results Table</u>												
PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)		
51.004	50.00	6.45	5.280	0.203	0.0	0.0	11.0	0.96	38.0	38.5		
54.000	50.00	5.11	5.330	0.015	0.0	0.0	0.8	1.19	21.0	2.8		
51.005	50.00	6.62	5.070	0.252	0.0	0.0	13.6	1.43	101.3	47.8		
55.000	50.00	5.07	5.230	0.021	0.0	0.0	1.1	1.50	26.4	4.0		
51.006	50.00	6.95	4.950	0.273	0.0	0.0	14.8	1.76	124.4	51.8		
56.000	50.00	5.08	4.700	0.023	0.0	0.0	1.2	0.94	16.7	4.4		
51.007	50.00	7.20	4.510	0.355	0.0	0.0	19.2	1.62	114.4	67.3		
51.008	50.00	7.33	4.260	0.355	0.0	0.0	19.2	1.22	86.0	67.3		
51.009	50.00	7.38	4.200	0.389	0.0	0.0	21.1	2.05	144.8	73.7		
51.010	50.00	7.45	4.100	0.389	0.0	0.0	21.1	1.05	74.2	73.7		
45.016	50.00	11.34	4.080	0.708	0.0	0.0	38.3	0.15	10.5	134.2		
57.000	50.00	5.08	4.140	0.016	0.0	0.0	0.9	1.27	90.1	3.0		
57.001	50.00	5.15	4.100	0.016	0.0	0.0	0.9	1.03	72.6	3.0		
©1982-2018 Innovyze												

RSK LDE										Page 18		
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT						Drove Lane, Yapton Surface Water Network Calculations - FEH Data						
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...						Designed by AMuthusami Checked by						
XP Solutions						Network 2018.1.1						
<u>Network Design Table for Surface Network 1</u>												
PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section	Type	Auto Design
45.017	25.461	0.020	1273.0	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		
58.000	19.027	0.530	35.9	0.004	5.00	0.0	0.600	o	150	Pipe/Conduit		
58.001	10.816	0.100	108.2	0.029	0.00	0.0	0.600	o	150	Pipe/Conduit		
58.002	9.026	0.130	69.4	0.040	0.00	0.0	0.600	o	150	Pipe/Conduit		
58.003	2.619	0.040	65.5	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit		
45.018	5.411	0.020	270.6	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		
45.019	22.710	0.090	252.3	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		
45.020	10.353	0.050	207.1	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		
45.021	12.519	0.150	83.5	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		
59.000	22.046	0.190	116.0	0.030	5.00	0.0	0.600	o	150	Pipe/Conduit		
59.001	9.725	0.090	108.1	0.038	0.00	0.0	0.600	o	150	Pipe/Conduit		
60.000	6.462	0.490	13.2	0.038	5.00	0.0	0.600	o	150	Pipe/Conduit		
59.002	19.638	0.280	70.1	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit		
61.000	7.982	0.715	11.2	0.009	5.00	0.0	0.600	o	150	Pipe/Conduit		
61.001	10.368	0.300	34.6	0.024	0.00	0.0	0.600	o	150	Pipe/Conduit		
<u>Network Results Table</u>												
PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)		
45.017	50.00	12.32	4.080	0.724		0.0	0.0	39.2	0.43	30.6«	137.3	
58.000	50.00	5.19	5.180	0.004		0.0	0.0	0.2	1.69	29.8	0.8	
58.001	50.00	5.37	4.650	0.033		0.0	0.0	1.8	0.97	17.1	6.3	
58.002	50.00	5.50	4.550	0.073		0.0	0.0	4.0	1.21	21.4	13.8	
58.003	50.00	5.53	4.350	0.073		0.0	0.0	4.0	1.24	22.0	13.8	
45.018	50.00	12.42	4.060	0.797		0.0	0.0	43.2	0.95	67.2«	151.1	
45.019	50.00	12.80	4.040	0.797		0.0	0.0	43.2	0.99	69.6«	151.1	
45.020	50.00	12.96	3.950	0.797		0.0	0.0	43.2	1.09	77.0«	151.1	
45.021	50.00	13.08	3.900	0.797		0.0	0.0	43.2	1.72	121.7«	151.1	
59.000	50.00	5.39	4.860	0.030		0.0	0.0	1.6	0.93	16.5	5.7	
59.001	50.00	5.56	4.670	0.068		0.0	0.0	3.7	0.97	17.1	12.9	
60.000	50.00	5.04	5.070	0.038		0.0	0.0	2.1	2.79	49.3	7.2	
59.002	50.00	5.83	4.580	0.106		0.0	0.0	5.7	1.20	21.2	20.1	
61.000	50.00	5.04	5.315	0.009		0.0	0.0	0.5	3.03	53.6	1.7	
61.001	50.00	5.14	4.600	0.033		0.0	0.0	1.8	1.72	30.4	6.3	
©1982-2018 Innovyze												

RSK LDE										Page 19																																																																																																																																																																																																																																																																																																												
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT					Drove Lane, Yapton Surface Water Network Calculations - FEH Data																																																																																																																																																																																																																																																																																																																	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...					Designed by AMuthusami Checked by																																																																																																																																																																																																																																																																																																																	
XP Solutions					Network 2018.1.1																																																																																																																																																																																																																																																																																																																	
<u>Network Design Table for Surface Network 1</u> <table><tr><th>PN</th><th>Length (m)</th><th>Fall (m)</th><th>Slope (1:X)</th><th>I.Area (ha)</th><th>T.E. (mins)</th><th>Base Flow (l/s)</th><th>k (mm)</th><th>HYD SECT</th><th>DIA (mm)</th><th>Section Type</th><th>Auto Design</th></tr><tr><td>59.003</td><td>12.789</td><td>0.080</td><td>159.9</td><td>0.000</td><td>0.00</td><td>0.0</td><td>0.600</td><td>o</td><td>300</td><td>Pipe/Conduit</td><td></td></tr><tr><td>59.004</td><td>47.729</td><td>0.250</td><td>190.9</td><td>0.080</td><td>0.00</td><td>0.0</td><td>0.600</td><td>o</td><td>300</td><td>Pipe/Conduit</td><td></td></tr><tr><td>62.000</td><td>4.985</td><td>0.430</td><td>11.6</td><td>0.026</td><td>5.00</td><td>0.0</td><td>0.600</td><td>o</td><td>150</td><td>Pipe/Conduit</td><td></td></tr><tr><td>59.005</td><td>12.346</td><td>0.050</td><td>246.9</td><td>0.000</td><td>0.00</td><td>0.0</td><td>0.600</td><td>o</td><td>300</td><td>Pipe/Conduit</td><td></td></tr><tr><td>59.006</td><td>5.698</td><td>0.020</td><td>284.9</td><td>0.027</td><td>0.00</td><td>0.0</td><td>0.600</td><td>o</td><td>300</td><td>Pipe/Conduit</td><td></td></tr><tr><td>59.007</td><td>3.876</td><td>0.000</td><td>0.0</td><td>0.000</td><td>0.00</td><td>0.0</td><td>0.600</td><td>o</td><td>300</td><td>Pipe/Conduit</td><td></td></tr><tr><td>45.022</td><td>32.579</td><td>0.000</td><td>0.0</td><td>0.000</td><td>0.00</td><td>0.0</td><td>0.600</td><td>o</td><td>300</td><td>Pipe/Conduit</td><td></td></tr><tr><td>63.000</td><td>11.089</td><td>0.095</td><td>116.7</td><td>0.024</td><td>5.00</td><td>0.0</td><td>0.600</td><td>o</td><td>150</td><td>Pipe/Conduit</td><td></td></tr><tr><td>63.001</td><td>22.582</td><td>0.350</td><td>64.5</td><td>0.000</td><td>0.00</td><td>0.0</td><td>0.600</td><td>o</td><td>150</td><td>Pipe/Conduit</td><td></td></tr><tr><td>45.023</td><td>9.002</td><td>0.050</td><td>180.0</td><td>0.000</td><td>0.00</td><td>0.0</td><td>0.600</td><td>o</td><td>300</td><td>Pipe/Conduit</td><td></td></tr><tr><td>1.027</td><td>9.559</td><td>0.050</td><td>191.2</td><td>0.000</td><td>0.00</td><td>0.0</td><td>0.600</td><td>o</td><td>300</td><td>Pipe/Conduit</td><td></td></tr><tr><td>1.028</td><td>4.451</td><td>0.050</td><td>89.0</td><td>0.000</td><td>0.00</td><td>0.0</td><td>0.600</td><td>o</td><td>300</td><td>Pipe/Conduit</td><td></td></tr></table> <u>Network Results Table</u> <table><tr><th>PN</th><th>Rain (mm/hr)</th><th>T.C. (mins)</th><th>US/IL (m)</th><th>Σ I.Area (ha)</th><th>Σ Base Flow (l/s)</th><th>Foul (l/s)</th><th>Add Flow (l/s)</th><th>Vel (m/s)</th><th>Cap (l/s)</th><th>Flow (l/s)</th></tr><tr><td>59.003</td><td>50.00</td><td>6.01</td><td>4.150</td><td>0.139</td><td>0.0</td><td>0.0</td><td>7.5</td><td>1.24</td><td>87.7</td><td>26.4</td></tr><tr><td>59.004</td><td>50.00</td><td>6.71</td><td>4.070</td><td>0.219</td><td>0.0</td><td>0.0</td><td>11.9</td><td>1.13</td><td>80.2</td><td>41.5</td></tr><tr><td>62.000</td><td>50.00</td><td>5.03</td><td>4.400</td><td>0.026</td><td>0.0</td><td>0.0</td><td>1.4</td><td>2.98</td><td>52.6</td><td>4.9</td></tr><tr><td>59.005</td><td>50.00</td><td>6.91</td><td>3.820</td><td>0.245</td><td>0.0</td><td>0.0</td><td>13.3</td><td>1.00</td><td>70.4</td><td>46.4</td></tr><tr><td>59.006</td><td>50.00</td><td>7.02</td><td>3.770</td><td>0.272</td><td>0.0</td><td>0.0</td><td>14.7</td><td>0.93</td><td>65.5</td><td>51.6</td></tr><tr><td>59.007</td><td>50.00</td><td>7.45</td><td>3.750</td><td>0.272</td><td>0.0</td><td>0.0</td><td>14.7</td><td>0.15</td><td>10.5«</td><td>51.6</td></tr><tr><td>45.022</td><td>50.00</td><td>16.73</td><td>3.750</td><td>1.069</td><td>0.0</td><td>0.0</td><td>57.9</td><td>0.15</td><td>10.5«</td><td>202.7</td></tr><tr><td>63.000</td><td>50.00</td><td>5.20</td><td>4.345</td><td>0.024</td><td>0.0</td><td>0.0</td><td>1.3</td><td>0.93</td><td>16.4</td><td>4.5</td></tr><tr><td>63.001</td><td>50.00</td><td>5.50</td><td>4.250</td><td>0.024</td><td>0.0</td><td>0.0</td><td>1.3</td><td>1.25</td><td>22.2</td><td>4.5</td></tr><tr><td>45.023</td><td>50.00</td><td>16.86</td><td>3.750</td><td>1.093</td><td>0.0</td><td>0.0</td><td>59.2</td><td>1.17</td><td>82.6«</td><td>207.2</td></tr><tr><td>1.027</td><td>50.00</td><td>30.00</td><td>3.700</td><td>4.331</td><td>0.0</td><td>0.0</td><td>234.6</td><td>1.13</td><td>80.1«</td><td>821.1</td></tr><tr><td>1.028</td><td>50.00</td><td>30.00</td><td>3.650</td><td>4.331</td><td>0.0</td><td>0.0</td><td>234.6</td><td>1.67</td><td>117.8«</td><td>821.1</td></tr></table>												PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design	59.003	12.789	0.080	159.9	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		59.004	47.729	0.250	190.9	0.080	0.00	0.0	0.600	o	300	Pipe/Conduit		62.000	4.985	0.430	11.6	0.026	5.00	0.0	0.600	o	150	Pipe/Conduit		59.005	12.346	0.050	246.9	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		59.006	5.698	0.020	284.9	0.027	0.00	0.0	0.600	o	300	Pipe/Conduit		59.007	3.876	0.000	0.0	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		45.022	32.579	0.000	0.0	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		63.000	11.089	0.095	116.7	0.024	5.00	0.0	0.600	o	150	Pipe/Conduit		63.001	22.582	0.350	64.5	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit		45.023	9.002	0.050	180.0	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		1.027	9.559	0.050	191.2	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		1.028	4.451	0.050	89.0	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit		PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)	59.003	50.00	6.01	4.150	0.139	0.0	0.0	7.5	1.24	87.7	26.4	59.004	50.00	6.71	4.070	0.219	0.0	0.0	11.9	1.13	80.2	41.5	62.000	50.00	5.03	4.400	0.026	0.0	0.0	1.4	2.98	52.6	4.9	59.005	50.00	6.91	3.820	0.245	0.0	0.0	13.3	1.00	70.4	46.4	59.006	50.00	7.02	3.770	0.272	0.0	0.0	14.7	0.93	65.5	51.6	59.007	50.00	7.45	3.750	0.272	0.0	0.0	14.7	0.15	10.5«	51.6	45.022	50.00	16.73	3.750	1.069	0.0	0.0	57.9	0.15	10.5«	202.7	63.000	50.00	5.20	4.345	0.024	0.0	0.0	1.3	0.93	16.4	4.5	63.001	50.00	5.50	4.250	0.024	0.0	0.0	1.3	1.25	22.2	4.5	45.023	50.00	16.86	3.750	1.093	0.0	0.0	59.2	1.17	82.6«	207.2	1.027	50.00	30.00	3.700	4.331	0.0	0.0	234.6	1.13	80.1«	821.1	1.028	50.00	30.00	3.650	4.331	0.0	0.0	234.6	1.67	117.8«	821.1
PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design																																																																																																																																																																																																																																																																																																											
59.003	12.789	0.080	159.9	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit																																																																																																																																																																																																																																																																																																												
59.004	47.729	0.250	190.9	0.080	0.00	0.0	0.600	o	300	Pipe/Conduit																																																																																																																																																																																																																																																																																																												
62.000	4.985	0.430	11.6	0.026	5.00	0.0	0.600	o	150	Pipe/Conduit																																																																																																																																																																																																																																																																																																												
59.005	12.346	0.050	246.9	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit																																																																																																																																																																																																																																																																																																												
59.006	5.698	0.020	284.9	0.027	0.00	0.0	0.600	o	300	Pipe/Conduit																																																																																																																																																																																																																																																																																																												
59.007	3.876	0.000	0.0	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit																																																																																																																																																																																																																																																																																																												
45.022	32.579	0.000	0.0	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit																																																																																																																																																																																																																																																																																																												
63.000	11.089	0.095	116.7	0.024	5.00	0.0	0.600	o	150	Pipe/Conduit																																																																																																																																																																																																																																																																																																												
63.001	22.582	0.350	64.5	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit																																																																																																																																																																																																																																																																																																												
45.023	9.002	0.050	180.0	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit																																																																																																																																																																																																																																																																																																												
1.027	9.559	0.050	191.2	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit																																																																																																																																																																																																																																																																																																												
1.028	4.451	0.050	89.0	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit																																																																																																																																																																																																																																																																																																												
PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)																																																																																																																																																																																																																																																																																																												
59.003	50.00	6.01	4.150	0.139	0.0	0.0	7.5	1.24	87.7	26.4																																																																																																																																																																																																																																																																																																												
59.004	50.00	6.71	4.070	0.219	0.0	0.0	11.9	1.13	80.2	41.5																																																																																																																																																																																																																																																																																																												
62.000	50.00	5.03	4.400	0.026	0.0	0.0	1.4	2.98	52.6	4.9																																																																																																																																																																																																																																																																																																												
59.005	50.00	6.91	3.820	0.245	0.0	0.0	13.3	1.00	70.4	46.4																																																																																																																																																																																																																																																																																																												
59.006	50.00	7.02	3.770	0.272	0.0	0.0	14.7	0.93	65.5	51.6																																																																																																																																																																																																																																																																																																												
59.007	50.00	7.45	3.750	0.272	0.0	0.0	14.7	0.15	10.5«	51.6																																																																																																																																																																																																																																																																																																												
45.022	50.00	16.73	3.750	1.069	0.0	0.0	57.9	0.15	10.5«	202.7																																																																																																																																																																																																																																																																																																												
63.000	50.00	5.20	4.345	0.024	0.0	0.0	1.3	0.93	16.4	4.5																																																																																																																																																																																																																																																																																																												
63.001	50.00	5.50	4.250	0.024	0.0	0.0	1.3	1.25	22.2	4.5																																																																																																																																																																																																																																																																																																												
45.023	50.00	16.86	3.750	1.093	0.0	0.0	59.2	1.17	82.6«	207.2																																																																																																																																																																																																																																																																																																												
1.027	50.00	30.00	3.700	4.331	0.0	0.0	234.6	1.13	80.1«	821.1																																																																																																																																																																																																																																																																																																												
1.028	50.00	30.00	3.650	4.331	0.0	0.0	234.6	1.67	117.8«	821.1																																																																																																																																																																																																																																																																																																												
©1982-2018 Innovyze																																																																																																																																																																																																																																																																																																																						

RSK LDE		Page 20
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions	Network 2018.1.1	

Manhole Schedules for Surface Network 1

MH Name	MH CL (m)	MH Depth (m)	MH Connection	MH Diam., L*W (mm)	PN	Pipe Out Invert Level (m)	Pipe Out Diameter (mm)	PN	Pipes In Invert Level (m)	Pipes In Diameter (mm)	Backdrop (mm)
S1	6.900	1.300	Open Manhole	1200	1.000	5.600	150				
S2	6.900	1.300	Open Manhole	1200	1.001	6.200	150	1.000	5.600	150	
S3	6.900	0.750	Open Manhole	1200	1.002	6.150	150	1.001	6.150	150	
S4	7.180	1.270	Open Manhole	1200	1.003	5.910	150	1.002	5.910	150	
S5	6.900	1.650	Open Manhole	1200	1.004	5.250	300	1.003	5.840	150	440
S6	7.300	0.975	Open Manhole	1200	2.000	6.325	150				
S7	7.200	1.245	Open Manhole	1200	2.001	5.955	150	2.000	5.955	150	
S8	7.261	1.356	Open Manhole	1200	2.002	5.905	150	2.001	5.905	150	
S9	7.083	1.253	Open Manhole	1200	2.003	5.830	150	2.002	5.830	150	
S10	6.809	1.249	Open Manhole	1200	2.004	5.560	150	2.003	5.560	150	
S11	6.900	1.380	Open Manhole	1200	2.005	5.520	150	2.004	5.520	150	
S12	6.900	1.650	Open Manhole	1200	1.005	5.250	300	1.004	5.250	300	
								2.005	5.510	150	110
S13	7.227	1.347	Open Manhole	1200	3.000	5.880	150				
S14	7.280	1.460	Open Manhole	1200	3.001	5.820	150	3.000	5.820	150	
S15	7.290	1.550	Open Manhole	1200	3.002	5.740	150	3.001	5.740	150	
S16	7.277	1.577	Open Manhole	1200	3.003	5.700	150	3.002	5.700	150	
S17	7.378	1.678	Open Manhole	1200	3.004	6.115	150	3.003	5.700	150	
S18	7.323	1.283	Open Manhole	1200	3.005	6.040	150	3.004	6.040	150	
S19	7.436	1.336	Open Manhole	1200	4.000	6.100	150				
S20	7.300	1.310	Open Manhole	1200	3.006	5.990	150	3.005	5.990	150	
								4.000	5.990	150	
S21	7.180	1.300	Open Manhole	1200	3.007	5.880	150	3.006	5.880	150	
S255	7.100	1.480	Open Manhole	1200	5.000	5.620	150				
S254	7.104	1.484	Open Manhole	1200	5.001	5.620	150	5.000	5.620	150	
S22	7.425	1.805	Open Manhole	1200	5.002	5.620	225	5.001	5.620	150	
S23	7.250	1.396	Open Manhole	1200	6.000	5.854	150				
S24	7.100	1.600	Open Manhole	1200	3.008	5.500	300	3.007	5.650	150	
								5.002	5.500	225	
								6.000	5.650	150	
S26	6.876	1.473	Open Manhole	1200	3.009	5.403	300	3.008	5.403	300	
S27	6.772	1.413	Open Manhole	1200	3.010	5.359	300	3.009	5.359	300	
S28	6.674	1.354	Open Manhole	1200	3.011	5.320	300	3.010	5.320	300	
S29	6.571	1.114	Open Manhole	1200	7.000	5.457	150				
S30	6.481	1.261	Open Manhole	1200	3.012	5.220	300	3.011	5.220	300	
								7.000	5.370	150	
S31	6.514	1.334	Open Manhole	1200	3.013	5.180	300	3.012	5.180	300	
S32	6.650	1.500	Open Manhole	1200	1.006	5.150	300	1.005	5.150	300	

RSK LDE		Page 21
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions	Network 2018.1.1	

Manhole Schedules for Surface Network 1

MH Name	MH CL (m)	MH Depth (m)	MH Connection	MH Diam., L*W (mm)	PN	Pipe Out Invert Level (m)	Pipe Out Diameter (mm)	PN	Pipes In Invert Level (m)	Pipes In Diameter (mm)	Backdrop (mm)
S33	6.400	0.850	Open Manhole	1200	8.000	5.550	150	3.013	5.150	300	
S34	6.350	1.000	Open Manhole	1200	9.000	5.350	150				
S35	6.350	1.060	Open Manhole	1200	8.001	5.290	150	8.000	5.290	150	
								9.000	5.290	150	
S36	6.900	1.780	Open Manhole	1200	1.007	5.120	300	1.006	5.120	300	
								8.001	5.270	150	
S37	6.400	1.280	Open Manhole	1200	1.008	5.120	300	1.007	5.120	300	
S38	6.400	1.280	Open Manhole	1200	1.009	5.120	150	1.008	5.120	300	
S39	6.200	1.240	Open Manhole	1200	1.010	4.960	150	1.009	4.960	150	
S112	7.000	0.950	Open Manhole	1200	10.000	6.050	150				
S111	6.800	0.900	Open Manhole	1200	10.001	5.900	150	10.000	5.900	150	
S40	6.800	1.000	Open Manhole	1200	10.002	5.800	150	10.001	5.800	150	
S41	6.900	1.220	Open Manhole	1200	10.003	5.680	150	10.002	5.680	150	
S42	6.900	1.290	Open Manhole	1200	10.004	5.610	150	10.003	5.610	150	
S256	6.741	1.351	Open Manhole	1200	11.000	5.390	150				
S43	6.618	1.358	Open Manhole	1200	10.005	5.260	150	10.004	5.260	150	
								11.000	5.260	150	
S44	6.482	1.332	Open Manhole	1200	10.006	5.150	150	10.005	5.150	150	
S45	6.293	1.293	Open Manhole	1200	10.007	5.000	150	10.006	5.000	150	
S46	6.096	1.146	Open Manhole	1200	10.008	4.950	150	10.007	4.950	150	
S47	6.095	1.195	Open Manhole	1200	10.009	4.900	150	10.008	4.900	150	
S48	6.450	1.600	Open Manhole	1200	1.011	4.850	150	1.010	4.850	150	
								10.009	4.850	150	
S49	5.800	1.000	Open Manhole	1200	1.012	4.800	225	1.011	4.800	150	
S50	5.800	1.086	Open Manhole	1200	1.013	4.714	225	1.012	4.714	225	
S51	6.150	0.900	Open Manhole	1200	12.000	5.250	150				
S52	6.000	0.940	Open Manhole	1200	12.001	5.060	150	12.000	5.060	150	
S53	6.000	1.332	Open Manhole	1200	1.014	4.668	225	1.013	4.668	225	
								12.001	5.060	150	
S54	6.000	1.458	Open Manhole	1200	1.015	4.542	225	1.014	4.542	225	
S55	5.800	1.448	Open Manhole	1200	1.016	4.352	225	1.015	4.352	225	
S56	6.134	1.344	Open Manhole	1200	13.000	4.790	150				
S57	5.996	1.346	Open Manhole	1200	13.001	4.650	150	13.000	4.650	150	
S58	5.916	1.356	Open Manhole	1200	13.002	4.560	150	13.001	4.560	150	
S59	5.807	1.357	Open Manhole	1200	13.003	4.450	150	13.002	4.450	150	
S60	5.750	1.500	Open Manhole	1200	1.017	4.250	300	1.016	4.250	225	
								13.003	4.250	150	

RSK LDE							Page 22				
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT				Drove Lane, Yapton Surface Water Network Calculations - FEH Data							
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...				Designed by AMuthusami Checked by							
XP Solutions				Network 2018.1.1							
<u>Manhole Schedules for Surface Network 1</u>											
MH Name	MH CL (m)	MH Depth (m)	MH Connection	MH Diam., L*W (mm)	PN	Pipe Out Invert Level (m)	Diameter (mm)	PN	Pipes In Invert Level (m)	Diameter (mm)	Backdrop (mm)
S61	6.980	0.795	Open Manhole	1200	14.000	6.185	150				
S62	6.900	0.860	Open Manhole	1200	15.000	6.040	150				
S63	6.900	1.190	Open Manhole	1200	14.001	5.710	150	14.000	5.710	150	
								15.000	5.710	150	
S64	6.450	0.940	Open Manhole	1200	14.002	5.510	150	14.001	5.510	150	
S65	6.574	1.544	Open Manhole	1200	14.003	5.030	300	14.002	5.180	150	
S66	6.237	1.497	Open Manhole	1200	14.004	4.740	300	14.003	4.740	300	
S67	6.750	1.790	Open Manhole	1200	16.000	4.960	150				
S68	6.160	1.360	Open Manhole	1200	16.001	4.800	150	16.000	4.800	150	
S69	5.886	1.496	Open Manhole	1200	14.005	4.390	300	14.004	4.390	300	
								16.001	4.540	150	
S70	5.667	1.377	Open Manhole	1200	14.006	4.290	300	14.005	4.290	300	
S71	5.900	1.640	Open Manhole	1200	14.007	4.260	300	14.006	4.260	300	
S72	6.150	0.750	Open Manhole	1200	17.000	5.400	150				
S73	6.000	0.870	Open Manhole	1200	18.000	5.130	150				
S74	6.050	1.200	Open Manhole	1200	17.001	4.850	150	17.000	4.850	150	
								18.000	4.850	150	
S75	5.560	0.790	Open Manhole	1200	17.002	4.770	150	17.001	4.770	150	
S76	5.550	1.350	Open Manhole	1200	1.018	4.200	300	1.017	4.200	300	
								14.007	4.200	300	
								17.002	4.350	150	
S77	5.550	1.400	Open Manhole	1200	1.019	4.150	300	1.018	4.150	300	
S78	5.750	1.650	Open Manhole	1200	1.020	4.100	300	1.019	4.100	300	
S79	5.420	1.370	Open Manhole	1200	1.021	4.050	300	1.020	4.050	300	
S80	7.005	1.345	Open Manhole	1200	19.000	5.660	225				
S81	6.895	1.302	Open Manhole	1200	19.001	5.593	225	19.000	5.593	225	
S82	6.825	1.202	Open Manhole	1200	20.000	5.623	150				
S83	6.669	1.257	Open Manhole	1200	19.002	5.412	300	19.001	5.487	225	
								20.000	5.562	150	
S84	6.529	1.172	Open Manhole	1200	19.003	5.357	300	19.002	5.357	300	
S85	6.499	1.217	Open Manhole	1200	19.004	5.282	300	19.003	5.282	300	
S86	6.497	1.314	Open Manhole	1200	19.005	5.183	300	19.004	5.183	300	
S87	6.600	1.525	Open Manhole	1200	19.006	5.075	300	19.005	5.075	300	
S88	6.550	1.520	Open Manhole	1200	19.007	5.030	300	19.006	5.030	300	
S89	6.550	1.607	Open Manhole	1200	19.008	4.943	300	19.007	4.943	300	
S253	7.300	1.400	Open Manhole	1200	21.000	5.900	150				
S90	7.300	1.400	Open Manhole	1200	21.001	5.900	150	21.000	5.900	150	
S91	7.623	1.958	Open Manhole	1200	21.002	5.665	225	21.001	5.740	150	
©1982-2018 Innovyze											

RSK LDE		Page 23
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions	Network 2018.1.1	

Manhole Schedules for Surface Network 1

MH Name	MH CL (m)	MH Depth (m)	MH Connection	MH Diam., L*W (mm)	PN	Pipe Out Invert Level (m)	Diameter (mm)	PN	Pipes In Invert Level (m)	Diameter (mm)	Backdrop (mm)
S92	7.429	1.880	Open Manhole	1200	21.003	5.549	225	21.002	5.549	225	
S93	7.250	1.800	Open Manhole	1200	21.004	5.450	225	21.003	5.450	225	
S94	7.164	1.764	Open Manhole	1200	21.005	5.400	225	21.004	5.400	225	
S95	6.981	1.686	Open Manhole	1200	21.006	5.295	225	21.005	5.295	225	
S96	7.020	0.990	Open Manhole	1200	22.000	6.030	150				
S97	6.780	1.280	Open Manhole	1200	22.001	5.500	150	22.000	5.500	150	
S98	6.780	1.130	Open Manhole	1200	23.000	5.650	150				
S99	6.800	1.606	Open Manhole	1200	21.007	5.194	225	21.006	5.194	225	
								22.001	5.269	150	
								23.000	5.269	150	
S100	6.536	1.474	Open Manhole	1200	21.008	5.062	225	21.007	5.062	225	
S101	6.430	1.420	Open Manhole	1200	21.009	5.010	225	21.008	5.010	225	
S102	6.550	1.635	Open Manhole	1200	21.010	4.915	300	21.009	4.990	225	
S103	6.556	1.641	Open Manhole	1200	19.009	4.915	300	19.008	4.915	300	
								21.010	4.915	300	
S104	6.556	1.641	Open Manhole	1200	19.010	4.915	300	19.009	4.915	300	
S105	6.900	2.150	Open Manhole	1200	19.011	4.750	300	19.010	4.750	300	
S106	7.120	0.810	Open Manhole	1200	24.000	6.310	150				
S107	7.200	1.040	Open Manhole	1200	24.001	6.160	150	24.000	6.160	150	
S108	7.050	1.080	Open Manhole	1200	24.002	5.970	150	24.001	5.970	150	
S109	6.900	1.400	Open Manhole	1200	24.003	5.500	150	24.002	5.500	150	
S110	6.900	2.150	Open Manhole	1200	19.012	4.750	300	19.011	4.750	300	
								24.003	5.000	150	
S113	7.000	0.950	Open Manhole	1200	25.000	6.050	150				
S114	6.804	0.804	Open Manhole	1200	25.001	6.000	150	25.000	6.000	150	
S115	6.849	0.869	Open Manhole	1200	25.002	5.980	150	25.001	5.980	150	
S116	7.100	1.150	Open Manhole	1200	25.003	5.950	150	25.002	5.950	150	
S117	7.100	1.150	Open Manhole	1200	25.004	5.950	150	25.003	5.950	150	
S118	7.000	1.060	Open Manhole	1200	25.005	5.940	150	25.004	5.940	150	
S119	7.000	1.060	Open Manhole	1200	25.006	5.940	150	25.005	5.940	150	
S120	6.750	0.830	Open Manhole	1200	25.007	5.920	150	25.006	5.920	150	
S121	6.900	0.800	Open Manhole	1200	26.000	6.100	300				
S122	7.100	1.050	Open Manhole	1200	26.001	6.200	150	26.000	6.050	300	
S123	7.105	1.055	Open Manhole	1200	26.002	6.050	150	26.001	6.050	150	
S124	6.900	0.900	Open Manhole	1200	26.003	6.000	150	26.002	6.000	150	
S125	6.719	0.719	Open Manhole	1200	26.004	6.000	150	26.003	6.000	150	
S126	6.753	0.728	Open Manhole	1200	27.000	6.025	150				
S127	6.753	2.113	Open Manhole	1200	19.013	4.640	300	19.012	4.640	300	

©1982-2018 Innovyze

RSK LDE								Page 24			
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT				Drove Lane, Yapton Surface Water Network Calculations - FEH Data							
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...				Designed by AMuthusami Checked by							
XP Solutions								Network 2018.1.1			
<u>Manhole Schedules for Surface Network 1</u>											
MH Name	MH CL (m)	MH Depth (m)	MH Connection	MH Diam., L*W (mm)	PN	Pipe Out Invert Level (m)	Diameter (mm)	PN	Pipes In Invert Level (m)	Diameter (mm)	Backdrop (mm)
								25.007	5.910	150	1120
								26.004	5.910	150	1120
								27.000	5.910	150	1120
S128	6.700	0.820	Open Manhole	1200	28.000	5.880	150				
S129	6.745	0.955	Open Manhole	1200	28.001	5.790	150	28.000	5.790	150	
S130	6.600	2.000	Open Manhole	1200	19.014	4.600	300	19.013	4.600	300	
								28.001	5.600	150	850
S131	6.577	1.267	Open Manhole	1200	29.000	5.310	150				
S132	6.474	1.354	Open Manhole	1200	29.001	5.120	150	29.000	5.120	150	
S133	6.320	1.320	Open Manhole	1200	29.002	5.000	150	29.001	5.000	150	
S134	6.600	2.140	Open Manhole	1200	19.015	4.460	300	19.014	4.460	300	
								29.002	4.710	150	100
S135	6.370	0.820	Open Manhole	1200	30.000	5.550	150				
S136	6.600	2.140	Open Manhole	1200	19.016	4.460	300	19.015	4.460	300	
								30.000	4.710	150	100
S137	6.250	1.150	Open Manhole	1200	31.000	5.100	150				
S138	5.938	1.538	Open Manhole	1200	19.017	4.400	300	19.016	4.400	300	
								31.000	4.650	150	100
S139	6.300	1.020	Open Manhole	1200	32.000	5.280	150				
S140	6.000	0.870	Open Manhole	1200	32.001	5.130	150	32.000	5.130	150	
S141	5.930	0.960	Open Manhole	1200	32.002	4.970	150	32.001	4.970	150	
S142	6.074	0.786	Open Manhole	1200	33.000	5.288	150				
S143	6.070	1.160	Open Manhole	1200	32.003	4.910	150	32.002	4.910	150	
								33.000	4.910	150	
S144	5.900	1.500	Open Manhole	1200	19.018	4.400	300	19.017	4.400	300	
								32.003	4.650	150	100
S145	6.617	1.347	Open Manhole	1200	34.000	5.270	150				
S146	6.310	1.210	Open Manhole	1200	35.000	5.100	150				
S147	6.152	1.502	Open Manhole	1200	34.001	4.650	300	34.000	4.800	150	
								35.000	4.650	150	
S148	5.993	1.563	Open Manhole	1200	34.002	4.430	300	34.001	4.430	300	
S149	5.898	1.538	Open Manhole	1200	34.003	4.360	300	34.002	4.360	300	
S150	5.782	1.512	Open Manhole	1200	34.004	4.270	300	34.003	4.270	300	
S151	5.920	1.350	Open Manhole	1200	36.000	4.570	150				
S152	5.640	1.490	Open Manhole	1200	19.019	4.150	300	19.018	4.150	300	
								34.004	4.150	300	
								36.000	4.300	150	
S153	5.970	1.395	Open Manhole	1200	37.000	4.575	150				
©1982-2018 Innovyze											

RSK LDE								Page 25			
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT				Drove Lane, Yapton Surface Water Network Calculations - FEH Data							
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...				Designed by AMuthusami Checked by							
XP Solutions				Network 2018.1.1							
<u>Manhole Schedules for Surface Network 1</u>											
MH Name	MH CL (m)	MH Depth (m)	MH Connection	MH Diam.,L*W (mm)	PN	Pipe Out Invert Level (m)	Diameter (mm)	PN	Pipes In Invert Level (m)	Diameter (mm)	Backdrop (mm)
S154	5.850	1.400	Open Manhole	1200	38.000	4.450	150				
S155	5.780	1.660	Open Manhole	1200	19.020	4.120	300	19.019	4.120	300	
								37.000	4.270	150	
								38.000	4.270	150	
S156	5.780	1.660	Open Manhole	1200	19.021	4.120	300	19.020	4.120	300	
S157	5.635	1.670	Open Manhole	1200	19.022	3.965	300	19.021	3.965	300	
S158	5.750	1.180	Open Manhole	1200	39.000	4.570	150				
S159	5.617	1.347	Open Manhole	1200	39.001	4.270	150	39.000	4.270	150	
S160	5.474	1.354	Open Manhole	1200	39.002	4.120	150	39.001	4.120	150	
S161	5.367	1.347	Open Manhole	1200	40.000	4.020	225				
S162	5.397	1.512	Open Manhole	1200	19.023	3.885	300	19.022	3.885	300	
								39.002	4.035	150	
								40.000	3.960	225	
S163	5.400	1.531	Open Manhole	1200	19.024	3.869	300	19.023	3.869	300	
S164	5.420	1.585	Open Manhole	1200	1.022	3.835	300	1.021	3.835	300	
								19.024	3.835	300	
S165	5.200	1.365	Open Manhole	1200	1.023	3.835	300	1.022	3.835	300	
S166	5.200	1.365	Open Manhole	1200	1.024	3.835	300	1.023	3.835	300	
S167	5.602	1.322	Open Manhole	1200	41.000	4.280	150				
S168	5.700	0.980	Open Manhole	1200	42.000	4.720	150				
S169	5.505	1.345	Open Manhole	1200	41.001	4.160	150	41.000	4.160	150	
								42.000	4.160	150	
S170	5.630	1.330	Open Manhole	1200	43.000	4.300	150				
S171	5.369	1.329	Open Manhole	1200	43.001	4.040	150	43.000	4.040	150	
S172	5.276	1.363	Open Manhole	1200	41.002	3.913	225	41.001	3.988	150	
								43.001	3.988	150	
S173	5.122	1.267	Open Manhole	1200	41.003	3.855	225	41.002	3.855	225	
S174	5.170	1.325	Open Manhole	1200	44.000	3.845	150				
S175	5.050	1.330	Open Manhole	1200	41.004	3.720	225	41.003	3.720	225	
								44.000	3.795	150	
S176	4.950	1.230	Open Manhole	1200	1.025	3.720	300	1.024	3.720	300	
								41.004	3.720	225	
S177	4.450	0.750	Open Manhole	1200	1.026	3.700	300	1.025	3.700	300	
S178	6.900	0.750	Open Manhole	1200	45.000	6.150	150				
S179	6.900	1.000	Open Manhole	1200	45.001	5.900	150	45.000	5.900	150	
S180	6.750	0.986	Open Manhole	1200	45.002	5.764	150	45.001	5.764	150	
S181	6.530	0.871	Open Manhole	1200	45.003	5.659	150	45.002	5.659	150	
S182	6.780	1.270	Open Manhole	1200	45.004	5.510	150	45.003	5.510	150	
©1982-2018 Innovyze											

RSK LDE		Page 26
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions	Network 2018.1.1	

Manhole Schedules for Surface Network 1

MH Name	MH CL (m)	MH Depth (m)	MH Connection	MH Diam., L*W (mm)	PN	Pipe Out Invert Level (m)	Diameter (mm)	PN	Pipes In Invert Level (m)	Diameter (mm)	Backdrop (mm)
S183	6.739	1.286	Open Manhole	1200	46.000	5.453	150				
S184	6.863	1.583	Open Manhole	1200	45.005	5.280	225	45.004	5.355	150	
								46.000	5.355	150	
S185	6.728	1.568	Open Manhole	1200	45.006	5.160	225	45.005	5.160	225	
S186	6.550	1.590	Open Manhole	1200	45.007	4.960	225	45.006	4.960	225	
S187	6.300	1.420	Open Manhole	1200	45.008	4.880	225	45.007	4.880	225	
S188	6.750	1.900	Open Manhole	1200	45.009	4.850	300	45.008	4.850	225	
S189	6.750	1.930	Open Manhole	1200	45.010	4.820	300	45.009	4.820	300	
S190	6.300	1.520	Open Manhole	1200	45.011	4.780	300	45.010	4.780	300	
S191	6.370	0.810	Open Manhole	1200	47.000	5.560	150				
S192	6.200	0.800	Open Manhole	1200	47.001	5.400	150	47.000	5.400	150	
S193	6.200	1.450	Open Manhole	1200	45.012	4.750	300	45.011	4.750	300	
								47.001	5.000	150	
S194	6.150	1.520	Open Manhole	1200	45.013	4.630	300	45.012	4.630	300	
S195	6.614	1.214	Open Manhole	1200	48.000	5.400	150				
S196	6.700	1.000	Open Manhole	1200	49.000	5.700	150				
S197	6.385	1.375	Open Manhole	1200	48.001	5.010	150	48.000	5.010	150	
								49.000	5.010	150	
S198	6.129	1.309	Open Manhole	1200	48.002	4.820	150	48.001	4.820	150	
S199	5.992	1.342	Open Manhole	1200	48.003	4.650	150	48.002	4.650	150	
S200	5.950	1.360	Open Manhole	1200	48.004	4.590	150	48.003	4.590	150	
S201	5.950	1.450	Open Manhole	1200	45.014	4.500	300	45.013	4.500	300	
								48.004	4.500	150	
S202	6.180	0.980	Open Manhole	1200	50.000	5.200	150				
S203	6.000	1.050	Open Manhole	1200	50.001	4.950	150	50.000	4.950	150	
S204	5.850	1.050	Open Manhole	1200	50.002	4.800	150	50.001	4.800	150	
S205	5.700	1.200	Open Manhole	1200	50.003	4.500	150	50.002	4.500	150	
S206	5.500	1.050	Open Manhole	1200	45.015	4.450	300	45.014	4.450	300	
								50.003	4.450	150	
S207	7.068	1.418	Open Manhole	1200	51.000	5.650	150				
S208a	7.225	1.350	Open Manhole	1050	52.000	5.875	150				
S208	7.026	1.466	Open Manhole	1200	51.001	5.560	150	51.000	5.560	150	
								52.000	5.560	150	
S209	6.950	1.515	Open Manhole	1200	51.002	5.435	225	51.001	5.510	150	
S210	6.919	1.519	Open Manhole	1200	51.003	5.400	225	51.002	5.400	225	
S211	7.000	0.980	Open Manhole	1200	53.000	6.020	150				
S212	6.749	1.469	Open Manhole	1200	51.004	5.280	225	51.003	5.280	225	
								53.000	5.355	150	

RSK LDE								Page 27			
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT				Drove Lane, Yapton Surface Water Network Calculations - FEH Data							
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...				Designed by AMuthusami Checked by							
XP Solutions								Network 2018.1.1			
<u>Manhole Schedules for Surface Network 1</u>											
MH Name	MH CL (m)	MH Depth (m)	MH Connection	MH Diam., L*W (mm)	PN	Pipe Out Invert Level (m)	Diameter (mm)	PN	Pipes In Invert Level (m)	Diameter (mm)	Backdrop (mm)
S213	6.709	1.379	Open Manhole	1200	54.000	5.330	150				
S214	6.538	1.468	Open Manhole	1200	51.005	5.070	300	51.004	5.145	225	
								54.000	5.220	150	
S215	6.680	1.450	Open Manhole	1200	55.000	5.230	150				
S216	6.425	1.475	Open Manhole	1200	51.006	4.950	300	51.005	4.950	300	
								55.000	5.100	150	
S217	5.979	1.279	Open Manhole	1200	56.000	4.700	150				
S218	5.997	1.487	Open Manhole	1200	51.007	4.510	300	51.006	4.510	300	
								56.000	4.660	150	
S219	5.767	1.507	Open Manhole	1200	51.008	4.260	300	51.007	4.260	300	
S220	5.666	1.466	Open Manhole	1200	51.009	4.200	300	51.008	4.200	300	
S221	5.500	1.400	Open Manhole	1200	51.010	4.100	300	51.009	4.100	300	
S222	5.500	1.420	Open Manhole	1200	45.016	4.080	300	45.015	4.080	300	
								51.010	4.080	300	
S223	5.636	1.496	Open Manhole	1200	57.000	4.140	300				
S224	5.600	1.500	Open Manhole	1200	57.001	4.100	300	57.000	4.100	300	
S225	5.500	1.420	Open Manhole	1200	45.017	4.080	300	45.016	4.080	300	
								57.001	4.080	300	
S226	5.930	0.750	Open Manhole	1200	58.000	5.180	150				
S227	5.400	0.750	Open Manhole	1200	58.001	4.650	150	58.000	4.650	150	
S228	5.400	0.850	Open Manhole	1200	58.002	4.550	150	58.001	4.550	150	
S229	5.300	0.950	Open Manhole	1200	58.003	4.350	150	58.002	4.420	150	70
S230	5.250	1.190	Open Manhole	1200	45.018	4.060	300	45.017	4.060	300	
								58.003	4.310	150	100
S231	5.200	1.160	Open Manhole	1200	45.019	4.040	300	45.018	4.040	300	
S232	5.150	1.200	Open Manhole	1200	45.020	3.950	300	45.019	3.950	300	
S233	5.150	1.250	Open Manhole	1200	45.021	3.900	300	45.020	3.900	300	
S234	6.235	1.375	Open Manhole	1200	59.000	4.860	150				
S235	6.050	1.380	Open Manhole	1200	59.001	4.670	150	59.000	4.670	150	
S236	6.180	1.110	Open Manhole	1200	60.000	5.070	150				
S237	5.966	1.386	Open Manhole	1200	59.002	4.580	150	59.001	4.580	150	
								60.000	4.580	150	
S238	6.200	0.885	Open Manhole	1200	61.000	5.315	150				
S239	5.952	1.352	Open Manhole	1200	61.001	4.600	150	61.000	4.600	150	
S240	5.803	1.653	Open Manhole	1200	59.003	4.150	300	59.002	4.300	150	
								61.001	4.300	150	
S241	5.694	1.624	Open Manhole	1200	59.004	4.070	300	59.003	4.070	300	
S242	5.500	1.100	Open Manhole	600	62.000	4.400	150				
©1982-2018 Innovyze											

RSK LDE		Page 28
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions	Network 2018.1.1	

Manhole Schedules for Surface Network 1

MH Name	MH CL (m)	MH Depth (m)	MH Connection	MH Diam., L*W (mm)	PN	Pipe Out Invert Level (m)	Diameter (mm)	PN	Pipes In Invert Level (m)	Diameter (mm)	Backdrop (mm)
S243	5.279	1.459	Open Manhole	1200	59.005	3.820	300	59.004	3.820	300	
								62.000	3.970	150	
S244	5.172	1.402	Open Manhole	1200	59.006	3.770	300	59.005	3.770	300	
S245	5.100	1.350	Open Manhole	1200	59.007	3.750	300	59.006	3.750	300	
S246	5.000	1.250	Open Manhole	1200	45.022	3.750	300	45.021	3.750	300	
								59.007	3.750	300	
S247	5.250	0.905	Open Manhole	1200	63.000	4.345	150				
S248	5.100	0.850	Open Manhole	1200	63.001	4.250	150	63.000	4.250	150	
S249	4.500	0.750	Open Manhole	1200	45.023	3.750	300	45.022	3.750	300	
								63.001	3.900	150	
S250	4.450	0.750	Open Manhole	1200	1.027	3.700	300	1.026	3.700	300	
								45.023	3.700	300	
S251	4.450	0.800	Open Manhole	1800	1.028	3.650	300	1.027	3.650	300	
S252	4.450	0.850	Open Manhole	1200		OUTFALL		1.028	3.600	300	

RSK LDE	Page 29
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by
XP Solutions	Network 2018.1.1



PIPELINE SCHEDULES for Surface Network 1

Upstream Manhole

PN	Hyd Sect	Diam (mm)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
1.000	o	150	S1	6.900	5.600	1.150	Open Manhole	1200
1.001	o	150	S2	6.900	6.200	0.550	Open Manhole	1200
1.002	o	150	S3	6.900	6.150	0.600	Open Manhole	1200
1.003	o	150	S4	7.180	5.910	1.120	Open Manhole	1200
1.004	o	300	S5	6.900	5.250	1.350	Open Manhole	1200
2.000	o	150	S6	7.300	6.325	0.825	Open Manhole	1200
2.001	o	150	S7	7.200	5.955	1.095	Open Manhole	1200
2.002	o	150	S8	7.261	5.905	1.206	Open Manhole	1200
2.003	o	150	S9	7.083	5.830	1.103	Open Manhole	1200
2.004	o	150	S10	6.809	5.560	1.099	Open Manhole	1200
2.005	o	150	S11	6.900	5.520	1.230	Open Manhole	1200
1.005	o	300	S12	6.900	5.250	1.350	Open Manhole	1200
3.000	o	150	S13	7.227	5.880	1.197	Open Manhole	1200
3.001	o	150	S14	7.280	5.820	1.310	Open Manhole	1200
3.002	o	150	S15	7.290	5.740	1.400	Open Manhole	1200
3.003	o	150	S16	7.277	5.700	1.427	Open Manhole	1200
3.004	o	150	S17	7.378	6.115	1.113	Open Manhole	1200
3.005	o	150	S18	7.323	6.040	1.133	Open Manhole	1200

Downstream Manhole

PN	Length (m)	Slope (1:X)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
1.000	79.638	0.0	S2	6.900	5.600	1.150	Open Manhole	1200
1.001	3.896	77.9	S3	6.900	6.150	0.600	Open Manhole	1200
1.002	31.170	129.9	S4	7.180	5.910	1.120	Open Manhole	1200
1.003	7.034	100.5	S5	6.900	5.840	0.910	Open Manhole	1200
1.004	34.423	0.0	S12	6.900	5.250	1.350	Open Manhole	1200
2.000	48.100	130.0	S7	7.200	5.955	1.095	Open Manhole	1200
2.001	6.496	129.9	S8	7.261	5.905	1.206	Open Manhole	1200
2.002	9.686	129.1	S9	7.083	5.830	1.103	Open Manhole	1200
2.003	32.873	121.8	S10	6.809	5.560	1.099	Open Manhole	1200
2.004	2.949	73.7	S11	6.900	5.520	1.230	Open Manhole	1200
2.005	2.131	213.1	S12	6.900	5.510	1.240	Open Manhole	1200
1.005	49.746	497.5	S32	6.650	5.150	1.200	Open Manhole	1200
3.000	7.158	119.3	S14	7.280	5.820	1.310	Open Manhole	1200
3.001	5.290	66.1	S15	7.290	5.740	1.400	Open Manhole	1200
3.002	3.462	86.6	S16	7.277	5.700	1.427	Open Manhole	1200
3.003	23.754	0.0	S17	7.378	5.700	1.528	Open Manhole	1200
3.004	11.051	147.3	S18	7.323	6.040	1.133	Open Manhole	1200
3.005	6.763	135.3	S20	7.300	5.990	1.160	Open Manhole	1200

RSK LDE		Page 30
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions	Network 2018.1.1	

PIPELINE SCHEDULES for Surface Network 1

Upstream Manhole

PN	Hyd Sect	Diam (mm)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
4.000	o	150	S19	7.436	6.100	1.186	Open Manhole	1200
3.006	o	150	S20	7.300	5.990	1.160	Open Manhole	1200
3.007	o	150	S21	7.180	5.880	1.150	Open Manhole	1200
5.000	o	150	S255	7.100	5.620	1.330	Open Manhole	1200
5.001	o	150	S254	7.104	5.620	1.334	Open Manhole	1200
5.002	o	225	S22	7.425	5.620	1.580	Open Manhole	1200
6.000	o	150	S23	7.250	5.854	1.246	Open Manhole	1200
3.008	o	300	S24	7.100	5.500	1.300	Open Manhole	1200
3.009	o	300	S26	6.876	5.403	1.173	Open Manhole	1200
3.010	o	300	S27	6.772	5.359	1.113	Open Manhole	1200
3.011	o	300	S28	6.674	5.320	1.054	Open Manhole	1200
7.000	o	150	S29	6.571	5.457	0.964	Open Manhole	1200
3.012	o	300	S30	6.481	5.220	0.961	Open Manhole	1200
3.013	o	300	S31	6.514	5.180	1.034	Open Manhole	1200

Downstream Manhole

PN	Length (m)	Slope (1:X)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
4.000	14.266	129.7	S20	7.300	5.990	1.160	Open Manhole	1200
3.006	14.865	135.1	S21	7.180	5.880	1.150	Open Manhole	1200
3.007	9.626	41.9	S24	7.100	5.650	1.300	Open Manhole	1200
5.000	3.524	0.0	S254	7.104	5.620	1.334	Open Manhole	1200
5.001	3.983	0.0	S22	7.425	5.620	1.655	Open Manhole	1200
5.002	23.848	198.7	S24	7.100	5.500	1.375	Open Manhole	1200
6.000	6.882	33.7	S24	7.100	5.650	1.300	Open Manhole	1200
3.008	27.083	279.2	S26	6.876	5.403	1.173	Open Manhole	1200
3.009	12.356	280.8	S27	6.772	5.359	1.113	Open Manhole	1200
3.010	11.015	282.4	S28	6.674	5.320	1.054	Open Manhole	1200
3.011	18.288	182.9	S30	6.481	5.220	0.961	Open Manhole	1200
7.000	12.139	139.5	S30	6.481	5.370	0.961	Open Manhole	1200
3.012	8.479	212.0	S31	6.514	5.180	1.034	Open Manhole	1200
3.013	4.885	162.8	S32	6.650	5.150	1.200	Open Manhole	1200

RSK LDE		Page 31
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions	Network 2018.1.1	

PIPELINE SCHEDULES for Surface Network 1

Upstream Manhole

PN	Hyd Sect	Diam (mm)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
1.006	o	300	S32	6.650	5.150	1.200	Open Manhole	1200
8.000	o	150	S33	6.400	5.550	0.700	Open Manhole	1200
9.000	o	150	S34	6.350	5.350	0.850	Open Manhole	1200
8.001	o	150	S35	6.350	5.290	0.910	Open Manhole	1200
1.007	o	300	S36	6.900	5.120	1.480	Open Manhole	1200
1.008	o	300	S37	6.400	5.120	0.980	Open Manhole	1200
1.009	o	150	S38	6.400	5.120	1.130	Open Manhole	1200
1.010	o	150	S39	6.200	4.960	1.090	Open Manhole	1200
10.000	o	150	S112	7.000	6.050	0.800	Open Manhole	1200
10.001	o	150	S111	6.800	5.900	0.750	Open Manhole	1200
10.002	o	150	S40	6.800	5.800	0.850	Open Manhole	1200
10.003	o	150	S41	6.900	5.680	1.070	Open Manhole	1200
10.004	o	150	S42	6.900	5.610	1.140	Open Manhole	1200
11.000	o	150	S256	6.741	5.390	1.201	Open Manhole	1200

Downstream Manhole

PN	Length (m)	Slope (1:X)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
1.006	65.460	2182.0	S36	6.900	5.120	1.480	Open Manhole	1200
8.000	22.407	86.2	S35	6.350	5.290	0.910	Open Manhole	1200
9.000	8.117	135.3	S35	6.350	5.290	0.910	Open Manhole	1200
8.001	2.047	102.4	S36	6.900	5.270	1.480	Open Manhole	1200
1.007	11.501	0.0	S37	6.400	5.120	0.980	Open Manhole	1200
1.008	2.310	0.0	S38	6.400	5.120	0.980	Open Manhole	1200
1.009	15.488	96.8	S39	6.200	4.960	1.090	Open Manhole	1200
1.010	13.870	126.1	S48	6.450	4.850	1.450	Open Manhole	1200
10.000	19.391	129.3	S111	6.800	5.900	0.750	Open Manhole	1200
10.001	12.727	127.3	S40	6.800	5.800	0.850	Open Manhole	1200
10.002	21.907	182.6	S41	6.900	5.680	1.070	Open Manhole	1200
10.003	6.116	87.4	S42	6.900	5.610	1.140	Open Manhole	1200
10.004	20.997	60.0	S43	6.618	5.260	1.208	Open Manhole	1200
11.000	13.280	102.2	S43	6.618	5.260	1.208	Open Manhole	1200

RSK LDE		Page 32						
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT		Drove Lane, Yapton Surface Water Network Calculations - FEH Data						
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...		Designed by AMuthusami Checked by						
XP Solutions		Network 2018.1.1						
PIPELINE SCHEDULES for Surface Network 1								
Upstream Manhole								
PN	Hyd Sect	Diam (mm)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
10.005	o	150	S43	6.618	5.260	1.208	Open Manhole	1200
10.006	o	150	S44	6.482	5.150	1.182	Open Manhole	1200
10.007	o	150	S45	6.293	5.000	1.143	Open Manhole	1200
10.008	o	150	S46	6.096	4.950	0.996	Open Manhole	1200
10.009	o	150	S47	6.095	4.900	1.045	Open Manhole	1200
1.011	o	150	S48	6.450	4.850	1.450	Open Manhole	1200
1.012	o	225	S49	5.800	4.800	0.775	Open Manhole	1200
1.013	o	225	S50	5.800	4.714	0.861	Open Manhole	1200
12.000	o	150	S51	6.150	5.250	0.750	Open Manhole	1200
12.001	o	150	S52	6.000	5.060	0.790	Open Manhole	1200
1.014	o	225	S53	6.000	4.668	1.107	Open Manhole	1200
1.015	o	225	S54	6.000	4.542	1.233	Open Manhole	1200
1.016	o	225	S55	5.800	4.352	1.223	Open Manhole	1200
13.000	o	150	S56	6.134	4.790	1.194	Open Manhole	1200
13.001	o	150	S57	5.996	4.650	1.196	Open Manhole	1200
13.002	o	150	S58	5.916	4.560	1.206	Open Manhole	1200
Downstream Manhole								
PN	Length (m)	Slope (1:X)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
10.005	11.443	104.0	S44	6.482	5.150	1.182	Open Manhole	1200
10.006	20.944	139.6	S45	6.293	5.000	1.143	Open Manhole	1200
10.007	27.264	545.3	S46	6.096	4.950	0.996	Open Manhole	1200
10.008	8.359	167.2	S47	6.095	4.900	1.045	Open Manhole	1200
10.009	8.609	172.2	S48	6.450	4.850	1.450	Open Manhole	1200
1.011	5.898	118.0	S49	5.800	4.800	0.850	Open Manhole	1200
1.012	17.211	200.1	S50	5.800	4.714	0.861	Open Manhole	1200
1.013	9.176	199.5	S53	6.000	4.668	1.107	Open Manhole	1200
12.000	28.335	149.1	S52	6.000	5.060	0.790	Open Manhole	1200
12.001	2.239	0.0	S53	6.000	5.060	0.790	Open Manhole	1200
1.014	33.907	269.1	S54	6.000	4.542	1.233	Open Manhole	1200
1.015	27.240	143.4	S55	5.800	4.352	1.223	Open Manhole	1200
1.016	12.467	122.2	S60	5.750	4.250	1.275	Open Manhole	1200
13.000	12.825	91.6	S57	5.996	4.650	1.196	Open Manhole	1200
13.001	8.557	95.1	S58	5.916	4.560	1.206	Open Manhole	1200
13.002	12.946	117.7	S59	5.807	4.450	1.207	Open Manhole	1200
©1982-2018 Innovyze								

RSK LDE		Page 33						
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT		Drove Lane, Yapton Surface Water Network Calculations - FEH Data						
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...		Designed by AMuthusami Checked by						
XP Solutions		Network 2018.1.1						
PIPELINE SCHEDULES for Surface Network 1								
Upstream Manhole								
PN	Hyd Sect	Diam (mm)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
13.003	o	150	S59	5.807	4.450	1.207	Open Manhole	1200
1.017	o	300	S60	5.750	4.250	1.200	Open Manhole	1200
14.000	o	150	S61	6.980	6.185	0.645	Open Manhole	1200
15.000	o	150	S62	6.900	6.040	0.710	Open Manhole	1200
14.001	o	150	S63	6.900	5.710	1.040	Open Manhole	1200
14.002	o	150	S64	6.450	5.510	0.790	Open Manhole	1200
14.003	o	300	S65	6.574	5.030	1.244	Open Manhole	1200
14.004	o	300	S66	6.237	4.740	1.197	Open Manhole	1200
16.000	o	150	S67	6.750	4.960	1.640	Open Manhole	1200
16.001	o	150	S68	6.160	4.800	1.210	Open Manhole	1200
14.005	o	300	S69	5.886	4.390	1.196	Open Manhole	1200
14.006	o	300	S70	5.667	4.290	1.077	Open Manhole	1200
14.007	o	300	S71	5.900	4.260	1.340	Open Manhole	1200
17.000	o	150	S72	6.150	5.400	0.600	Open Manhole	1200
Downstream Manhole								
PN	Length (m)	Slope (1:X)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
13.003	15.042	75.2	S60	5.750	4.250	1.350	Open Manhole	1200
1.017	46.870	937.4	S76	5.550	4.200	1.050	Open Manhole	1200
14.000	62.024	130.6	S63	6.900	5.710	1.040	Open Manhole	1200
15.000	41.672	126.3	S63	6.900	5.710	1.040	Open Manhole	1200
14.001	24.212	121.1	S64	6.450	5.510	0.790	Open Manhole	1200
14.002	3.715	11.3	S65	6.574	5.180	1.244	Open Manhole	1200
14.003	37.147	128.1	S66	6.237	4.740	1.197	Open Manhole	1200
14.004	35.580	101.7	S69	5.886	4.390	1.196	Open Manhole	1200
16.000	19.366	121.0	S68	6.160	4.800	1.210	Open Manhole	1200
16.001	7.069	27.2	S69	5.886	4.540	1.196	Open Manhole	1200
14.005	26.222	262.2	S70	5.667	4.290	1.077	Open Manhole	1200
14.006	5.601	186.7	S71	5.900	4.260	1.340	Open Manhole	1200
14.007	5.773	96.2	S76	5.550	4.200	1.050	Open Manhole	1200
17.000	25.210	45.8	S74	6.050	4.850	1.050	Open Manhole	1200
©1982-2018 Innovyze								

RSK LDE	Page 34
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by
XP Solutions	Network 2018.1.1



PIPELINE SCHEDULES for Surface Network 1

Upstream Manhole

PN	Hyd Sect	Diam (mm)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
18.000	o	150	S73	6.000	5.130	0.720	Open Manhole	1200
17.001	o	150	S74	6.050	4.850	1.050	Open Manhole	1200
17.002	o	150	S75	5.560	4.770	0.640	Open Manhole	1200
1.018	o	300	S76	5.550	4.200	1.050	Open Manhole	1200
1.019	o	300	S77	5.550	4.150	1.100	Open Manhole	1200
1.020	o	300	S78	5.750	4.100	1.350	Open Manhole	1200
1.021	o	300	S79	5.420	4.050	1.070	Open Manhole	1200
19.000	o	225	S80	7.005	5.660	1.120	Open Manhole	1200
19.001	o	225	S81	6.895	5.593	1.077	Open Manhole	1200
20.000	o	150	S82	6.825	5.623	1.052	Open Manhole	1200
19.002	o	300	S83	6.669	5.412	0.957	Open Manhole	1200
19.003	o	300	S84	6.529	5.357	0.872	Open Manhole	1200
19.004	o	300	S85	6.499	5.282	0.917	Open Manhole	1200
19.005	o	300	S86	6.497	5.183	1.014	Open Manhole	1200
19.006	o	300	S87	6.600	5.075	1.225	Open Manhole	1200

Downstream Manhole

PN	Length (m)	Slope (1:X)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
18.000	12.463	44.5	S74	6.050	4.850	1.050	Open Manhole	1200
17.001	9.756	122.0	S75	5.560	4.770	0.640	Open Manhole	1200
17.002	32.780	78.0	S76	5.550	4.350	1.050	Open Manhole	1200
1.018	6.009	120.2	S77	5.550	4.150	1.100	Open Manhole	1200
1.019	10.456	209.1	S78	5.750	4.100	1.350	Open Manhole	1200
1.020	31.084	621.7	S79	5.420	4.050	1.070	Open Manhole	1200
1.021	34.007	158.2	S164	5.420	3.835	1.285	Open Manhole	1200
19.000	13.799	206.0	S81	6.895	5.593	1.077	Open Manhole	1200
19.001	21.664	204.4	S83	6.669	5.487	0.957	Open Manhole	1200
20.000	8.199	134.4	S83	6.669	5.562	0.957	Open Manhole	1200
19.002	15.413	280.2	S84	6.529	5.357	0.872	Open Manhole	1200
19.003	20.973	279.6	S85	6.499	5.282	0.917	Open Manhole	1200
19.004	27.653	279.3	S86	6.497	5.183	1.014	Open Manhole	1200
19.005	29.912	277.0	S87	6.600	5.075	1.225	Open Manhole	1200
19.006	10.054	223.4	S88	6.550	5.030	1.220	Open Manhole	1200

RSK LDE		Page 35																																																																																																																																																																																																																																																																																																																			
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT		Drove Lane, Yapton Surface Water Network Calculations - FEH Data																																																																																																																																																																																																																																																																																																																			
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...		Designed by AMuthusami Checked by																																																																																																																																																																																																																																																																																																																			
XP Solutions		Network 2018.1.1																																																																																																																																																																																																																																																																																																																			
PIPELINE SCHEDULES for Surface Network 1 Upstream Manhole <table><thead><tr><th>PN</th><th>Hyd Sect</th><th>Diam (mm)</th><th>MH Name</th><th>C.Level (m)</th><th>I.Level (m)</th><th>D.Depth (m)</th><th>MH Connection</th><th>MH DIAM., L*W (mm)</th></tr></thead><tbody><tr><td>19.007</td><td>o</td><td>300</td><td>S88</td><td>6.550</td><td>5.030</td><td>1.220</td><td>Open Manhole</td><td>1200</td></tr><tr><td>19.008</td><td>o</td><td>300</td><td>S89</td><td>6.550</td><td>4.943</td><td>1.307</td><td>Open Manhole</td><td>1200</td></tr><tr><td>21.000</td><td>o</td><td>150</td><td>S253</td><td>7.300</td><td>5.900</td><td>1.250</td><td>Open Manhole</td><td>1200</td></tr><tr><td>21.001</td><td>o</td><td>150</td><td>S90</td><td>7.300</td><td>5.900</td><td>1.250</td><td>Open Manhole</td><td>1200</td></tr><tr><td>21.002</td><td>o</td><td>225</td><td>S91</td><td>7.623</td><td>5.665</td><td>1.733</td><td>Open Manhole</td><td>1200</td></tr><tr><td>21.003</td><td>o</td><td>225</td><td>S92</td><td>7.429</td><td>5.549</td><td>1.655</td><td>Open Manhole</td><td>1200</td></tr><tr><td>21.004</td><td>o</td><td>225</td><td>S93</td><td>7.250</td><td>5.450</td><td>1.575</td><td>Open Manhole</td><td>1200</td></tr><tr><td>21.005</td><td>o</td><td>225</td><td>S94</td><td>7.164</td><td>5.400</td><td>1.539</td><td>Open Manhole</td><td>1200</td></tr><tr><td>21.006</td><td>o</td><td>225</td><td>S95</td><td>6.981</td><td>5.295</td><td>1.461</td><td>Open Manhole</td><td>1200</td></tr><tr><td>22.000</td><td>o</td><td>150</td><td>S96</td><td>7.020</td><td>6.030</td><td>0.840</td><td>Open Manhole</td><td>1200</td></tr><tr><td>22.001</td><td>o</td><td>150</td><td>S97</td><td>6.780</td><td>5.500</td><td>1.130</td><td>Open Manhole</td><td>1200</td></tr><tr><td>23.000</td><td>o</td><td>150</td><td>S98</td><td>6.780</td><td>5.650</td><td>0.980</td><td>Open Manhole</td><td>1200</td></tr><tr><td>21.007</td><td>o</td><td>225</td><td>S99</td><td>6.800</td><td>5.194</td><td>1.381</td><td>Open Manhole</td><td>1200</td></tr><tr><td>21.008</td><td>o</td><td>225</td><td>S100</td><td>6.536</td><td>5.062</td><td>1.249</td><td>Open Manhole</td><td>1200</td></tr><tr><td>21.009</td><td>o</td><td>225</td><td>S101</td><td>6.430</td><td>5.010</td><td>1.195</td><td>Open Manhole</td><td>1200</td></tr><tr><td>21.010</td><td>o</td><td>300</td><td>S102</td><td>6.550</td><td>4.915</td><td>1.335</td><td>Open Manhole</td><td>1200</td></tr></tbody></table> Downstream Manhole <table><thead><tr><th>PN</th><th>Length (m)</th><th>Slope (1:X)</th><th>MH Name</th><th>C.Level (m)</th><th>I.Level (m)</th><th>D.Depth (m)</th><th>MH Connection</th><th>MH DIAM., L*W (mm)</th></tr></thead><tbody><tr><td>19.007</td><td>20.595</td><td>236.7</td><td>S89</td><td>6.550</td><td>4.943</td><td>1.307</td><td>Open Manhole</td><td>1200</td></tr><tr><td>19.008</td><td>6.292</td><td>224.7</td><td>S103</td><td>6.556</td><td>4.915</td><td>1.341</td><td>Open Manhole</td><td>1200</td></tr><tr><td>21.000</td><td>4.298</td><td>0.0</td><td>S90</td><td>7.300</td><td>5.900</td><td>1.250</td><td>Open Manhole</td><td>1200</td></tr><tr><td>21.001</td><td>13.399</td><td>83.7</td><td>S91</td><td>7.623</td><td>5.740</td><td>1.733</td><td>Open Manhole</td><td>1200</td></tr><tr><td>21.002</td><td>23.360</td><td>201.4</td><td>S92</td><td>7.429</td><td>5.549</td><td>1.655</td><td>Open Manhole</td><td>1200</td></tr><tr><td>21.003</td><td>19.767</td><td>199.7</td><td>S93</td><td>7.250</td><td>5.450</td><td>1.575</td><td>Open Manhole</td><td>1200</td></tr><tr><td>21.004</td><td>10.130</td><td>202.6</td><td>S94</td><td>7.164</td><td>5.400</td><td>1.539</td><td>Open Manhole</td><td>1200</td></tr><tr><td>21.005</td><td>21.349</td><td>203.3</td><td>S95</td><td>6.981</td><td>5.295</td><td>1.461</td><td>Open Manhole</td><td>1200</td></tr><tr><td>21.006</td><td>20.837</td><td>206.3</td><td>S99</td><td>6.800</td><td>5.194</td><td>1.381</td><td>Open Manhole</td><td>1200</td></tr><tr><td>22.000</td><td>26.569</td><td>50.1</td><td>S97</td><td>6.780</td><td>5.500</td><td>1.130</td><td>Open Manhole</td><td>1200</td></tr><tr><td>22.001</td><td>3.435</td><td>14.9</td><td>S99</td><td>6.800</td><td>5.269</td><td>1.381</td><td>Open Manhole</td><td>1200</td></tr><tr><td>23.000</td><td>6.758</td><td>17.7</td><td>S99</td><td>6.800</td><td>5.269</td><td>1.381</td><td>Open Manhole</td><td>1200</td></tr><tr><td>21.007</td><td>26.521</td><td>200.9</td><td>S100</td><td>6.536</td><td>5.062</td><td>1.249</td><td>Open Manhole</td><td>1200</td></tr><tr><td>21.008</td><td>10.259</td><td>197.3</td><td>S101</td><td>6.430</td><td>5.010</td><td>1.195</td><td>Open Manhole</td><td>1200</td></tr><tr><td>21.009</td><td>4.237</td><td>211.9</td><td>S102</td><td>6.550</td><td>4.990</td><td>1.335</td><td>Open Manhole</td><td>1200</td></tr><tr><td>21.010</td><td>3.485</td><td>0.0</td><td>S103</td><td>6.556</td><td>4.915</td><td>1.341</td><td>Open Manhole</td><td>1200</td></tr></tbody></table>				PN	Hyd Sect	Diam (mm)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)	19.007	o	300	S88	6.550	5.030	1.220	Open Manhole	1200	19.008	o	300	S89	6.550	4.943	1.307	Open Manhole	1200	21.000	o	150	S253	7.300	5.900	1.250	Open Manhole	1200	21.001	o	150	S90	7.300	5.900	1.250	Open Manhole	1200	21.002	o	225	S91	7.623	5.665	1.733	Open Manhole	1200	21.003	o	225	S92	7.429	5.549	1.655	Open Manhole	1200	21.004	o	225	S93	7.250	5.450	1.575	Open Manhole	1200	21.005	o	225	S94	7.164	5.400	1.539	Open Manhole	1200	21.006	o	225	S95	6.981	5.295	1.461	Open Manhole	1200	22.000	o	150	S96	7.020	6.030	0.840	Open Manhole	1200	22.001	o	150	S97	6.780	5.500	1.130	Open Manhole	1200	23.000	o	150	S98	6.780	5.650	0.980	Open Manhole	1200	21.007	o	225	S99	6.800	5.194	1.381	Open Manhole	1200	21.008	o	225	S100	6.536	5.062	1.249	Open Manhole	1200	21.009	o	225	S101	6.430	5.010	1.195	Open Manhole	1200	21.010	o	300	S102	6.550	4.915	1.335	Open Manhole	1200	PN	Length (m)	Slope (1:X)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)	19.007	20.595	236.7	S89	6.550	4.943	1.307	Open Manhole	1200	19.008	6.292	224.7	S103	6.556	4.915	1.341	Open Manhole	1200	21.000	4.298	0.0	S90	7.300	5.900	1.250	Open Manhole	1200	21.001	13.399	83.7	S91	7.623	5.740	1.733	Open Manhole	1200	21.002	23.360	201.4	S92	7.429	5.549	1.655	Open Manhole	1200	21.003	19.767	199.7	S93	7.250	5.450	1.575	Open Manhole	1200	21.004	10.130	202.6	S94	7.164	5.400	1.539	Open Manhole	1200	21.005	21.349	203.3	S95	6.981	5.295	1.461	Open Manhole	1200	21.006	20.837	206.3	S99	6.800	5.194	1.381	Open Manhole	1200	22.000	26.569	50.1	S97	6.780	5.500	1.130	Open Manhole	1200	22.001	3.435	14.9	S99	6.800	5.269	1.381	Open Manhole	1200	23.000	6.758	17.7	S99	6.800	5.269	1.381	Open Manhole	1200	21.007	26.521	200.9	S100	6.536	5.062	1.249	Open Manhole	1200	21.008	10.259	197.3	S101	6.430	5.010	1.195	Open Manhole	1200	21.009	4.237	211.9	S102	6.550	4.990	1.335	Open Manhole	1200	21.010	3.485	0.0	S103	6.556	4.915	1.341	Open Manhole	1200
PN	Hyd Sect	Diam (mm)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)																																																																																																																																																																																																																																																																																																													
19.007	o	300	S88	6.550	5.030	1.220	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
19.008	o	300	S89	6.550	4.943	1.307	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
21.000	o	150	S253	7.300	5.900	1.250	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
21.001	o	150	S90	7.300	5.900	1.250	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
21.002	o	225	S91	7.623	5.665	1.733	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
21.003	o	225	S92	7.429	5.549	1.655	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
21.004	o	225	S93	7.250	5.450	1.575	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
21.005	o	225	S94	7.164	5.400	1.539	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
21.006	o	225	S95	6.981	5.295	1.461	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
22.000	o	150	S96	7.020	6.030	0.840	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
22.001	o	150	S97	6.780	5.500	1.130	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
23.000	o	150	S98	6.780	5.650	0.980	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
21.007	o	225	S99	6.800	5.194	1.381	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
21.008	o	225	S100	6.536	5.062	1.249	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
21.009	o	225	S101	6.430	5.010	1.195	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
21.010	o	300	S102	6.550	4.915	1.335	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
PN	Length (m)	Slope (1:X)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)																																																																																																																																																																																																																																																																																																													
19.007	20.595	236.7	S89	6.550	4.943	1.307	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
19.008	6.292	224.7	S103	6.556	4.915	1.341	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
21.000	4.298	0.0	S90	7.300	5.900	1.250	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
21.001	13.399	83.7	S91	7.623	5.740	1.733	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
21.002	23.360	201.4	S92	7.429	5.549	1.655	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
21.003	19.767	199.7	S93	7.250	5.450	1.575	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
21.004	10.130	202.6	S94	7.164	5.400	1.539	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
21.005	21.349	203.3	S95	6.981	5.295	1.461	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
21.006	20.837	206.3	S99	6.800	5.194	1.381	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
22.000	26.569	50.1	S97	6.780	5.500	1.130	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
22.001	3.435	14.9	S99	6.800	5.269	1.381	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
23.000	6.758	17.7	S99	6.800	5.269	1.381	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
21.007	26.521	200.9	S100	6.536	5.062	1.249	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
21.008	10.259	197.3	S101	6.430	5.010	1.195	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
21.009	4.237	211.9	S102	6.550	4.990	1.335	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
21.010	3.485	0.0	S103	6.556	4.915	1.341	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
©1982-2018 Innovyze																																																																																																																																																																																																																																																																																																																					

RSK LDE		Page 36						
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT		Drove Lane, Yapton Surface Water Network Calculations - FEH Data						
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...		Designed by AMuthusami Checked by						
XP Solutions		Network 2018.1.1						
PIPELINE SCHEDULES for Surface Network 1								
Upstream Manhole								
PN	Hyd Sect	Diam (mm)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
19.009	o	300	S103	6.556	4.915	1.341	Open Manhole	1200
19.010	o	300	S104	6.556	4.915	1.341	Open Manhole	1200
19.011	o	300	S105	6.900	4.750	1.850	Open Manhole	1200
24.000	o	150	S106	7.120	6.310	0.660	Open Manhole	1200
24.001	o	150	S107	7.200	6.160	0.890	Open Manhole	1200
24.002	o	150	S108	7.050	5.970	0.930	Open Manhole	1200
24.003	o	150	S109	6.900	5.500	1.250	Open Manhole	1200
19.012	o	300	S110	6.900	4.750	1.850	Open Manhole	1200
25.000	o	150	S113	7.000	6.050	0.800	Open Manhole	1200
25.001	o	150	S114	6.804	6.000	0.654	Open Manhole	1200
25.002	o	150	S115	6.849	5.980	0.719	Open Manhole	1200
25.003	o	150	S116	7.100	5.950	1.000	Open Manhole	1200
25.004	o	150	S117	7.100	5.950	1.000	Open Manhole	1200
25.005	o	150	S118	7.000	5.940	0.910	Open Manhole	1200
25.006	o	150	S119	7.000	5.940	0.910	Open Manhole	1200
25.007	o	150	S120	6.750	5.920	0.680	Open Manhole	1200
26.000	o	300	S121	6.900	6.100	0.500	Open Manhole	1200
Downstream Manhole								
PN	Length (m)	Slope (1:X)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
19.009	7.791	0.0	S104	6.556	4.915	1.341	Open Manhole	1200
19.010	24.064	145.8	S105	6.900	4.750	1.850	Open Manhole	1200
19.011	11.457	0.0	S110	6.900	4.750	1.850	Open Manhole	1200
24.000	18.358	122.4	S107	7.200	6.160	0.890	Open Manhole	1200
24.001	23.010	121.1	S108	7.050	5.970	0.930	Open Manhole	1200
24.002	11.017	23.4	S109	6.900	5.500	1.250	Open Manhole	1200
24.003	10.252	20.5	S110	6.900	5.000	1.750	Open Manhole	1200
19.012	25.858	235.1	S127	6.753	4.640	1.813	Open Manhole	1200
25.000	17.917	358.3	S114	6.804	6.000	0.654	Open Manhole	1200
25.001	17.329	866.5	S115	6.849	5.980	0.719	Open Manhole	1200
25.002	33.286	1109.5	S116	7.100	5.950	1.000	Open Manhole	1200
25.003	6.308	0.0	S117	7.100	5.950	1.000	Open Manhole	1200
25.004	18.925	1892.5	S118	7.000	5.940	0.910	Open Manhole	1200
25.005	8.662	0.0	S119	7.000	5.940	0.910	Open Manhole	1200
25.006	18.362	918.1	S120	6.750	5.920	0.680	Open Manhole	1200
25.007	6.116	611.6	S127	6.753	5.910	0.693	Open Manhole	1200
26.000	46.370	927.4	S122	7.100	6.050	0.750	Open Manhole	1200
©1982-2018 Innovyze								

RSK LDE		Page 37
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions	Network 2018.1.1	

PIPELINE SCHEDULES for Surface Network 1

Upstream Manhole

PN	Hyd Sect	Diam (mm)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
26.001	o	150	S122	7.100	6.200	0.750	Open Manhole	1200
26.002	o	150	S123	7.105	6.050	0.905	Open Manhole	1200
26.003	o	150	S124	6.900	6.000	0.750	Open Manhole	1200
26.004	o	150	S125	6.719	6.000	0.569	Open Manhole	1200
27.000	o	150	S126	6.753	6.025	0.578	Open Manhole	1200
19.013	o	300	S127	6.753	4.640	1.813	Open Manhole	1200
28.000	o	150	S128	6.700	5.880	0.670	Open Manhole	1200
28.001	o	150	S129	6.745	5.790	0.805	Open Manhole	1200
19.014	o	300	S130	6.600	4.600	1.700	Open Manhole	1200
29.000	o	150	S131	6.577	5.310	1.117	Open Manhole	1200
29.001	o	150	S132	6.474	5.120	1.204	Open Manhole	1200
29.002	o	150	S133	6.320	5.000	1.170	Open Manhole	1200
19.015	o	300	S134	6.600	4.460	1.840	Open Manhole	1200
30.000	o	150	S135	6.370	5.550	0.670	Open Manhole	1200

Downstream Manhole

PN	Length (m)	Slope (1:X)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
26.001	9.129	60.9	S123	7.105	6.050	0.905	Open Manhole	1200
26.002	16.992	339.8	S124	6.900	6.000	0.750	Open Manhole	1200
26.003	8.356	0.0	S125	6.719	6.000	0.569	Open Manhole	1200
26.004	12.917	143.5	S127	6.753	5.910	0.693	Open Manhole	1200
27.000	17.312	150.5	S127	6.753	5.910	0.693	Open Manhole	1200
19.013	15.685	392.1	S130	6.600	4.600	1.700	Open Manhole	1200
28.000	9.451	105.0	S129	6.745	5.790	0.805	Open Manhole	1200
28.001	9.804	51.6	S130	6.600	5.600	0.850	Open Manhole	1200
19.014	34.119	243.7	S134	6.600	4.460	1.840	Open Manhole	1200
29.000	7.073	37.2	S132	6.474	5.120	1.204	Open Manhole	1200
29.001	13.576	113.1	S133	6.320	5.000	1.170	Open Manhole	1200
29.002	8.815	30.4	S134	6.600	4.710	1.740	Open Manhole	1200
19.015	23.076	0.0	S136	6.600	4.460	1.840	Open Manhole	1200
30.000	9.323	11.1	S136	6.600	4.710	1.740	Open Manhole	1200

RSK LDE		Page 38																																																																																																																																																																																																																									
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT		Drove Lane, Yapton Surface Water Network Calculations - FEH Data																																																																																																																																																																																																																									
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...		Designed by AMuthusami Checked by																																																																																																																																																																																																																									
XP Solutions		Network 2018.1.1																																																																																																																																																																																																																									
PIPELINE SCHEDULES for Surface Network 1 Upstream Manhole <table><tr><th>PN</th><th>Hyd Sect</th><th>Diam (mm)</th><th>MH Name</th><th>C.Level (m)</th><th>I.Level (m)</th><th>D.Depth (m)</th><th>MH Connection</th><th>MH DIAM., L*W (mm)</th></tr><tr><td>19.016</td><td>o</td><td>300</td><td>S136</td><td>6.600</td><td>4.460</td><td>1.840</td><td>Open Manhole</td><td>1200</td></tr><tr><td>31.000</td><td>o</td><td>150</td><td>S137</td><td>6.250</td><td>5.100</td><td>1.000</td><td>Open Manhole</td><td>1200</td></tr><tr><td>19.017</td><td>o</td><td>300</td><td>S138</td><td>5.938</td><td>4.400</td><td>1.238</td><td>Open Manhole</td><td>1200</td></tr><tr><td>32.000</td><td>o</td><td>150</td><td>S139</td><td>6.300</td><td>5.280</td><td>0.870</td><td>Open Manhole</td><td>1200</td></tr><tr><td>32.001</td><td>o</td><td>150</td><td>S140</td><td>6.000</td><td>5.130</td><td>0.720</td><td>Open Manhole</td><td>1200</td></tr><tr><td>32.002</td><td>o</td><td>150</td><td>S141</td><td>5.930</td><td>4.970</td><td>0.810</td><td>Open Manhole</td><td>1200</td></tr><tr><td>33.000</td><td>o</td><td>150</td><td>S142</td><td>6.074</td><td>5.288</td><td>0.636</td><td>Open Manhole</td><td>1200</td></tr><tr><td>32.003</td><td>o</td><td>150</td><td>S143</td><td>6.070</td><td>4.910</td><td>1.010</td><td>Open Manhole</td><td>1200</td></tr><tr><td>19.018</td><td>o</td><td>300</td><td>S144</td><td>5.900</td><td>4.400</td><td>1.200</td><td>Open Manhole</td><td>1200</td></tr><tr><td>34.000</td><td>o</td><td>150</td><td>S145</td><td>6.617</td><td>5.270</td><td>1.197</td><td>Open Manhole</td><td>1200</td></tr><tr><td>35.000</td><td>o</td><td>150</td><td>S146</td><td>6.310</td><td>5.100</td><td>1.060</td><td>Open Manhole</td><td>1200</td></tr></table> Downstream Manhole <table><tr><th>PN</th><th>Length (m)</th><th>Slope (1:X)</th><th>MH Name</th><th>C.Level (m)</th><th>I.Level (m)</th><th>D.Depth (m)</th><th>MH Connection</th><th>MH DIAM., L*W (mm)</th></tr><tr><td>19.016</td><td>15.391</td><td>256.5</td><td>S138</td><td>5.938</td><td>4.400</td><td>1.238</td><td>Open Manhole</td><td>1200</td></tr><tr><td>31.000</td><td>10.092</td><td>22.4</td><td>S138</td><td>5.938</td><td>4.650</td><td>1.138</td><td>Open Manhole</td><td>1200</td></tr><tr><td>19.017</td><td>14.640</td><td>0.0</td><td>S144</td><td>5.900</td><td>4.400</td><td>1.200</td><td>Open Manhole</td><td>1200</td></tr><tr><td>32.000</td><td>19.257</td><td>128.4</td><td>S140</td><td>6.000</td><td>5.130</td><td>0.720</td><td>Open Manhole</td><td>1200</td></tr><tr><td>32.001</td><td>21.001</td><td>131.3</td><td>S141</td><td>5.930</td><td>4.970</td><td>0.810</td><td>Open Manhole</td><td>1200</td></tr><tr><td>32.002</td><td>6.741</td><td>112.4</td><td>S143</td><td>6.070</td><td>4.910</td><td>1.010</td><td>Open Manhole</td><td>1200</td></tr><tr><td>33.000</td><td>20.846</td><td>55.1</td><td>S143</td><td>6.070</td><td>4.910</td><td>1.010</td><td>Open Manhole</td><td>1200</td></tr><tr><td>32.003</td><td>7.942</td><td>30.5</td><td>S144</td><td>5.900</td><td>4.650</td><td>1.100</td><td>Open Manhole</td><td>1200</td></tr><tr><td>19.018</td><td>11.784</td><td>47.1</td><td>S152</td><td>5.640</td><td>4.150</td><td>1.190</td><td>Open Manhole</td><td>1200</td></tr><tr><td>34.000</td><td>56.564</td><td>120.3</td><td>S147</td><td>6.152</td><td>4.800</td><td>1.202</td><td>Open Manhole</td><td>1200</td></tr><tr><td>35.000</td><td>4.645</td><td>10.3</td><td>S147</td><td>6.152</td><td>4.650</td><td>1.352</td><td>Open Manhole</td><td>1200</td></tr></table>				PN	Hyd Sect	Diam (mm)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)	19.016	o	300	S136	6.600	4.460	1.840	Open Manhole	1200	31.000	o	150	S137	6.250	5.100	1.000	Open Manhole	1200	19.017	o	300	S138	5.938	4.400	1.238	Open Manhole	1200	32.000	o	150	S139	6.300	5.280	0.870	Open Manhole	1200	32.001	o	150	S140	6.000	5.130	0.720	Open Manhole	1200	32.002	o	150	S141	5.930	4.970	0.810	Open Manhole	1200	33.000	o	150	S142	6.074	5.288	0.636	Open Manhole	1200	32.003	o	150	S143	6.070	4.910	1.010	Open Manhole	1200	19.018	o	300	S144	5.900	4.400	1.200	Open Manhole	1200	34.000	o	150	S145	6.617	5.270	1.197	Open Manhole	1200	35.000	o	150	S146	6.310	5.100	1.060	Open Manhole	1200	PN	Length (m)	Slope (1:X)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)	19.016	15.391	256.5	S138	5.938	4.400	1.238	Open Manhole	1200	31.000	10.092	22.4	S138	5.938	4.650	1.138	Open Manhole	1200	19.017	14.640	0.0	S144	5.900	4.400	1.200	Open Manhole	1200	32.000	19.257	128.4	S140	6.000	5.130	0.720	Open Manhole	1200	32.001	21.001	131.3	S141	5.930	4.970	0.810	Open Manhole	1200	32.002	6.741	112.4	S143	6.070	4.910	1.010	Open Manhole	1200	33.000	20.846	55.1	S143	6.070	4.910	1.010	Open Manhole	1200	32.003	7.942	30.5	S144	5.900	4.650	1.100	Open Manhole	1200	19.018	11.784	47.1	S152	5.640	4.150	1.190	Open Manhole	1200	34.000	56.564	120.3	S147	6.152	4.800	1.202	Open Manhole	1200	35.000	4.645	10.3	S147	6.152	4.650	1.352	Open Manhole	1200
PN	Hyd Sect	Diam (mm)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)																																																																																																																																																																																																																			
19.016	o	300	S136	6.600	4.460	1.840	Open Manhole	1200																																																																																																																																																																																																																			
31.000	o	150	S137	6.250	5.100	1.000	Open Manhole	1200																																																																																																																																																																																																																			
19.017	o	300	S138	5.938	4.400	1.238	Open Manhole	1200																																																																																																																																																																																																																			
32.000	o	150	S139	6.300	5.280	0.870	Open Manhole	1200																																																																																																																																																																																																																			
32.001	o	150	S140	6.000	5.130	0.720	Open Manhole	1200																																																																																																																																																																																																																			
32.002	o	150	S141	5.930	4.970	0.810	Open Manhole	1200																																																																																																																																																																																																																			
33.000	o	150	S142	6.074	5.288	0.636	Open Manhole	1200																																																																																																																																																																																																																			
32.003	o	150	S143	6.070	4.910	1.010	Open Manhole	1200																																																																																																																																																																																																																			
19.018	o	300	S144	5.900	4.400	1.200	Open Manhole	1200																																																																																																																																																																																																																			
34.000	o	150	S145	6.617	5.270	1.197	Open Manhole	1200																																																																																																																																																																																																																			
35.000	o	150	S146	6.310	5.100	1.060	Open Manhole	1200																																																																																																																																																																																																																			
PN	Length (m)	Slope (1:X)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)																																																																																																																																																																																																																			
19.016	15.391	256.5	S138	5.938	4.400	1.238	Open Manhole	1200																																																																																																																																																																																																																			
31.000	10.092	22.4	S138	5.938	4.650	1.138	Open Manhole	1200																																																																																																																																																																																																																			
19.017	14.640	0.0	S144	5.900	4.400	1.200	Open Manhole	1200																																																																																																																																																																																																																			
32.000	19.257	128.4	S140	6.000	5.130	0.720	Open Manhole	1200																																																																																																																																																																																																																			
32.001	21.001	131.3	S141	5.930	4.970	0.810	Open Manhole	1200																																																																																																																																																																																																																			
32.002	6.741	112.4	S143	6.070	4.910	1.010	Open Manhole	1200																																																																																																																																																																																																																			
33.000	20.846	55.1	S143	6.070	4.910	1.010	Open Manhole	1200																																																																																																																																																																																																																			
32.003	7.942	30.5	S144	5.900	4.650	1.100	Open Manhole	1200																																																																																																																																																																																																																			
19.018	11.784	47.1	S152	5.640	4.150	1.190	Open Manhole	1200																																																																																																																																																																																																																			
34.000	56.564	120.3	S147	6.152	4.800	1.202	Open Manhole	1200																																																																																																																																																																																																																			
35.000	4.645	10.3	S147	6.152	4.650	1.352	Open Manhole	1200																																																																																																																																																																																																																			
©1982-2018 Innovyze																																																																																																																																																																																																																											

RSK LDE		Page 39						
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT		Drove Lane, Yapton Surface Water Network Calculations - FEH Data						
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...		Designed by AMuthusami Checked by						
XP Solutions		Network 2018.1.1						
PIPELINE SCHEDULES for Surface Network 1								
Upstream Manhole								
PN	Hyd Sect	Diam (mm)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
34.001	o	300	S147	6.152	4.650	1.202	Open Manhole	1200
34.002	o	300	S148	5.993	4.430	1.263	Open Manhole	1200
34.003	o	300	S149	5.898	4.360	1.238	Open Manhole	1200
34.004	o	300	S150	5.782	4.270	1.212	Open Manhole	1200
36.000	o	150	S151	5.920	4.570	1.200	Open Manhole	1200
19.019	o	300	S152	5.640	4.150	1.190	Open Manhole	1200
37.000	o	150	S153	5.970	4.575	1.245	Open Manhole	1200
38.000	o	150	S154	5.850	4.450	1.250	Open Manhole	1200
19.020	o	300	S155	5.780	4.120	1.360	Open Manhole	1200
19.021	o	300	S156	5.780	4.120	1.360	Open Manhole	1200
19.022	o	300	S157	5.635	3.965	1.370	Open Manhole	1200
39.000	o	150	S158	5.750	4.570	1.030	Open Manhole	1200
39.001	o	150	S159	5.617	4.270	1.197	Open Manhole	1200
39.002	o	150	S160	5.474	4.120	1.204	Open Manhole	1200
Downstream Manhole								
PN	Length (m)	Slope (1:X)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
34.001	18.478	84.0	S148	5.993	4.430	1.263	Open Manhole	1200
34.002	12.434	177.6	S149	5.898	4.360	1.238	Open Manhole	1200
34.003	14.555	161.7	S150	5.782	4.270	1.212	Open Manhole	1200
34.004	22.413	186.8	S152	5.640	4.150	1.190	Open Manhole	1200
36.000	20.257	75.0	S152	5.640	4.300	1.190	Open Manhole	1200
19.019	4.632	154.4	S155	5.780	4.120	1.360	Open Manhole	1200
37.000	9.059	29.7	S155	5.780	4.270	1.360	Open Manhole	1200
38.000	6.094	33.9	S155	5.780	4.270	1.360	Open Manhole	1200
19.020	11.644	0.0	S156	5.780	4.120	1.360	Open Manhole	1200
19.021	32.158	207.5	S157	5.635	3.965	1.370	Open Manhole	1200
19.022	6.651	83.1	S162	5.397	3.885	1.212	Open Manhole	1200
39.000	5.810	19.4	S159	5.617	4.270	1.197	Open Manhole	1200
39.001	14.385	95.9	S160	5.474	4.120	1.204	Open Manhole	1200
39.002	7.928	93.3	S162	5.397	4.035	1.212	Open Manhole	1200
©1982-2018 Innovyze								

RSK LDE		Page 40																																																																																																																																																																																																																																																													
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT		Drove Lane, Yapton Surface Water Network Calculations - FEH Data																																																																																																																																																																																																																																																													
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...		Designed by AMuthusami Checked by																																																																																																																																																																																																																																																													
XP Solutions		Network 2018.1.1																																																																																																																																																																																																																																																													
PIPELINE SCHEDULES for Surface Network 1 Upstream Manhole <table><thead><tr><th>PN</th><th>Hyd Sect</th><th>Diam (mm)</th><th>MH Name</th><th>C.Level (m)</th><th>I.Level (m)</th><th>D.Depth (m)</th><th>MH Connection</th><th>MH DIAM., L*W (mm)</th></tr></thead><tbody><tr><td>40.000</td><td>o</td><td>225</td><td>S161</td><td>5.367</td><td>4.020</td><td>1.122</td><td>Open Manhole</td><td>1200</td></tr><tr><td>19.023</td><td>o</td><td>300</td><td>S162</td><td>5.397</td><td>3.885</td><td>1.212</td><td>Open Manhole</td><td>1200</td></tr><tr><td>19.024</td><td>o</td><td>300</td><td>S163</td><td>5.400</td><td>3.869</td><td>1.231</td><td>Open Manhole</td><td>1200</td></tr><tr><td>1.022</td><td>o</td><td>300</td><td>S164</td><td>5.420</td><td>3.835</td><td>1.285</td><td>Open Manhole</td><td>1200</td></tr><tr><td>1.023</td><td>o</td><td>300</td><td>S165</td><td>5.200</td><td>3.835</td><td>1.065</td><td>Open Manhole</td><td>1200</td></tr><tr><td>1.024</td><td>o</td><td>300</td><td>S166</td><td>5.200</td><td>3.835</td><td>1.065</td><td>Open Manhole</td><td>1200</td></tr><tr><td>41.000</td><td>o</td><td>150</td><td>S167</td><td>5.602</td><td>4.280</td><td>1.172</td><td>Open Manhole</td><td>1200</td></tr><tr><td>42.000</td><td>o</td><td>150</td><td>S168</td><td>5.700</td><td>4.720</td><td>0.830</td><td>Open Manhole</td><td>1200</td></tr><tr><td>41.001</td><td>o</td><td>150</td><td>S169</td><td>5.505</td><td>4.160</td><td>1.195</td><td>Open Manhole</td><td>1200</td></tr><tr><td>43.000</td><td>o</td><td>150</td><td>S170</td><td>5.630</td><td>4.300</td><td>1.180</td><td>Open Manhole</td><td>1200</td></tr><tr><td>43.001</td><td>o</td><td>150</td><td>S171</td><td>5.369</td><td>4.040</td><td>1.179</td><td>Open Manhole</td><td>1200</td></tr><tr><td>41.002</td><td>o</td><td>225</td><td>S172</td><td>5.276</td><td>3.913</td><td>1.138</td><td>Open Manhole</td><td>1200</td></tr><tr><td>41.003</td><td>o</td><td>225</td><td>S173</td><td>5.122</td><td>3.855</td><td>1.042</td><td>Open Manhole</td><td>1200</td></tr></tbody></table> Downstream Manhole <table><thead><tr><th>PN</th><th>Length (m)</th><th>Slope (1:X)</th><th>MH Name</th><th>C.Level (m)</th><th>I.Level (m)</th><th>D.Depth (m)</th><th>MH Connection</th><th>MH DIAM., L*W (mm)</th></tr></thead><tbody><tr><td>40.000</td><td>6.955</td><td>115.9</td><td>S162</td><td>5.397</td><td>3.960</td><td>1.212</td><td>Open Manhole</td><td>1200</td></tr><tr><td>19.023</td><td>4.513</td><td>282.1</td><td>S163</td><td>5.400</td><td>3.869</td><td>1.231</td><td>Open Manhole</td><td>1200</td></tr><tr><td>19.024</td><td>8.201</td><td>241.2</td><td>S164</td><td>5.420</td><td>3.835</td><td>1.285</td><td>Open Manhole</td><td>1200</td></tr><tr><td>1.022</td><td>17.390</td><td>0.0</td><td>S165</td><td>5.200</td><td>3.835</td><td>1.065</td><td>Open Manhole</td><td>1200</td></tr><tr><td>1.023</td><td>48.402</td><td>0.0</td><td>S166</td><td>5.200</td><td>3.835</td><td>1.065</td><td>Open Manhole</td><td>1200</td></tr><tr><td>1.024</td><td>38.318</td><td>333.2</td><td>S176</td><td>4.950</td><td>3.720</td><td>0.930</td><td>Open Manhole</td><td>1200</td></tr><tr><td>41.000</td><td>11.954</td><td>99.6</td><td>S169</td><td>5.505</td><td>4.160</td><td>1.195</td><td>Open Manhole</td><td>1200</td></tr><tr><td>42.000</td><td>7.349</td><td>13.1</td><td>S169</td><td>5.505</td><td>4.160</td><td>1.195</td><td>Open Manhole</td><td>1200</td></tr><tr><td>41.001</td><td>22.295</td><td>129.6</td><td>S172</td><td>5.276</td><td>3.988</td><td>1.138</td><td>Open Manhole</td><td>1200</td></tr><tr><td>43.000</td><td>6.317</td><td>24.3</td><td>S171</td><td>5.369</td><td>4.040</td><td>1.179</td><td>Open Manhole</td><td>1200</td></tr><tr><td>43.001</td><td>6.785</td><td>130.5</td><td>S172</td><td>5.276</td><td>3.988</td><td>1.138</td><td>Open Manhole</td><td>1200</td></tr><tr><td>41.002</td><td>11.709</td><td>201.9</td><td>S173</td><td>5.122</td><td>3.855</td><td>1.042</td><td>Open Manhole</td><td>1200</td></tr><tr><td>41.003</td><td>27.011</td><td>200.1</td><td>S175</td><td>5.050</td><td>3.720</td><td>1.105</td><td>Open Manhole</td><td>1200</td></tr></tbody></table>				PN	Hyd Sect	Diam (mm)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)	40.000	o	225	S161	5.367	4.020	1.122	Open Manhole	1200	19.023	o	300	S162	5.397	3.885	1.212	Open Manhole	1200	19.024	o	300	S163	5.400	3.869	1.231	Open Manhole	1200	1.022	o	300	S164	5.420	3.835	1.285	Open Manhole	1200	1.023	o	300	S165	5.200	3.835	1.065	Open Manhole	1200	1.024	o	300	S166	5.200	3.835	1.065	Open Manhole	1200	41.000	o	150	S167	5.602	4.280	1.172	Open Manhole	1200	42.000	o	150	S168	5.700	4.720	0.830	Open Manhole	1200	41.001	o	150	S169	5.505	4.160	1.195	Open Manhole	1200	43.000	o	150	S170	5.630	4.300	1.180	Open Manhole	1200	43.001	o	150	S171	5.369	4.040	1.179	Open Manhole	1200	41.002	o	225	S172	5.276	3.913	1.138	Open Manhole	1200	41.003	o	225	S173	5.122	3.855	1.042	Open Manhole	1200	PN	Length (m)	Slope (1:X)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)	40.000	6.955	115.9	S162	5.397	3.960	1.212	Open Manhole	1200	19.023	4.513	282.1	S163	5.400	3.869	1.231	Open Manhole	1200	19.024	8.201	241.2	S164	5.420	3.835	1.285	Open Manhole	1200	1.022	17.390	0.0	S165	5.200	3.835	1.065	Open Manhole	1200	1.023	48.402	0.0	S166	5.200	3.835	1.065	Open Manhole	1200	1.024	38.318	333.2	S176	4.950	3.720	0.930	Open Manhole	1200	41.000	11.954	99.6	S169	5.505	4.160	1.195	Open Manhole	1200	42.000	7.349	13.1	S169	5.505	4.160	1.195	Open Manhole	1200	41.001	22.295	129.6	S172	5.276	3.988	1.138	Open Manhole	1200	43.000	6.317	24.3	S171	5.369	4.040	1.179	Open Manhole	1200	43.001	6.785	130.5	S172	5.276	3.988	1.138	Open Manhole	1200	41.002	11.709	201.9	S173	5.122	3.855	1.042	Open Manhole	1200	41.003	27.011	200.1	S175	5.050	3.720	1.105	Open Manhole	1200
PN	Hyd Sect	Diam (mm)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)																																																																																																																																																																																																																																																							
40.000	o	225	S161	5.367	4.020	1.122	Open Manhole	1200																																																																																																																																																																																																																																																							
19.023	o	300	S162	5.397	3.885	1.212	Open Manhole	1200																																																																																																																																																																																																																																																							
19.024	o	300	S163	5.400	3.869	1.231	Open Manhole	1200																																																																																																																																																																																																																																																							
1.022	o	300	S164	5.420	3.835	1.285	Open Manhole	1200																																																																																																																																																																																																																																																							
1.023	o	300	S165	5.200	3.835	1.065	Open Manhole	1200																																																																																																																																																																																																																																																							
1.024	o	300	S166	5.200	3.835	1.065	Open Manhole	1200																																																																																																																																																																																																																																																							
41.000	o	150	S167	5.602	4.280	1.172	Open Manhole	1200																																																																																																																																																																																																																																																							
42.000	o	150	S168	5.700	4.720	0.830	Open Manhole	1200																																																																																																																																																																																																																																																							
41.001	o	150	S169	5.505	4.160	1.195	Open Manhole	1200																																																																																																																																																																																																																																																							
43.000	o	150	S170	5.630	4.300	1.180	Open Manhole	1200																																																																																																																																																																																																																																																							
43.001	o	150	S171	5.369	4.040	1.179	Open Manhole	1200																																																																																																																																																																																																																																																							
41.002	o	225	S172	5.276	3.913	1.138	Open Manhole	1200																																																																																																																																																																																																																																																							
41.003	o	225	S173	5.122	3.855	1.042	Open Manhole	1200																																																																																																																																																																																																																																																							
PN	Length (m)	Slope (1:X)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)																																																																																																																																																																																																																																																							
40.000	6.955	115.9	S162	5.397	3.960	1.212	Open Manhole	1200																																																																																																																																																																																																																																																							
19.023	4.513	282.1	S163	5.400	3.869	1.231	Open Manhole	1200																																																																																																																																																																																																																																																							
19.024	8.201	241.2	S164	5.420	3.835	1.285	Open Manhole	1200																																																																																																																																																																																																																																																							
1.022	17.390	0.0	S165	5.200	3.835	1.065	Open Manhole	1200																																																																																																																																																																																																																																																							
1.023	48.402	0.0	S166	5.200	3.835	1.065	Open Manhole	1200																																																																																																																																																																																																																																																							
1.024	38.318	333.2	S176	4.950	3.720	0.930	Open Manhole	1200																																																																																																																																																																																																																																																							
41.000	11.954	99.6	S169	5.505	4.160	1.195	Open Manhole	1200																																																																																																																																																																																																																																																							
42.000	7.349	13.1	S169	5.505	4.160	1.195	Open Manhole	1200																																																																																																																																																																																																																																																							
41.001	22.295	129.6	S172	5.276	3.988	1.138	Open Manhole	1200																																																																																																																																																																																																																																																							
43.000	6.317	24.3	S171	5.369	4.040	1.179	Open Manhole	1200																																																																																																																																																																																																																																																							
43.001	6.785	130.5	S172	5.276	3.988	1.138	Open Manhole	1200																																																																																																																																																																																																																																																							
41.002	11.709	201.9	S173	5.122	3.855	1.042	Open Manhole	1200																																																																																																																																																																																																																																																							
41.003	27.011	200.1	S175	5.050	3.720	1.105	Open Manhole	1200																																																																																																																																																																																																																																																							
©1982-2018 Innovyze																																																																																																																																																																																																																																																															

RSK LDE		Page 41																																																																																																																																																																																																																																																																																																																			
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT		Drove Lane, Yapton Surface Water Network Calculations - FEH Data																																																																																																																																																																																																																																																																																																																			
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...		Designed by AMuthusami Checked by																																																																																																																																																																																																																																																																																																																			
XP Solutions		Network 2018.1.1																																																																																																																																																																																																																																																																																																																			
PIPELINE SCHEDULES for Surface Network 1 Upstream Manhole <table><thead><tr><th>PN</th><th>Hyd Sect</th><th>Diam (mm)</th><th>MH Name</th><th>C.Level (m)</th><th>I.Level (m)</th><th>D.Depth (m)</th><th>MH Connection</th><th>MH DIAM., L*W (mm)</th></tr></thead><tbody><tr><td>44.000</td><td>o</td><td>150</td><td>S174</td><td>5.170</td><td>3.845</td><td>1.175</td><td>Open Manhole</td><td>1200</td></tr><tr><td>41.004</td><td>o</td><td>225</td><td>S175</td><td>5.050</td><td>3.720</td><td>1.105</td><td>Open Manhole</td><td>1200</td></tr><tr><td>1.025</td><td>o</td><td>300</td><td>S176</td><td>4.950</td><td>3.720</td><td>0.930</td><td>Open Manhole</td><td>1200</td></tr><tr><td>1.026</td><td>o</td><td>300</td><td>S177</td><td>4.450</td><td>3.700</td><td>0.450</td><td>Open Manhole</td><td>1200</td></tr><tr><td>45.000</td><td>o</td><td>150</td><td>S178</td><td>6.900</td><td>6.150</td><td>0.600</td><td>Open Manhole</td><td>1200</td></tr><tr><td>45.001</td><td>o</td><td>150</td><td>S179</td><td>6.900</td><td>5.900</td><td>0.850</td><td>Open Manhole</td><td>1200</td></tr><tr><td>45.002</td><td>o</td><td>150</td><td>S180</td><td>6.750</td><td>5.764</td><td>0.836</td><td>Open Manhole</td><td>1200</td></tr><tr><td>45.003</td><td>o</td><td>150</td><td>S181</td><td>6.530</td><td>5.659</td><td>0.721</td><td>Open Manhole</td><td>1200</td></tr><tr><td>45.004</td><td>o</td><td>150</td><td>S182</td><td>6.780</td><td>5.510</td><td>1.120</td><td>Open Manhole</td><td>1200</td></tr><tr><td>46.000</td><td>o</td><td>150</td><td>S183</td><td>6.739</td><td>5.453</td><td>1.136</td><td>Open Manhole</td><td>1200</td></tr><tr><td>45.005</td><td>o</td><td>225</td><td>S184</td><td>6.863</td><td>5.280</td><td>1.358</td><td>Open Manhole</td><td>1200</td></tr><tr><td>45.006</td><td>o</td><td>225</td><td>S185</td><td>6.728</td><td>5.160</td><td>1.343</td><td>Open Manhole</td><td>1200</td></tr><tr><td>45.007</td><td>o</td><td>225</td><td>S186</td><td>6.550</td><td>4.960</td><td>1.365</td><td>Open Manhole</td><td>1200</td></tr><tr><td>45.008</td><td>o</td><td>225</td><td>S187</td><td>6.300</td><td>4.880</td><td>1.195</td><td>Open Manhole</td><td>1200</td></tr><tr><td>45.009</td><td>o</td><td>300</td><td>S188</td><td>6.750</td><td>4.850</td><td>1.600</td><td>Open Manhole</td><td>1200</td></tr><tr><td>45.010</td><td>o</td><td>300</td><td>S189</td><td>6.750</td><td>4.820</td><td>1.630</td><td>Open Manhole</td><td>1200</td></tr></tbody></table> Downstream Manhole <table><thead><tr><th>PN</th><th>Length (m)</th><th>Slope (1:X)</th><th>MH Name</th><th>C.Level (m)</th><th>I.Level (m)</th><th>D.Depth (m)</th><th>MH Connection</th><th>MH DIAM., L*W (mm)</th></tr></thead><tbody><tr><td>44.000</td><td>6.461</td><td>129.2</td><td>S175</td><td>5.050</td><td>3.795</td><td>1.105</td><td>Open Manhole</td><td>1200</td></tr><tr><td>41.004</td><td>6.311</td><td>0.0</td><td>S176</td><td>4.950</td><td>3.720</td><td>1.005</td><td>Open Manhole</td><td>1200</td></tr><tr><td>1.025</td><td>20.213</td><td>1010.7</td><td>S177</td><td>4.450</td><td>3.700</td><td>0.450</td><td>Open Manhole</td><td>1200</td></tr><tr><td>1.026</td><td>20.756</td><td>0.0</td><td>S250</td><td>4.450</td><td>3.700</td><td>0.450</td><td>Open Manhole</td><td>1200</td></tr><tr><td>45.000</td><td>15.268</td><td>61.1</td><td>S179</td><td>6.900</td><td>5.900</td><td>0.850</td><td>Open Manhole</td><td>1200</td></tr><tr><td>45.001</td><td>17.732</td><td>130.4</td><td>S180</td><td>6.750</td><td>5.764</td><td>0.836</td><td>Open Manhole</td><td>1200</td></tr><tr><td>45.002</td><td>13.608</td><td>129.6</td><td>S181</td><td>6.530</td><td>5.659</td><td>0.721</td><td>Open Manhole</td><td>1200</td></tr><tr><td>45.003</td><td>19.402</td><td>130.2</td><td>S182</td><td>6.780</td><td>5.510</td><td>1.120</td><td>Open Manhole</td><td>1200</td></tr><tr><td>45.004</td><td>6.955</td><td>44.9</td><td>S184</td><td>6.863</td><td>5.355</td><td>1.358</td><td>Open Manhole</td><td>1200</td></tr><tr><td>46.000</td><td>12.734</td><td>129.9</td><td>S184</td><td>6.863</td><td>5.355</td><td>1.358</td><td>Open Manhole</td><td>1200</td></tr><tr><td>45.005</td><td>14.384</td><td>119.9</td><td>S185</td><td>6.728</td><td>5.160</td><td>1.343</td><td>Open Manhole</td><td>1200</td></tr><tr><td>45.006</td><td>24.977</td><td>124.9</td><td>S186</td><td>6.550</td><td>4.960</td><td>1.365</td><td>Open Manhole</td><td>1200</td></tr><tr><td>45.007</td><td>8.469</td><td>105.9</td><td>S187</td><td>6.300</td><td>4.880</td><td>1.195</td><td>Open Manhole</td><td>1200</td></tr><tr><td>45.008</td><td>6.810</td><td>227.0</td><td>S188</td><td>6.750</td><td>4.850</td><td>1.675</td><td>Open Manhole</td><td>1200</td></tr><tr><td>45.009</td><td>9.471</td><td>315.7</td><td>S189</td><td>6.750</td><td>4.820</td><td>1.630</td><td>Open Manhole</td><td>1200</td></tr><tr><td>45.010</td><td>11.295</td><td>282.4</td><td>S190</td><td>6.300</td><td>4.780</td><td>1.220</td><td>Open Manhole</td><td>1200</td></tr></tbody></table>				PN	Hyd Sect	Diam (mm)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)	44.000	o	150	S174	5.170	3.845	1.175	Open Manhole	1200	41.004	o	225	S175	5.050	3.720	1.105	Open Manhole	1200	1.025	o	300	S176	4.950	3.720	0.930	Open Manhole	1200	1.026	o	300	S177	4.450	3.700	0.450	Open Manhole	1200	45.000	o	150	S178	6.900	6.150	0.600	Open Manhole	1200	45.001	o	150	S179	6.900	5.900	0.850	Open Manhole	1200	45.002	o	150	S180	6.750	5.764	0.836	Open Manhole	1200	45.003	o	150	S181	6.530	5.659	0.721	Open Manhole	1200	45.004	o	150	S182	6.780	5.510	1.120	Open Manhole	1200	46.000	o	150	S183	6.739	5.453	1.136	Open Manhole	1200	45.005	o	225	S184	6.863	5.280	1.358	Open Manhole	1200	45.006	o	225	S185	6.728	5.160	1.343	Open Manhole	1200	45.007	o	225	S186	6.550	4.960	1.365	Open Manhole	1200	45.008	o	225	S187	6.300	4.880	1.195	Open Manhole	1200	45.009	o	300	S188	6.750	4.850	1.600	Open Manhole	1200	45.010	o	300	S189	6.750	4.820	1.630	Open Manhole	1200	PN	Length (m)	Slope (1:X)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)	44.000	6.461	129.2	S175	5.050	3.795	1.105	Open Manhole	1200	41.004	6.311	0.0	S176	4.950	3.720	1.005	Open Manhole	1200	1.025	20.213	1010.7	S177	4.450	3.700	0.450	Open Manhole	1200	1.026	20.756	0.0	S250	4.450	3.700	0.450	Open Manhole	1200	45.000	15.268	61.1	S179	6.900	5.900	0.850	Open Manhole	1200	45.001	17.732	130.4	S180	6.750	5.764	0.836	Open Manhole	1200	45.002	13.608	129.6	S181	6.530	5.659	0.721	Open Manhole	1200	45.003	19.402	130.2	S182	6.780	5.510	1.120	Open Manhole	1200	45.004	6.955	44.9	S184	6.863	5.355	1.358	Open Manhole	1200	46.000	12.734	129.9	S184	6.863	5.355	1.358	Open Manhole	1200	45.005	14.384	119.9	S185	6.728	5.160	1.343	Open Manhole	1200	45.006	24.977	124.9	S186	6.550	4.960	1.365	Open Manhole	1200	45.007	8.469	105.9	S187	6.300	4.880	1.195	Open Manhole	1200	45.008	6.810	227.0	S188	6.750	4.850	1.675	Open Manhole	1200	45.009	9.471	315.7	S189	6.750	4.820	1.630	Open Manhole	1200	45.010	11.295	282.4	S190	6.300	4.780	1.220	Open Manhole	1200
PN	Hyd Sect	Diam (mm)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)																																																																																																																																																																																																																																																																																																													
44.000	o	150	S174	5.170	3.845	1.175	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
41.004	o	225	S175	5.050	3.720	1.105	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
1.025	o	300	S176	4.950	3.720	0.930	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
1.026	o	300	S177	4.450	3.700	0.450	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
45.000	o	150	S178	6.900	6.150	0.600	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
45.001	o	150	S179	6.900	5.900	0.850	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
45.002	o	150	S180	6.750	5.764	0.836	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
45.003	o	150	S181	6.530	5.659	0.721	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
45.004	o	150	S182	6.780	5.510	1.120	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
46.000	o	150	S183	6.739	5.453	1.136	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
45.005	o	225	S184	6.863	5.280	1.358	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
45.006	o	225	S185	6.728	5.160	1.343	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
45.007	o	225	S186	6.550	4.960	1.365	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
45.008	o	225	S187	6.300	4.880	1.195	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
45.009	o	300	S188	6.750	4.850	1.600	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
45.010	o	300	S189	6.750	4.820	1.630	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
PN	Length (m)	Slope (1:X)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)																																																																																																																																																																																																																																																																																																													
44.000	6.461	129.2	S175	5.050	3.795	1.105	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
41.004	6.311	0.0	S176	4.950	3.720	1.005	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
1.025	20.213	1010.7	S177	4.450	3.700	0.450	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
1.026	20.756	0.0	S250	4.450	3.700	0.450	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
45.000	15.268	61.1	S179	6.900	5.900	0.850	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
45.001	17.732	130.4	S180	6.750	5.764	0.836	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
45.002	13.608	129.6	S181	6.530	5.659	0.721	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
45.003	19.402	130.2	S182	6.780	5.510	1.120	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
45.004	6.955	44.9	S184	6.863	5.355	1.358	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
46.000	12.734	129.9	S184	6.863	5.355	1.358	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
45.005	14.384	119.9	S185	6.728	5.160	1.343	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
45.006	24.977	124.9	S186	6.550	4.960	1.365	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
45.007	8.469	105.9	S187	6.300	4.880	1.195	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
45.008	6.810	227.0	S188	6.750	4.850	1.675	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
45.009	9.471	315.7	S189	6.750	4.820	1.630	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
45.010	11.295	282.4	S190	6.300	4.780	1.220	Open Manhole	1200																																																																																																																																																																																																																																																																																																													
©1982-2018 Innovyze																																																																																																																																																																																																																																																																																																																					

RSK LDE		Page 42						
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT		Drove Lane, Yapton Surface Water Network Calculations - FEH Data						
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...		Designed by AMuthusami Checked by						
XP Solutions		Network 2018.1.1						
PIPELINE SCHEDULES for Surface Network 1								
Upstream Manhole								
PN	Hyd Sect	Diam (mm)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
45.011	o	300	S190	6.300	4.780	1.220	Open Manhole	1200
47.000	o	150	S191	6.370	5.560	0.660	Open Manhole	1200
47.001	o	150	S192	6.200	5.400	0.650	Open Manhole	1200
45.012	o	300	S193	6.200	4.750	1.150	Open Manhole	1200
45.013	o	300	S194	6.150	4.630	1.220	Open Manhole	1200
48.000	o	150	S195	6.614	5.400	1.064	Open Manhole	1200
49.000	o	150	S196	6.700	5.700	0.850	Open Manhole	1200
48.001	o	150	S197	6.385	5.010	1.225	Open Manhole	1200
48.002	o	150	S198	6.129	4.820	1.159	Open Manhole	1200
48.003	o	150	S199	5.992	4.650	1.192	Open Manhole	1200
48.004	o	150	S200	5.950	4.590	1.210	Open Manhole	1200
45.014	o	300	S201	5.950	4.500	1.150	Open Manhole	1200
50.000	o	150	S202	6.180	5.200	0.830	Open Manhole	1200
50.001	o	150	S203	6.000	4.950	0.900	Open Manhole	1200
Downstream Manhole								
PN	Length (m)	Slope (1:X)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
45.011	11.386	379.5	S193	6.200	4.750	1.150	Open Manhole	1200
47.000	11.315	70.7	S192	6.200	5.400	0.650	Open Manhole	1200
47.001	3.838	9.6	S193	6.200	5.000	1.050	Open Manhole	1200
45.012	18.379	153.2	S194	6.150	4.630	1.220	Open Manhole	1200
45.013	18.447	141.9	S201	5.950	4.500	1.150	Open Manhole	1200
48.000	14.874	38.1	S197	6.385	5.010	1.225	Open Manhole	1200
49.000	7.319	10.6	S197	6.385	5.010	1.225	Open Manhole	1200
48.001	14.874	78.3	S198	6.129	4.820	1.159	Open Manhole	1200
48.002	12.797	75.3	S199	5.992	4.650	1.192	Open Manhole	1200
48.003	7.578	126.3	S200	5.950	4.590	1.210	Open Manhole	1200
48.004	4.811	53.5	S201	5.950	4.500	1.300	Open Manhole	1200
45.014	23.863	477.3	S206	5.500	4.450	0.750	Open Manhole	1200
50.000	14.888	59.6	S203	6.000	4.950	0.900	Open Manhole	1200
50.001	12.946	86.3	S204	5.850	4.800	0.900	Open Manhole	1200
©1982-2018 Innovyze								

RSK LDE		Page 43						
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT		Drove Lane, Yapton Surface Water Network Calculations - FEH Data						
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...		Designed by AMuthusami Checked by						
XP Solutions		Network 2018.1.1						
PIPELINE SCHEDULES for Surface Network 1								
Upstream Manhole								
PN	Hyd Sect	Diam (mm)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
50.002	o	150	S204	5.850	4.800	0.900	Open Manhole	1200
50.003	o	150	S205	5.700	4.500	1.050	Open Manhole	1200
45.015	o	300	S206	5.500	4.450	0.750	Open Manhole	1200
51.000	o	150	S207	7.068	5.650	1.268	Open Manhole	1200
52.000	o	150	S208a	7.225	5.875	1.200	Open Manhole	1050
51.001	o	150	S208	7.026	5.560	1.316	Open Manhole	1200
51.002	o	225	S209	6.950	5.435	1.290	Open Manhole	1200
51.003	o	225	S210	6.919	5.400	1.294	Open Manhole	1200
53.000	o	150	S211	7.000	6.020	0.830	Open Manhole	1200
51.004	o	225	S212	6.749	5.280	1.244	Open Manhole	1200
54.000	o	150	S213	6.709	5.330	1.229	Open Manhole	1200
51.005	o	300	S214	6.538	5.070	1.168	Open Manhole	1200
Downstream Manhole								
PN	Length (m)	Slope (1:X)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
50.002	8.198	27.3	S205	5.700	4.500	1.050	Open Manhole	1200
50.003	6.381	127.6	S206	5.500	4.450	0.900	Open Manhole	1200
45.015	22.453	60.7	S222	5.500	4.080	1.120	Open Manhole	1200
51.000	11.028	122.5	S208	7.026	5.560	1.316	Open Manhole	1200
52.000	25.533	81.1	S208	7.026	5.560	1.316	Open Manhole	1200
51.001	8.644	172.9	S209	6.950	5.510	1.290	Open Manhole	1200
51.002	5.990	171.1	S210	6.919	5.400	1.294	Open Manhole	1200
51.003	20.542	171.2	S212	6.749	5.280	1.244	Open Manhole	1200
53.000	6.398	9.6	S212	6.749	5.355	1.244	Open Manhole	1200
51.004	25.121	186.1	S214	6.538	5.145	1.168	Open Manhole	1200
54.000	7.911	71.9	S214	6.538	5.220	1.168	Open Manhole	1200
51.005	14.419	120.2	S216	6.425	4.950	1.175	Open Manhole	1200
©1982-2018 Innovyze								

RSK LDE		Page 44						
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT		Drove Lane, Yapton Surface Water Network Calculations - FEH Data						
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...		Designed by AMuthusami Checked by						
XP Solutions		Network 2018.1.1						
PIPELINE SCHEDULES for Surface Network 1								
Upstream Manhole								
PN	Hyd Sect	Diam (mm)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
55.000	o	150	S215	6.680	5.230	1.300	Open Manhole	1200
51.006	o	300	S216	6.425	4.950	1.175	Open Manhole	1200
56.000	o	150	S217	5.979	4.700	1.129	Open Manhole	1200
51.007	o	300	S218	5.997	4.510	1.187	Open Manhole	1200
51.008	o	300	S219	5.767	4.260	1.207	Open Manhole	1200
51.009	o	300	S220	5.666	4.200	1.166	Open Manhole	1200
51.010	o	300	S221	5.500	4.100	1.100	Open Manhole	1200
45.016	o	300	S222	5.500	4.080	1.120	Open Manhole	1200
57.000	o	300	S223	5.636	4.140	1.196	Open Manhole	1200
57.001	o	300	S224	5.600	4.100	1.200	Open Manhole	1200
45.017	o	300	S225	5.500	4.080	1.120	Open Manhole	1200
58.000	o	150	S226	5.930	5.180	0.600	Open Manhole	1200
58.001	o	150	S227	5.400	4.650	0.600	Open Manhole	1200
58.002	o	150	S228	5.400	4.550	0.700	Open Manhole	1200
Downstream Manhole								
PN	Length (m)	Slope (1:X)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
55.000	5.913	45.5	S216	6.425	5.100	1.175	Open Manhole	1200
51.006	35.195	80.0	S218	5.997	4.510	1.187	Open Manhole	1200
56.000	4.517	112.9	S218	5.997	4.660	1.187	Open Manhole	1200
51.007	23.594	94.4	S219	5.767	4.260	1.207	Open Manhole	1200
51.008	9.979	166.3	S220	5.666	4.200	1.166	Open Manhole	1200
51.009	5.909	59.1	S221	5.500	4.100	1.100	Open Manhole	1200
51.010	4.450	222.5	S222	5.500	4.080	1.120	Open Manhole	1200
45.016	22.062	0.0	S225	5.500	4.080	1.120	Open Manhole	1200
57.000	6.067	151.7	S224	5.600	4.100	1.200	Open Manhole	1200
57.001	4.644	232.2	S225	5.500	4.080	1.120	Open Manhole	1200
45.017	25.461	1273.0	S230	5.250	4.060	0.890	Open Manhole	1200
58.000	19.027	35.9	S227	5.400	4.650	0.600	Open Manhole	1200
58.001	10.816	108.2	S228	5.400	4.550	0.700	Open Manhole	1200
58.002	9.026	69.4	S229	5.300	4.420	0.730	Open Manhole	1200
©1982-2018 Innovyze								

RSK LDE		Page 45						
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT		Drove Lane, Yapton Surface Water Network Calculations - FEH Data						
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...		Designed by AMuthusami Checked by						
XP Solutions		Network 2018.1.1						
PIPELINE SCHEDULES for Surface Network 1								
Upstream Manhole								
PN	Hyd Sect	Diam (mm)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
58.003	o	150	S229	5.300	4.350	0.800	Open Manhole	1200
45.018	o	300	S230	5.250	4.060	0.890	Open Manhole	1200
45.019	o	300	S231	5.200	4.040	0.860	Open Manhole	1200
45.020	o	300	S232	5.150	3.950	0.900	Open Manhole	1200
45.021	o	300	S233	5.150	3.900	0.950	Open Manhole	1200
59.000	o	150	S234	6.235	4.860	1.225	Open Manhole	1200
59.001	o	150	S235	6.050	4.670	1.230	Open Manhole	1200
60.000	o	150	S236	6.180	5.070	0.960	Open Manhole	1200
59.002	o	150	S237	5.966	4.580	1.236	Open Manhole	1200
61.000	o	150	S238	6.200	5.315	0.735	Open Manhole	1200
61.001	o	150	S239	5.952	4.600	1.202	Open Manhole	1200
59.003	o	300	S240	5.803	4.150	1.353	Open Manhole	1200
59.004	o	300	S241	5.694	4.070	1.324	Open Manhole	1200
62.000	o	150	S242	5.500	4.400	0.950	Open Manhole	600
Downstream Manhole								
PN	Length (m)	Slope (1:X)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
58.003	2.619	65.5	S230	5.250	4.310	0.790	Open Manhole	1200
45.018	5.411	270.6	S231	5.200	4.040	0.860	Open Manhole	1200
45.019	22.710	252.3	S232	5.150	3.950	0.900	Open Manhole	1200
45.020	10.353	207.1	S233	5.150	3.900	0.950	Open Manhole	1200
45.021	12.519	83.5	S246	5.000	3.750	0.950	Open Manhole	1200
59.000	22.046	116.0	S235	6.050	4.670	1.230	Open Manhole	1200
59.001	9.725	108.1	S237	5.966	4.580	1.236	Open Manhole	1200
60.000	6.462	13.2	S237	5.966	4.580	1.236	Open Manhole	1200
59.002	19.638	70.1	S240	5.803	4.300	1.353	Open Manhole	1200
61.000	7.982	11.2	S239	5.952	4.600	1.202	Open Manhole	1200
61.001	10.368	34.6	S240	5.803	4.300	1.353	Open Manhole	1200
59.003	12.789	159.9	S241	5.694	4.070	1.324	Open Manhole	1200
59.004	47.729	190.9	S243	5.279	3.820	1.159	Open Manhole	1200
62.000	4.985	11.6	S243	5.279	3.970	1.159	Open Manhole	1200
©1982-2018 Innovyze								

RSK LDE		Page 46
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT		
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...		
XP Solutions		
Drove Lane, Yapton Surface Water Network Calculations - FEH Data		
Designed by AMuthusami Checked by		
Network 2018.1.1		

PIPELINE SCHEDULES for Surface Network 1

Upstream Manhole

PN	Hyd Sect	Diam (mm)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
59.005	o	300	S243	5.279	3.820	1.159	Open Manhole	1200
59.006	o	300	S244	5.172	3.770	1.102	Open Manhole	1200
59.007	o	300	S245	5.100	3.750	1.050	Open Manhole	1200
45.022	o	300	S246	5.000	3.750	0.950	Open Manhole	1200
63.000	o	150	S247	5.250	4.345	0.755	Open Manhole	1200
63.001	o	150	S248	5.100	4.250	0.700	Open Manhole	1200
45.023	o	300	S249	4.500	3.750	0.450	Open Manhole	1200
1.027	o	300	S250	4.450	3.700	0.450	Open Manhole	1200
1.028	o	300	S251	4.450	3.650	0.500	Open Manhole	1800

Downstream Manhole

PN	Length (m)	Slope (1:X)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
59.005	12.346	246.9	S244	5.172	3.770	1.102	Open Manhole	1200
59.006	5.698	284.9	S245	5.100	3.750	1.050	Open Manhole	1200
59.007	3.876	0.0	S246	5.000	3.750	0.950	Open Manhole	1200
45.022	32.579	0.0	S249	4.500	3.750	0.450	Open Manhole	1200
63.000	11.089	116.7	S248	5.100	4.250	0.700	Open Manhole	1200
63.001	22.582	64.5	S249	4.500	3.900	0.450	Open Manhole	1200
45.023	9.002	180.0	S250	4.450	3.700	0.450	Open Manhole	1200
1.027	9.559	191.2	S251	4.450	3.650	0.500	Open Manhole	1800
1.028	4.451	89.0	S252	4.450	3.600	0.550	Open Manhole	1200


Surcharged Outfall Details for Surface Network 1

Outfall Pipe Number	Outfall Name	C. Level (m)	I. Level (m)	Min I. Level (m)	D,L (mm)	W (mm)
1.028	S252	4.450	3.600	0.000	1200	0

Datum (m) 0.000 Offset (mins) 0

©1982-2018 Innovyze

RSK LDE				Page 47							
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT				Drove Lane, Yapton Surface Water Network Calculations - FEH Data							
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...				Designed by AMuthusami Checked by							
XP Solutions				Network 2018.1.1							
<u>Surcharged Outfall Details for Surface Network 1</u>											
Time (mins)	Depth (m)	Time (mins)	Depth (m)	Time (mins)	Depth (m)	Time (mins)	Depth (m)	Time (mins)	Depth (m)	Time (mins)	Depth (m)
100	4.000	3500	4.000	6900	4.000	10300	4.000	13700	4.000	17100	4.000
200	4.000	3600	4.000	7000	4.000	10400	4.000	13800	4.000	17200	4.000
300	4.000	3700	4.000	7100	4.000	10500	4.000	13900	4.000	17300	4.000
400	4.000	3800	4.000	7200	4.000	10600	4.000	14000	4.000	17400	4.000
500	4.000	3900	4.000	7300	4.000	10700	4.000	14100	4.000	17500	4.000
600	4.000	4000	4.000	7400	4.000	10800	4.000	14200	4.000	17600	4.000
700	4.000	4100	4.000	7500	4.000	10900	4.000	14300	4.000	17700	4.000
800	4.000	4200	4.000	7600	4.000	11000	4.000	14400	4.000	17800	4.000
900	4.000	4300	4.000	7700	4.000	11100	4.000	14500	4.000	17900	4.000
1000	4.000	4400	4.000	7800	4.000	11200	4.000	14600	4.000	18000	4.000
1100	4.000	4500	4.000	7900	4.000	11300	4.000	14700	4.000	18100	4.000
1200	4.000	4600	4.000	8000	4.000	11400	4.000	14800	4.000	18200	4.000
1300	4.000	4700	4.000	8100	4.000	11500	4.000	14900	4.000	18300	4.000
1400	4.000	4800	4.000	8200	4.000	11600	4.000	15000	4.000	18400	4.000
1500	4.000	4900	4.000	8300	4.000	11700	4.000	15100	4.000	18500	4.000
1600	4.000	5000	4.000	8400	4.000	11800	4.000	15200	4.000	18600	4.000
1700	4.000	5100	4.000	8500	4.000	11900	4.000	15300	4.000	18700	4.000
1800	4.000	5200	4.000	8600	4.000	12000	4.000	15400	4.000	18800	4.000
1900	4.000	5300	4.000	8700	4.000	12100	4.000	15500	4.000	18900	4.000
2000	4.000	5400	4.000	8800	4.000	12200	4.000	15600	4.000	19000	4.000
2100	4.000	5500	4.000	8900	4.000	12300	4.000	15700	4.000	19100	4.000
2200	4.000	5600	4.000	9000	4.000	12400	4.000	15800	4.000	19200	4.000
2300	4.000	5700	4.000	9100	4.000	12500	4.000	15900	4.000	19300	4.000
2400	4.000	5800	4.000	9200	4.000	12600	4.000	16000	4.000	19400	4.000
2500	4.000	5900	4.000	9300	4.000	12700	4.000	16100	4.000	19500	4.000
2600	4.000	6000	4.000	9400	4.000	12800	4.000	16200	4.000	19600	4.000
2700	4.000	6100	4.000	9500	4.000	12900	4.000	16300	4.000	19700	4.000
2800	4.000	6200	4.000	9600	4.000	13000	4.000	16400	4.000	19800	4.000
2900	4.000	6300	4.000	9700	4.000	13100	4.000	16500	4.000	19900	4.000
3000	4.000	6400	4.000	9800	4.000	13200	4.000	16600	4.000	20000	4.000
3100	4.000	6500	4.000	9900	4.000	13300	4.000	16700	4.000		
3200	4.000	6600	4.000	10000	4.000	13400	4.000	16800	4.000		
3300	4.000	6700	4.000	10100	4.000	13500	4.000	16900	4.000		
3400	4.000	6800	4.000	10200	4.000	13600	4.000	17000	4.000		
©1982-2018 Innovyze											



RSK LDE		Page 48
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions Network 2018.1.1		

Online Controls for Surface Network 1

Hydro-Brake® Optimum Manhole: S22, DS/PN: 5.002, Volume (m³): 2.1

Unit Reference	MD-SHE-0045-1000-1200-1000
Design Head (m)	1.200
Design Flow (l/s)	1.0
Flush-Flo™	Calculated
Objective	Minimise upstream storage
Application	Surface
Sump Available	Yes
Diameter (mm)	45
Invert Level (m)	5.620
Minimum Outlet Pipe Diameter (mm)	75
Suggested Manhole Diameter (mm)	1200

Control Points	Head (m)	Flow (l/s)
Design Point (Calculated)	1.200	1.0
Flush-Flo™	0.196	0.7
Kick-Flo®	0.398	0.6
Mean Flow over Head Range	-	0.8

The hydrological calculations have been based on the Head/Discharge relationship for the Hydro-Brake® Optimum as specified. Should another type of control device other than a Hydro-Brake Optimum® be utilised then these storage routing calculations will be invalidated

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.100	0.7	1.200	1.0	3.000	1.5	7.000	2.2
0.200	0.7	1.400	1.1	3.500	1.6	7.500	2.3
0.300	0.7	1.600	1.1	4.000	1.7	8.000	2.4
0.400	0.6	1.800	1.2	4.500	1.8	8.500	2.4
0.500	0.7	2.000	1.3	5.000	1.9	9.000	2.5
0.600	0.7	2.200	1.3	5.500	2.0	9.500	2.6
0.800	0.8	2.400	1.4	6.000	2.1		
1.000	0.9	2.600	1.4	6.500	2.2		

Hydro-Brake® Optimum Manhole: S32, DS/PN: 1.006, Volume (m³): 5.4

Unit Reference	MD-SHE-0103-5000-1200-5000
Design Head (m)	1.200
Design Flow (l/s)	5.0
Flush-Flo™	Calculated
Objective	Minimise upstream storage
Application	Surface
Sump Available	Yes
Diameter (mm)	103
Invert Level (m)	5.150
Minimum Outlet Pipe Diameter (mm)	150
Suggested Manhole Diameter (mm)	1200

©1982-2018 Innovyze

RSK LDE

Page 49

18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions	Network 2018.1.1	

Hydro-Brake® Optimum Manhole: S32, DS/PN: 1.006, Volume (m³): 5.4

Control Points	Head (m)	Flow (l/s)
Design Point (Calculated)	1.200	5.0
Flush-Flo™	0.354	5.0
Kick-Flo®	0.745	4.0
Mean Flow over Head Range	-	4.4

The hydrological calculations have been based on the Head/Discharge relationship for the Hydro-Brake® Optimum as specified. Should another type of control device other than a Hydro-Brake Optimum® be utilised then these storage routing calculations will be invalidated

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.100	3.4	1.200	5.0	3.000	7.7	7.000	11.5
0.200	4.7	1.400	5.4	3.500	8.3	7.500	11.8
0.300	5.0	1.600	5.7	4.000	8.8	8.000	12.2
0.400	5.0	1.800	6.0	4.500	9.3	8.500	12.6
0.500	4.9	2.000	6.3	5.000	9.8	9.000	12.9
0.600	4.7	2.200	6.6	5.500	10.2	9.500	13.3
0.800	4.1	2.400	6.9	6.000	10.7		
1.000	4.6	2.600	7.2	6.500	11.1		

Orifice Manhole: S38, DS/PN: 1.009, Volume (m³): 1.5

Diameter (m) 0.077 Discharge Coefficient 0.600 Invert Level (m) 5.120

Hydro-Brake® Optimum Manhole: S48, DS/PN: 1.011, Volume (m³): 2.2

Unit Reference	MD-SHE-0136-9000-1200-9000
Design Head (m)	1.200
Design Flow (l/s)	9.0
Flush-Flo™	Calculated
Objective	Minimise upstream storage
Application	Surface
Sump Available	Yes
Diameter (mm)	136
Invert Level (m)	4.850
Minimum Outlet Pipe Diameter (mm)	150
Suggested Manhole Diameter (mm)	1200

Control Points	Head (m)	Flow (l/s)
Design Point (Calculated)	1.200	9.0
Flush-Flo™	0.354	9.0
Kick-Flo®	0.769	7.3
Mean Flow over Head Range	-	7.8

The hydrological calculations have been based on the Head/Discharge relationship for the Hydro-Brake® Optimum as specified. Should another type of control device other than a Hydro-Brake Optimum® be utilised then these storage routing calculations will be invalidated

©1982-2018 Innovyze

RSK LDE		Page 50													
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data														
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by														
XP Solutions Network 2018.1.1															
<u>Hydro-Brake® Optimum Manhole: S48, DS/PN: 1.011, Volume (m³): 2.2</u>															
Depth (m) Flow (l/s)	Depth (m) Flow (l/s)	Depth (m) Flow (l/s)	Depth (m) Flow (l/s)												
0.100 4.9	1.200 9.0	3.000 13.9	7.000 20.8												
0.200 8.5	1.400 9.7	3.500 14.9	7.500 21.5												
0.300 8.9	1.600 10.3	4.000 15.9	8.000 22.2												
0.400 9.0	1.800 10.9	4.500 16.8	8.500 22.8												
0.500 8.8	2.000 11.4	5.000 17.7	9.000 23.5												
0.600 8.5	2.200 12.0	5.500 18.5	9.500 24.1												
0.800 7.4	2.400 12.5	6.000 19.3													
1.000 8.3	2.600 13.0	6.500 20.1													
<u>Orifice Manhole: S50, DS/PN: 1.013, Volume (m³): 1.9</u>															
Diameter (m) 0.077 Discharge Coefficient 0.600 Invert Level (m) 4.714															
<u>Orifice Manhole: S77, DS/PN: 1.019, Volume (m³): 1.9</u>															
Diameter (m) 0.073 Discharge Coefficient 0.600 Invert Level (m) 4.150															
<u>Orifice Manhole: S88, DS/PN: 19.007, Volume (m³): 2.3</u>															
Diameter (m) 0.053 Discharge Coefficient 0.600 Invert Level (m) 5.030															
<u>Orifice Manhole: S104, DS/PN: 19.010, Volume (m³): 2.3</u>															
Diameter (m) 0.077 Discharge Coefficient 0.600 Invert Level (m) 4.915															
<u>Orifice Manhole: S110, DS/PN: 19.012, Volume (m³): 3.3</u>															
Diameter (m) 0.047 Discharge Coefficient 0.600 Invert Level (m) 4.750															
<u>Hydro-Brake® Optimum Manhole: S127, DS/PN: 19.013, Volume (m³): 4.7</u>															
Unit Reference MD-SHE-0143-1000-1200-1000															
Design Head (m) 1.200															
Design Flow (l/s) 10.0															
Flush-Flo™ Calculated															
Objective Minimise upstream storage															
Application Surface															
Sump Available Yes															
Diameter (mm) 143															
Invert Level (m) 4.640															
Minimum Outlet Pipe Diameter (mm) 225															
Suggested Manhole Diameter (mm) 1200															
<table><tr><td>Control Points</td><td>Head (m)</td><td>Flow (l/s)</td></tr><tr><td>Design Point (Calculated)</td><td>1.200</td><td>10.0</td></tr><tr><td>Flush-Flo™</td><td>0.357</td><td>10.0</td></tr><tr><td>Kick-Flo®</td><td>0.778</td><td>8.2</td></tr></table>				Control Points	Head (m)	Flow (l/s)	Design Point (Calculated)	1.200	10.0	Flush-Flo™	0.357	10.0	Kick-Flo®	0.778	8.2
Control Points	Head (m)	Flow (l/s)													
Design Point (Calculated)	1.200	10.0													
Flush-Flo™	0.357	10.0													
Kick-Flo®	0.778	8.2													
©1982-2018 Innovyze															

RSK LDE		Page 51
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT		
Drove Lane, Yapton Surface Water Network Calculations - FEH Data		
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...		
Designed by AMuthusami Checked by		
XP Solutions		Network 2018.1.1

Hydro-Brake® Optimum Manhole: S127, DS/PN: 19.013, Volume (m³): 4.7

Control Points	Head (m)	Flow (l/s)
Mean Flow over Head Range	-	8.7

The hydrological calculations have been based on the Head/Discharge relationship for the Hydro-Brake® Optimum as specified. Should another type of control device other than a Hydro-Brake Optimum® be utilised then these storage routing calculations will be invalidated

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.100	5.1	1.200	10.0	3.000	15.4	7.000	23.2
0.200	9.4	1.400	10.8	3.500	16.6	7.500	23.9
0.300	9.9	1.600	11.5	4.000	17.7	8.000	24.7
0.400	10.0	1.800	12.1	4.500	18.7	8.500	25.4
0.500	9.8	2.000	12.7	5.000	19.7	9.000	26.1
0.600	9.5	2.200	13.3	5.500	20.6	9.500	26.8
0.800	8.3	2.400	13.9	6.000	21.5		
1.000	9.2	2.600	14.4	6.500	22.3		

Orifice Manhole: S130, DS/PN: 19.014, Volume (m³): 3.4

Diameter (m) 0.092 Discharge Coefficient 0.600 Invert Level (m) 4.600

Hydro-Brake® Optimum Manhole: S136, DS/PN: 19.016, Volume (m³): 4.1

Unit Reference	MD-SHE-0125-7500-1200-7500
Design Head (m)	1.200
Design Flow (l/s)	7.5
Flush-Flo™	Calculated
Objective	Minimise upstream storage
Application	Surface
Sump Available	Yes
Diameter (mm)	125
Invert Level (m)	4.460
Minimum Outlet Pipe Diameter (mm)	150
Suggested Manhole Diameter (mm)	1200

Control Points	Head (m)	Flow (l/s)
Design Point (Calculated)	1.200	7.5
Flush-Flo™	0.356	7.5
Kick-Flo®	0.763	6.1
Mean Flow over Head Range	-	6.5

The hydrological calculations have been based on the Head/Discharge relationship for the Hydro-Brake® Optimum as specified. Should another type of control device other than a Hydro-Brake Optimum® be utilised then these storage routing calculations will be invalidated

©1982-2018 Innovyze

RSK LDE		Page 52																																																																								
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data																																																																									
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by																																																																									
XP Solutions	Network 2018.1.1																																																																									
<u>Hydro-Brake® Optimum Manhole: S136, DS/PN: 19.016, Volume (m³): 4.1</u> <table><tr><th>Depth (m)</th><th>Flow (l/s)</th><th>Depth (m)</th><th>Flow (l/s)</th><th>Depth (m)</th><th>Flow (l/s)</th><th>Depth (m)</th><th>Flow (l/s)</th></tr><tr><td>0.100</td><td>4.5</td><td>1.200</td><td>7.5</td><td>3.000</td><td>11.5</td><td>7.000</td><td>17.3</td></tr><tr><td>0.200</td><td>7.1</td><td>1.400</td><td>8.1</td><td>3.500</td><td>12.4</td><td>7.500</td><td>17.9</td></tr><tr><td>0.300</td><td>7.5</td><td>1.600</td><td>8.6</td><td>4.000</td><td>13.2</td><td>8.000</td><td>18.4</td></tr><tr><td>0.400</td><td>7.5</td><td>1.800</td><td>9.1</td><td>4.500</td><td>14.0</td><td>8.500</td><td>19.0</td></tr><tr><td>0.500</td><td>7.4</td><td>2.000</td><td>9.5</td><td>5.000</td><td>14.7</td><td>9.000</td><td>19.5</td></tr><tr><td>0.600</td><td>7.1</td><td>2.200</td><td>10.0</td><td>5.500</td><td>15.4</td><td>9.500</td><td>20.0</td></tr><tr><td>0.800</td><td>6.2</td><td>2.400</td><td>10.4</td><td>6.000</td><td>16.1</td><td></td><td></td></tr><tr><td>1.000</td><td>6.9</td><td>2.600</td><td>10.8</td><td>6.500</td><td>16.7</td><td></td><td></td></tr></table> <u>Orifice Manhole: S144, DS/PN: 19.018, Volume (m³): 2.8</u> Diameter (m) 0.077 Discharge Coefficient 0.600 Invert Level (m) 4.400 <u>Orifice Manhole: S164, DS/PN: 1.022, Volume (m³): 4.6</u> Diameter (m) 0.096 Discharge Coefficient 0.600 Invert Level (m) 3.835 <u>Orifice Manhole: S166, DS/PN: 1.024, Volume (m³): 4.9</u> Diameter (m) 0.112 Discharge Coefficient 0.600 Invert Level (m) 3.835 <u>Orifice Manhole: S176, DS/PN: 1.025, Volume (m³): 4.2</u> Diameter (m) 0.142 Discharge Coefficient 0.600 Invert Level (m) 3.720 <u>Orifice Manhole: S180, DS/PN: 45.002, Volume (m³): 1.4</u> Diameter (m) 0.053 Discharge Coefficient 0.600 Invert Level (m) 5.764 <u>Orifice Manhole: S189, DS/PN: 45.010, Volume (m³): 2.8</u> Diameter (m) 0.096 Discharge Coefficient 0.600 Invert Level (m) 4.820 <u>Orifice Manhole: S193, DS/PN: 45.012, Volume (m³): 2.4</u> Diameter (m) 0.077 Discharge Coefficient 0.600 Invert Level (m) 4.750 <u>Orifice Manhole: S201, DS/PN: 45.014, Volume (m³): 2.9</u> Diameter (m) 0.077 Discharge Coefficient 0.600 Invert Level (m) 4.500 <u>Orifice Manhole: S225, DS/PN: 45.017, Volume (m³): 3.3</u> Diameter (m) 0.077 Discharge Coefficient 0.600 Invert Level (m) 4.080			Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	0.100	4.5	1.200	7.5	3.000	11.5	7.000	17.3	0.200	7.1	1.400	8.1	3.500	12.4	7.500	17.9	0.300	7.5	1.600	8.6	4.000	13.2	8.000	18.4	0.400	7.5	1.800	9.1	4.500	14.0	8.500	19.0	0.500	7.4	2.000	9.5	5.000	14.7	9.000	19.5	0.600	7.1	2.200	10.0	5.500	15.4	9.500	20.0	0.800	6.2	2.400	10.4	6.000	16.1			1.000	6.9	2.600	10.8	6.500	16.7		
Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)																																																																			
0.100	4.5	1.200	7.5	3.000	11.5	7.000	17.3																																																																			
0.200	7.1	1.400	8.1	3.500	12.4	7.500	17.9																																																																			
0.300	7.5	1.600	8.6	4.000	13.2	8.000	18.4																																																																			
0.400	7.5	1.800	9.1	4.500	14.0	8.500	19.0																																																																			
0.500	7.4	2.000	9.5	5.000	14.7	9.000	19.5																																																																			
0.600	7.1	2.200	10.0	5.500	15.4	9.500	20.0																																																																			
0.800	6.2	2.400	10.4	6.000	16.1																																																																					
1.000	6.9	2.600	10.8	6.500	16.7																																																																					
©1982-2018 Innovyze																																																																										

RSK LDE		Page 53
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions Network 2018.1.1		

Orifice Manhole: S246, DS/PN: 45.022, Volume (m³): 2.4

Diameter (m) 0.106 Discharge Coefficient 0.600 Invert Level (m) 3.750

Hydro-Brake® Optimum Manhole: S251, DS/PN: 1.028, Volume (m³): 2.6

Unit Reference	MD-SHE-0195-1820-0600-1820
Design Head (m)	0.600
Design Flow (l/s)	18.2
Flush-Flo™	Calculated
Objective	Minimise upstream storage
Application	Surface
Sump Available	Yes
Diameter (mm)	195
Invert Level (m)	3.650
Minimum Outlet Pipe Diameter (mm)	225
Suggested Manhole Diameter (mm)	1200

Control Points	Head (m)	Flow (l/s)
Design Point (Calculated)	0.600	18.2
Flush-Flo™	0.289	18.2
Kick-Flo®	0.485	16.5
Mean Flow over Head Range	-	14.3

The hydrological calculations have been based on the Head/Discharge relationship for the Hydro-Brake® Optimum as specified. Should another type of control device other than a Hydro-Brake Optimum® be utilised then these storage routing calculations will be invalidated

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.100	6.8	1.200	25.3	3.000	39.4	7.000	59.1
0.200	17.7	1.400	27.3	3.500	42.4	7.500	61.2
0.300	18.2	1.600	29.1	4.000	45.2	8.000	63.2
0.400	17.7	1.800	30.8	4.500	47.9	8.500	65.2
0.500	16.7	2.000	32.4	5.000	50.4	9.000	67.1
0.600	18.2	2.200	33.9	5.500	52.8	9.500	68.9
0.800	20.9	2.400	35.3	6.000	55.1		
1.000	23.2	2.600	36.7	6.500	56.9		

©1982-2018 Innovyze

RSK LDE		Page 54																																																																																																																				
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data																																																																																																																					
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by																																																																																																																					
XP Solutions Network 2018.1.1																																																																																																																						
<u>Storage Structures for Surface Network 1</u> <u>Trench Soakaway Manhole: S1, DS/PN: 1.000</u> <table><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Trench Width (m)</td><td>1.0</td></tr><tr><td>Infiltration Coefficient Side (m/hr)</td><td>0.00000</td><td>Trench Length (m)</td><td>72.0</td></tr><tr><td>Safety Factor</td><td>2.0</td><td>Slope (1:X)</td><td>200.0</td></tr><tr><td>Porosity</td><td>0.30</td><td>Cap Volume Depth (m)</td><td>6.600</td></tr><tr><td>Invert Level (m)</td><td>5.600</td><td>Cap Infiltration Depth (m)</td><td>6.600</td></tr></table> <u>Porous Car Park Manhole: S6, DS/PN: 2.000</u> <table><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Width (m)</td><td>10.0</td></tr><tr><td>Membrane Percolation (mm/hr)</td><td>1000</td><td>Length (m)</td><td>288.1</td></tr><tr><td>Max Percolation (l/s)</td><td>800.3</td><td>Slope (1:X)</td><td>100.0</td></tr><tr><td>Safety Factor</td><td>2.0</td><td>Depression Storage (mm)</td><td>5</td></tr><tr><td>Porosity</td><td>0.30</td><td>Evaporation (mm/day)</td><td>3</td></tr><tr><td>Invert Level (m)</td><td>6.690</td><td>Cap Volume Depth (m)</td><td>0.400</td></tr></table> <u>Swale Manhole: S12, DS/PN: 1.005</u> Warning:- Volume should always be included unless the upstream pipe is being used for storage and/or as a carrier <table><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Length (m)</td><td>80.0</td></tr><tr><td>Infiltration Coefficient Side (m/hr)</td><td>0.00000</td><td>Side Slope (1:X)</td><td>4.0</td></tr><tr><td>Safety Factor</td><td>2.0</td><td>Slope (1:X)</td><td>200.0</td></tr><tr><td>Porosity</td><td>0.30</td><td>Cap Volume Depth (m)</td><td>1.650</td></tr><tr><td>Invert Level (m)</td><td>5.250</td><td>Cap Infiltration Depth (m)</td><td>0.000</td></tr><tr><td>Base Width (m)</td><td>2.5</td><td>Include Swale Volume</td><td>Yes</td></tr></table> <u>Porous Car Park Manhole: S13, DS/PN: 3.000</u> <table><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Width (m)</td><td>10.0</td></tr><tr><td>Membrane Percolation (mm/hr)</td><td>1000</td><td>Length (m)</td><td>11.1</td></tr><tr><td>Max Percolation (l/s)</td><td>30.8</td><td>Slope (1:X)</td><td>100.0</td></tr><tr><td>Safety Factor</td><td>2.0</td><td>Depression Storage (mm)</td><td>5</td></tr><tr><td>Porosity</td><td>0.30</td><td>Evaporation (mm/day)</td><td>3</td></tr><tr><td>Invert Level (m)</td><td>6.617</td><td>Cap Volume Depth (m)</td><td>0.400</td></tr></table> <u>Swale Manhole: S17, DS/PN: 3.004</u> Warning:- Volume should always be included unless the upstream pipe is being used for storage and/or as a carrier <table><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Length (m)</td><td>23.8</td></tr><tr><td>Infiltration Coefficient Side (m/hr)</td><td>0.00000</td><td>Side Slope (1:X)</td><td>4.0</td></tr><tr><td>Safety Factor</td><td>2.0</td><td>Slope (1:X)</td><td>200.0</td></tr><tr><td>Porosity</td><td>0.30</td><td>Cap Volume Depth (m)</td><td>7.000</td></tr><tr><td>Invert Level (m)</td><td>5.700</td><td>Cap Infiltration Depth (m)</td><td>7.000</td></tr><tr><td>Base Width (m)</td><td>2.4</td><td>Include Swale Volume</td><td>Yes</td></tr></table>			Infiltration Coefficient Base (m/hr)	0.00000	Trench Width (m)	1.0	Infiltration Coefficient Side (m/hr)	0.00000	Trench Length (m)	72.0	Safety Factor	2.0	Slope (1:X)	200.0	Porosity	0.30	Cap Volume Depth (m)	6.600	Invert Level (m)	5.600	Cap Infiltration Depth (m)	6.600	Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0	Membrane Percolation (mm/hr)	1000	Length (m)	288.1	Max Percolation (l/s)	800.3	Slope (1:X)	100.0	Safety Factor	2.0	Depression Storage (mm)	5	Porosity	0.30	Evaporation (mm/day)	3	Invert Level (m)	6.690	Cap Volume Depth (m)	0.400	Infiltration Coefficient Base (m/hr)	0.00000	Length (m)	80.0	Infiltration Coefficient Side (m/hr)	0.00000	Side Slope (1:X)	4.0	Safety Factor	2.0	Slope (1:X)	200.0	Porosity	0.30	Cap Volume Depth (m)	1.650	Invert Level (m)	5.250	Cap Infiltration Depth (m)	0.000	Base Width (m)	2.5	Include Swale Volume	Yes	Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0	Membrane Percolation (mm/hr)	1000	Length (m)	11.1	Max Percolation (l/s)	30.8	Slope (1:X)	100.0	Safety Factor	2.0	Depression Storage (mm)	5	Porosity	0.30	Evaporation (mm/day)	3	Invert Level (m)	6.617	Cap Volume Depth (m)	0.400	Infiltration Coefficient Base (m/hr)	0.00000	Length (m)	23.8	Infiltration Coefficient Side (m/hr)	0.00000	Side Slope (1:X)	4.0	Safety Factor	2.0	Slope (1:X)	200.0	Porosity	0.30	Cap Volume Depth (m)	7.000	Invert Level (m)	5.700	Cap Infiltration Depth (m)	7.000	Base Width (m)	2.4	Include Swale Volume	Yes
Infiltration Coefficient Base (m/hr)	0.00000	Trench Width (m)	1.0																																																																																																																			
Infiltration Coefficient Side (m/hr)	0.00000	Trench Length (m)	72.0																																																																																																																			
Safety Factor	2.0	Slope (1:X)	200.0																																																																																																																			
Porosity	0.30	Cap Volume Depth (m)	6.600																																																																																																																			
Invert Level (m)	5.600	Cap Infiltration Depth (m)	6.600																																																																																																																			
Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0																																																																																																																			
Membrane Percolation (mm/hr)	1000	Length (m)	288.1																																																																																																																			
Max Percolation (l/s)	800.3	Slope (1:X)	100.0																																																																																																																			
Safety Factor	2.0	Depression Storage (mm)	5																																																																																																																			
Porosity	0.30	Evaporation (mm/day)	3																																																																																																																			
Invert Level (m)	6.690	Cap Volume Depth (m)	0.400																																																																																																																			
Infiltration Coefficient Base (m/hr)	0.00000	Length (m)	80.0																																																																																																																			
Infiltration Coefficient Side (m/hr)	0.00000	Side Slope (1:X)	4.0																																																																																																																			
Safety Factor	2.0	Slope (1:X)	200.0																																																																																																																			
Porosity	0.30	Cap Volume Depth (m)	1.650																																																																																																																			
Invert Level (m)	5.250	Cap Infiltration Depth (m)	0.000																																																																																																																			
Base Width (m)	2.5	Include Swale Volume	Yes																																																																																																																			
Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0																																																																																																																			
Membrane Percolation (mm/hr)	1000	Length (m)	11.1																																																																																																																			
Max Percolation (l/s)	30.8	Slope (1:X)	100.0																																																																																																																			
Safety Factor	2.0	Depression Storage (mm)	5																																																																																																																			
Porosity	0.30	Evaporation (mm/day)	3																																																																																																																			
Invert Level (m)	6.617	Cap Volume Depth (m)	0.400																																																																																																																			
Infiltration Coefficient Base (m/hr)	0.00000	Length (m)	23.8																																																																																																																			
Infiltration Coefficient Side (m/hr)	0.00000	Side Slope (1:X)	4.0																																																																																																																			
Safety Factor	2.0	Slope (1:X)	200.0																																																																																																																			
Porosity	0.30	Cap Volume Depth (m)	7.000																																																																																																																			
Invert Level (m)	5.700	Cap Infiltration Depth (m)	7.000																																																																																																																			
Base Width (m)	2.4	Include Swale Volume	Yes																																																																																																																			
©1982-2018 Innovyze																																																																																																																						

RSK LDE		Page 55
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions Network 2018.1.1		

Complex Manhole: S255, DS/PN: 5.000

Cellular Storage

Infiltration Coefficient Base (m/hr)	0.00000	Safety Factor	1.0
Infiltration Coefficient Side (m/hr)	0.00000	Porosity	0.95

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	81.0	108.0	0.900	0.0	146.4
0.800	81.0	146.4			

Porous Car Park

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0
Membrane Percolation (mm/hr)	1000	Length (m)	25.5
Max Percolation (l/s)	70.8	Slope (1:X)	100.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	6.420	Cap Volume Depth (m)	0.400

Porous Car Park Manhole: S22, DS/PN: 5.002

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0
Membrane Percolation (mm/hr)	1000	Length (m)	7.6
Max Percolation (l/s)	21.1	Slope (1:X)	100.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	6.815	Cap Volume Depth (m)	0.400

Porous Car Park Manhole: S23, DS/PN: 6.000

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0
Membrane Percolation (mm/hr)	1000	Length (m)	51.4
Max Percolation (l/s)	142.8	Slope (1:X)	100.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	6.540	Cap Volume Depth (m)	0.400

Porous Car Park Manhole: S26, DS/PN: 3.009

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0
Membrane Percolation (mm/hr)	1000	Length (m)	10.7
Max Percolation (l/s)	29.7	Slope (1:X)	100.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	6.288	Cap Volume Depth (m)	0.400

©1982-2018 Innovyze

RSK LDE		Page 56																																																																																																																								
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data																																																																																																																									
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by																																																																																																																									
XP Solutions	Network 2018.1.1																																																																																																																									
<u>Porous Car Park Manhole: S27, DS/PN: 3.010</u> <table><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Width (m)</td><td>4.0</td></tr><tr><td>Membrane Percolation (mm/hr)</td><td>1000</td><td>Length (m)</td><td>10.0</td></tr><tr><td>Max Percolation (l/s)</td><td>11.1</td><td>Slope (1:X)</td><td>100.0</td></tr><tr><td>Safety Factor</td><td>2.0</td><td>Depression Storage (mm)</td><td>5</td></tr><tr><td>Porosity</td><td>0.30</td><td>Evaporation (mm/day)</td><td>3</td></tr><tr><td>Invert Level (m)</td><td>6.216</td><td>Cap Volume Depth (m)</td><td>0.400</td></tr></table> <u>Porous Car Park Manhole: S29, DS/PN: 7.000</u> <table><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Width (m)</td><td>10.0</td></tr><tr><td>Membrane Percolation (mm/hr)</td><td>1000</td><td>Length (m)</td><td>22.1</td></tr><tr><td>Max Percolation (l/s)</td><td>61.4</td><td>Slope (1:X)</td><td>100.0</td></tr><tr><td>Safety Factor</td><td>2.0</td><td>Depression Storage (mm)</td><td>5</td></tr><tr><td>Porosity</td><td>0.30</td><td>Evaporation (mm/day)</td><td>3</td></tr><tr><td>Invert Level (m)</td><td>5.956</td><td>Cap Volume Depth (m)</td><td>0.400</td></tr></table> <u>Porous Car Park Manhole: S33, DS/PN: 8.000</u> <table><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Width (m)</td><td>10.0</td></tr><tr><td>Membrane Percolation (mm/hr)</td><td>1000</td><td>Length (m)</td><td>37.2</td></tr><tr><td>Max Percolation (l/s)</td><td>103.3</td><td>Slope (1:X)</td><td>100.0</td></tr><tr><td>Safety Factor</td><td>2.0</td><td>Depression Storage (mm)</td><td>5</td></tr><tr><td>Porosity</td><td>0.30</td><td>Evaporation (mm/day)</td><td>3</td></tr><tr><td>Invert Level (m)</td><td>5.790</td><td>Cap Volume Depth (m)</td><td>0.400</td></tr></table> <u>Porous Car Park Manhole: S34, DS/PN: 9.000</u> <table><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Width (m)</td><td>10.0</td></tr><tr><td>Membrane Percolation (mm/hr)</td><td>1000</td><td>Length (m)</td><td>38.8</td></tr><tr><td>Max Percolation (l/s)</td><td>107.8</td><td>Slope (1:X)</td><td>100.0</td></tr><tr><td>Safety Factor</td><td>2.0</td><td>Depression Storage (mm)</td><td>5</td></tr><tr><td>Porosity</td><td>0.30</td><td>Evaporation (mm/day)</td><td>3</td></tr><tr><td>Invert Level (m)</td><td>5.740</td><td>Cap Volume Depth (m)</td><td>0.400</td></tr></table> <u>Complex Manhole: S36, DS/PN: 1.007</u> <u>Swale</u> Warning:- Volume should always be included unless the upstream pipe is being used for storage and/or as a carrier <table><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Length (m)</td><td>75.0</td></tr><tr><td>Infiltration Coefficient Side (m/hr)</td><td>0.00000</td><td>Side Slope (1:X)</td><td>4.0</td></tr><tr><td>Safety Factor</td><td>2.0</td><td>Slope (1:X)</td><td>359.0</td></tr><tr><td>Porosity</td><td>0.30</td><td>Cap Volume Depth (m)</td><td>1.650</td></tr><tr><td>Invert Level (m)</td><td>5.120</td><td>Cap Infiltration Depth (m)</td><td>0.000</td></tr><tr><td>Base Width (m)</td><td>2.5</td><td>Include Swale Volume</td><td>Yes</td></tr></table>			Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	4.0	Membrane Percolation (mm/hr)	1000	Length (m)	10.0	Max Percolation (l/s)	11.1	Slope (1:X)	100.0	Safety Factor	2.0	Depression Storage (mm)	5	Porosity	0.30	Evaporation (mm/day)	3	Invert Level (m)	6.216	Cap Volume Depth (m)	0.400	Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0	Membrane Percolation (mm/hr)	1000	Length (m)	22.1	Max Percolation (l/s)	61.4	Slope (1:X)	100.0	Safety Factor	2.0	Depression Storage (mm)	5	Porosity	0.30	Evaporation (mm/day)	3	Invert Level (m)	5.956	Cap Volume Depth (m)	0.400	Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0	Membrane Percolation (mm/hr)	1000	Length (m)	37.2	Max Percolation (l/s)	103.3	Slope (1:X)	100.0	Safety Factor	2.0	Depression Storage (mm)	5	Porosity	0.30	Evaporation (mm/day)	3	Invert Level (m)	5.790	Cap Volume Depth (m)	0.400	Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0	Membrane Percolation (mm/hr)	1000	Length (m)	38.8	Max Percolation (l/s)	107.8	Slope (1:X)	100.0	Safety Factor	2.0	Depression Storage (mm)	5	Porosity	0.30	Evaporation (mm/day)	3	Invert Level (m)	5.740	Cap Volume Depth (m)	0.400	Infiltration Coefficient Base (m/hr)	0.00000	Length (m)	75.0	Infiltration Coefficient Side (m/hr)	0.00000	Side Slope (1:X)	4.0	Safety Factor	2.0	Slope (1:X)	359.0	Porosity	0.30	Cap Volume Depth (m)	1.650	Invert Level (m)	5.120	Cap Infiltration Depth (m)	0.000	Base Width (m)	2.5	Include Swale Volume	Yes
Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	4.0																																																																																																																							
Membrane Percolation (mm/hr)	1000	Length (m)	10.0																																																																																																																							
Max Percolation (l/s)	11.1	Slope (1:X)	100.0																																																																																																																							
Safety Factor	2.0	Depression Storage (mm)	5																																																																																																																							
Porosity	0.30	Evaporation (mm/day)	3																																																																																																																							
Invert Level (m)	6.216	Cap Volume Depth (m)	0.400																																																																																																																							
Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0																																																																																																																							
Membrane Percolation (mm/hr)	1000	Length (m)	22.1																																																																																																																							
Max Percolation (l/s)	61.4	Slope (1:X)	100.0																																																																																																																							
Safety Factor	2.0	Depression Storage (mm)	5																																																																																																																							
Porosity	0.30	Evaporation (mm/day)	3																																																																																																																							
Invert Level (m)	5.956	Cap Volume Depth (m)	0.400																																																																																																																							
Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0																																																																																																																							
Membrane Percolation (mm/hr)	1000	Length (m)	37.2																																																																																																																							
Max Percolation (l/s)	103.3	Slope (1:X)	100.0																																																																																																																							
Safety Factor	2.0	Depression Storage (mm)	5																																																																																																																							
Porosity	0.30	Evaporation (mm/day)	3																																																																																																																							
Invert Level (m)	5.790	Cap Volume Depth (m)	0.400																																																																																																																							
Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0																																																																																																																							
Membrane Percolation (mm/hr)	1000	Length (m)	38.8																																																																																																																							
Max Percolation (l/s)	107.8	Slope (1:X)	100.0																																																																																																																							
Safety Factor	2.0	Depression Storage (mm)	5																																																																																																																							
Porosity	0.30	Evaporation (mm/day)	3																																																																																																																							
Invert Level (m)	5.740	Cap Volume Depth (m)	0.400																																																																																																																							
Infiltration Coefficient Base (m/hr)	0.00000	Length (m)	75.0																																																																																																																							
Infiltration Coefficient Side (m/hr)	0.00000	Side Slope (1:X)	4.0																																																																																																																							
Safety Factor	2.0	Slope (1:X)	359.0																																																																																																																							
Porosity	0.30	Cap Volume Depth (m)	1.650																																																																																																																							
Invert Level (m)	5.120	Cap Infiltration Depth (m)	0.000																																																																																																																							
Base Width (m)	2.5	Include Swale Volume	Yes																																																																																																																							
©1982-2018 Innovyze																																																																																																																										

RSK LDE		Page 57
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions Network 2018.1.1		

Swale Manhole: S41, DS/PN: 10.003

Warning:- Volume should always be included unless the upstream pipe is being used for storage and/or as a carrier

Infiltration Coefficient Base (m/hr)	0.00000	Length (m)	39.0
Infiltration Coefficient Side (m/hr)	0.00000	Side Slope (1:X)	4.0
Safety Factor	2.0	Slope (1:X)	100.0
Porosity	0.30	Cap Volume Depth (m)	6.500
Invert Level (m)	5.680	Cap Infiltration Depth (m)	6.500
Base Width (m)	2.4	Include Swale Volume	Yes

Swale Manhole: S47, DS/PN: 10.009

Warning:- Volume should always be included unless the upstream pipe is being used for storage and/or as a carrier

Infiltration Coefficient Base (m/hr)	0.00000	Length (m)	64.8
Infiltration Coefficient Side (m/hr)	0.00000	Side Slope (1:X)	4.0
Safety Factor	2.0	Slope (1:X)	100.0
Porosity	0.30	Cap Volume Depth (m)	6.000
Invert Level (m)	4.900	Cap Infiltration Depth (m)	6.000
Base Width (m)	2.0	Include Swale Volume	Yes

Tank or Pond Manhole: S49, DS/PN: 1.012

Invert Level (m) 4.800

Depth (m)	Area (m ²)	Depth (m)	Area (m ²)
0.000	25.3	1.000	146.1

Porous Car Park Manhole: S51, DS/PN: 12.000

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0
Membrane Percolation (mm/hr)	1000	Length (m)	20.0
Max Percolation (l/s)	55.6	Slope (1:X)	100.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	5.540	Cap Volume Depth (m)	0.400

Porous Car Park Manhole: S56, DS/PN: 13.000

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	2.9
Membrane Percolation (mm/hr)	1000	Length (m)	10.0
Max Percolation (l/s)	8.1	Slope (1:X)	100.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	5.524	Cap Volume Depth (m)	0.400

©1982-2018 Innovyze

RSK LDE		Page 58
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions Network 2018.1.1		

Porous Car Park Manhole: S58, DS/PN: 13.002

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0
Membrane Percolation (mm/hr)	1000	Length (m)	16.3
Max Percolation (l/s)	45.3	Slope (1:X)	100.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	5.306	Cap Volume Depth (m)	0.400

Complex Manhole: S60, DS/PN: 1.017

Filter Drain

Infiltration Coefficient Base (m/hr)	0.00000	Pipe Diameter (m)	0.150
Infiltration Coefficient Side (m/hr)	0.00000	Pipe Depth above Invert (m)	0.000
Safety Factor	2.0	Number of Pipes	1
Porosity	0.30	Slope (1:X)	0.0
Invert Level (m)	4.250	Cap Volume Depth (m)	0.400
Trench Width (m)	2.4	Cap Infiltration Depth (m)	0.000
Trench Length (m)	83.5		

Swale

Warning:- Volume should always be included unless the upstream pipe is being used for storage and/or as a carrier

Infiltration Coefficient Base (m/hr)	0.00000	Length (m)	83.5
Infiltration Coefficient Side (m/hr)	0.00000	Side Slope (1:X)	3.0
Safety Factor	2.0	Slope (1:X)	0.0
Porosity	1.00	Cap Volume Depth (m)	0.300
Invert Level (m)	4.650	Cap Infiltration Depth (m)	0.000
Base Width (m)	1.0	Include Swale Volume	Yes

Porous Car Park Manhole: S63, DS/PN: 14.001

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0
Membrane Percolation (mm/hr)	1000	Length (m)	47.2
Max Percolation (l/s)	131.1	Slope (1:X)	100.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	6.290	Cap Volume Depth (m)	0.400

Porous Car Park Manhole: S68, DS/PN: 16.001

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0
Membrane Percolation (mm/hr)	1000	Length (m)	20.9
Max Percolation (l/s)	58.1	Slope (1:X)	100.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	5.550	Cap Volume Depth (m)	0.400

©1982-2018 Innovyze

RSK LDE		Page 59
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions Network 2018.1.1		

Porous Car Park Manhole: S70, DS/PN: 14.006

Infiltration Coefficient Base (m/hr) 0.00000	Width (m) 8.8	
Membrane Percolation (mm/hr) 1000	Length (m) 10.0	
Max Percolation (l/s) 24.4	Slope (1:X) 100.0	
Safety Factor 2.0	Depression Storage (mm) 5	
Porosity 0.30	Evaporation (mm/day) 3	
Invert Level (m) 5.057	Cap Volume Depth (m) 0.400	

Porous Car Park Manhole: S72, DS/PN: 17.000

Infiltration Coefficient Base (m/hr) 0.00000	Width (m) 10.0	
Membrane Percolation (mm/hr) 1000	Length (m) 22.9	
Max Percolation (l/s) 63.6	Slope (1:X) 100.0	
Safety Factor 2.0	Depression Storage (mm) 5	
Porosity 0.30	Evaporation (mm/day) 3	
Invert Level (m) 5.540	Cap Volume Depth (m) 0.400	

Porous Car Park Manhole: S73, DS/PN: 18.000

Infiltration Coefficient Base (m/hr) 0.00000	Width (m) 10.0	
Membrane Percolation (mm/hr) 1000	Length (m) 23.2	
Max Percolation (l/s) 64.4	Slope (1:X) 100.0	
Safety Factor 2.0	Depression Storage (mm) 5	
Porosity 0.30	Evaporation (mm/day) 3	
Invert Level (m) 5.390	Cap Volume Depth (m) 0.400	

Tank or Pond Manhole: S76, DS/PN: 1.018

Invert Level (m) 4.550

Depth (m)	Area (m ²)	Depth (m)	Area (m ²)
0.000	610.9	1.000	966.0

Complex Manhole: S79, DS/PN: 1.021

Filter Drain

Infiltration Coefficient Base (m/hr) 0.00000	Pipe Diameter (m) 0.300
Infiltration Coefficient Side (m/hr) 0.00000	Pipe Depth above Invert (m) 0.000
Safety Factor 2.0	Number of Pipes 1
Porosity 0.30	Slope (1:X) 0.0
Invert Level (m) 4.050	Cap Volume Depth (m) 1.400
Trench Width (m) 2.4	Cap Infiltration Depth (m) 0.000
Trench Length (m) 38.7	

Swale

Warning:- Volume should always be included unless the upstream pipe is being used for storage and/or as a carrier

©1982-2018 Innovyze

RSK LDE		Page 60																		
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data																			
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by																			
XP Solutions	Network 2018.1.1																			
Swale Infiltration Coefficient Base (m/hr) 0.00000 Infiltration Coefficient Side (m/hr) 0.00000 Safety Factor 2.0 Porosity 1.00 Invert Level (m) 5.450 Base Width (m) 0.8 Length (m) 38.7 Side Slope (1:X) 3.0 Slope (1:X) 387.0 Cap Volume Depth (m) 0.300 Cap Infiltration Depth (m) 0.000 Include Swale Volume Yes <tr><td colspan="3"> Porous Car Park Manhole: S80, DS/PN: 19.000 Infiltration Coefficient Base (m/hr) 0.00000 Membrane Percolation (mm/hr) 1000 Max Percolation (l/s) 99.4 Safety Factor 2.0 Porosity 0.30 Invert Level (m) 6.395 Width (m) 10.0 Length (m) 35.8 Slope (1:X) 100.0 Depression Storage (mm) 5 Evaporation (mm/day) 3 Cap Volume Depth (m) 0.400 </td></tr> <tr><td colspan="3"> Porous Car Park Manhole: S81, DS/PN: 19.001 Infiltration Coefficient Base (m/hr) 0.00000 Membrane Percolation (mm/hr) 1000 Max Percolation (l/s) 38.3 Safety Factor 2.0 Porosity 0.30 Invert Level (m) 6.285 Width (m) 10.0 Length (m) 13.8 Slope (1:X) 100.0 Depression Storage (mm) 5 Evaporation (mm/day) 3 Cap Volume Depth (m) 0.400 </td></tr> <tr><td colspan="3"> Porous Car Park Manhole: S82, DS/PN: 20.000 Infiltration Coefficient Base (m/hr) 0.00000 Membrane Percolation (mm/hr) 1000 Max Percolation (l/s) 70.0 Safety Factor 2.0 Porosity 0.30 Invert Level (m) 6.215 Width (m) 10.0 Length (m) 25.2 Slope (1:X) 100.0 Depression Storage (mm) 5 Evaporation (mm/day) 3 Cap Volume Depth (m) 0.400 </td></tr> <tr><td colspan="3"> Porous Car Park Manhole: S85, DS/PN: 19.004 Infiltration Coefficient Base (m/hr) 0.00000 Membrane Percolation (mm/hr) 1000 Max Percolation (l/s) 43.6 Safety Factor 2.0 Porosity 0.30 Invert Level (m) 5.889 Width (m) 10.0 Length (m) 15.7 Slope (1:X) 100.0 Depression Storage (mm) 5 Evaporation (mm/day) 3 Cap Volume Depth (m) 0.400 </td></tr> <tr><td colspan="3"> Porous Car Park Manhole: S86, DS/PN: 19.005 Infiltration Coefficient Base (m/hr) 0.00000 Membrane Percolation (mm/hr) 1000 Max Percolation (l/s) 86.1 Safety Factor 2.0 Porosity 0.30 Invert Level (m) 5.887 Width (m) 10.0 Length (m) 31.0 Slope (1:X) 100.0 Depression Storage (mm) 5 </td></tr> <tr><td colspan="3">©1982-2018 Innovyze</td></tr>			Porous Car Park Manhole: S80, DS/PN: 19.000 Infiltration Coefficient Base (m/hr) 0.00000 Membrane Percolation (mm/hr) 1000 Max Percolation (l/s) 99.4 Safety Factor 2.0 Porosity 0.30 Invert Level (m) 6.395 Width (m) 10.0 Length (m) 35.8 Slope (1:X) 100.0 Depression Storage (mm) 5 Evaporation (mm/day) 3 Cap Volume Depth (m) 0.400			Porous Car Park Manhole: S81, DS/PN: 19.001 Infiltration Coefficient Base (m/hr) 0.00000 Membrane Percolation (mm/hr) 1000 Max Percolation (l/s) 38.3 Safety Factor 2.0 Porosity 0.30 Invert Level (m) 6.285 Width (m) 10.0 Length (m) 13.8 Slope (1:X) 100.0 Depression Storage (mm) 5 Evaporation (mm/day) 3 Cap Volume Depth (m) 0.400			Porous Car Park Manhole: S82, DS/PN: 20.000 Infiltration Coefficient Base (m/hr) 0.00000 Membrane Percolation (mm/hr) 1000 Max Percolation (l/s) 70.0 Safety Factor 2.0 Porosity 0.30 Invert Level (m) 6.215 Width (m) 10.0 Length (m) 25.2 Slope (1:X) 100.0 Depression Storage (mm) 5 Evaporation (mm/day) 3 Cap Volume Depth (m) 0.400			Porous Car Park Manhole: S85, DS/PN: 19.004 Infiltration Coefficient Base (m/hr) 0.00000 Membrane Percolation (mm/hr) 1000 Max Percolation (l/s) 43.6 Safety Factor 2.0 Porosity 0.30 Invert Level (m) 5.889 Width (m) 10.0 Length (m) 15.7 Slope (1:X) 100.0 Depression Storage (mm) 5 Evaporation (mm/day) 3 Cap Volume Depth (m) 0.400			Porous Car Park Manhole: S86, DS/PN: 19.005 Infiltration Coefficient Base (m/hr) 0.00000 Membrane Percolation (mm/hr) 1000 Max Percolation (l/s) 86.1 Safety Factor 2.0 Porosity 0.30 Invert Level (m) 5.887 Width (m) 10.0 Length (m) 31.0 Slope (1:X) 100.0 Depression Storage (mm) 5			©1982-2018 Innovyze		
Porous Car Park Manhole: S80, DS/PN: 19.000 Infiltration Coefficient Base (m/hr) 0.00000 Membrane Percolation (mm/hr) 1000 Max Percolation (l/s) 99.4 Safety Factor 2.0 Porosity 0.30 Invert Level (m) 6.395 Width (m) 10.0 Length (m) 35.8 Slope (1:X) 100.0 Depression Storage (mm) 5 Evaporation (mm/day) 3 Cap Volume Depth (m) 0.400																				
Porous Car Park Manhole: S81, DS/PN: 19.001 Infiltration Coefficient Base (m/hr) 0.00000 Membrane Percolation (mm/hr) 1000 Max Percolation (l/s) 38.3 Safety Factor 2.0 Porosity 0.30 Invert Level (m) 6.285 Width (m) 10.0 Length (m) 13.8 Slope (1:X) 100.0 Depression Storage (mm) 5 Evaporation (mm/day) 3 Cap Volume Depth (m) 0.400																				
Porous Car Park Manhole: S82, DS/PN: 20.000 Infiltration Coefficient Base (m/hr) 0.00000 Membrane Percolation (mm/hr) 1000 Max Percolation (l/s) 70.0 Safety Factor 2.0 Porosity 0.30 Invert Level (m) 6.215 Width (m) 10.0 Length (m) 25.2 Slope (1:X) 100.0 Depression Storage (mm) 5 Evaporation (mm/day) 3 Cap Volume Depth (m) 0.400																				
Porous Car Park Manhole: S85, DS/PN: 19.004 Infiltration Coefficient Base (m/hr) 0.00000 Membrane Percolation (mm/hr) 1000 Max Percolation (l/s) 43.6 Safety Factor 2.0 Porosity 0.30 Invert Level (m) 5.889 Width (m) 10.0 Length (m) 15.7 Slope (1:X) 100.0 Depression Storage (mm) 5 Evaporation (mm/day) 3 Cap Volume Depth (m) 0.400																				
Porous Car Park Manhole: S86, DS/PN: 19.005 Infiltration Coefficient Base (m/hr) 0.00000 Membrane Percolation (mm/hr) 1000 Max Percolation (l/s) 86.1 Safety Factor 2.0 Porosity 0.30 Invert Level (m) 5.887 Width (m) 10.0 Length (m) 31.0 Slope (1:X) 100.0 Depression Storage (mm) 5																				
©1982-2018 Innovyze																				

RSK LDE		Page 61
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions Network 2018.1.1		

Porous Car Park Manhole: S86, DS/PN: 19.005

Evaporation (mm/day) 3 Cap Volume Depth (m) 0.400

Cellular Storage Manhole: S88, DS/PN: 19.007

Invert Level (m) 5.030 Safety Factor 2.0
Infiltration Coefficient Base (m/hr) 0.00000 Porosity 0.95
Infiltration Coefficient Side (m/hr) 0.00000

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	64.0	64.0	1.300	0.0	104.0
1.200	64.0	102.4			

Complex Manhole: S253, DS/PN: 21.000

Cellular Storage

Invert Level (m) 5.900 Safety Factor 2.0
Infiltration Coefficient Base (m/hr) 0.00000 Porosity 0.95
Infiltration Coefficient Side (m/hr) 0.00000

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	76.5	76.5	0.500	0.0	90.5
0.400	76.5	90.5			

Porous Car Park

Infiltration Coefficient Base (m/hr) 0.00000 Width (m) 10.0
Membrane Percolation (mm/hr) 1000 Length (m) 89.5
Max Percolation (l/s) 248.6 Slope (1:X) 100.0
Safety Factor 2.0 Depression Storage (mm) 5
Porosity 0.30 Evaporation (mm/day) 3
Invert Level (m) 6.690 Cap Volume Depth (m) 0.400

Porous Car Park Manhole: S91, DS/PN: 21.002

Infiltration Coefficient Base (m/hr) 0.00000 Width (m) 10.0
Membrane Percolation (mm/hr) 1000 Length (m) 13.0
Max Percolation (l/s) 36.1 Slope (1:X) 100.0
Safety Factor 2.0 Depression Storage (mm) 5
Porosity 0.30 Evaporation (mm/day) 3
Invert Level (m) 7.013 Cap Volume Depth (m) 0.400

Porous Car Park Manhole: S93, DS/PN: 21.004

Infiltration Coefficient Base (m/hr) 0.00000 Safety Factor 2.0
Membrane Percolation (mm/hr) 1000 Porosity 0.30
Max Percolation (l/s) 33.1 Invert Level (m) 6.640

©1982-2018 Innovyze

RSK LDE		Page 62																																																																																																																																										
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data																																																																																																																																											
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by																																																																																																																																											
XP Solutions	Network 2018.1.1																																																																																																																																											
<u>Porous Car Park Manhole: S93, DS/PN: 21.004</u> <table><tr><td>Width (m)</td><td>10.0</td><td>Depression Storage (mm)</td><td>5</td></tr><tr><td>Length (m)</td><td>11.9</td><td>Evaporation (mm/day)</td><td>3</td></tr><tr><td>Slope (1:X)</td><td>100.0</td><td>Cap Volume Depth (m)</td><td>0.400</td></tr></table> <u>Porous Car Park Manhole: S97, DS/PN: 22.001</u> <table><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Width (m)</td><td>10.0</td></tr><tr><td>Membrane Percolation (mm/hr)</td><td>1000</td><td>Length (m)</td><td>15.2</td></tr><tr><td>Max Percolation (l/s)</td><td>42.2</td><td>Slope (1:X)</td><td>100.0</td></tr><tr><td>Safety Factor</td><td>2.0</td><td>Depression Storage (mm)</td><td>5</td></tr><tr><td>Porosity</td><td>0.30</td><td>Evaporation (mm/day)</td><td>3</td></tr><tr><td>Invert Level (m)</td><td>6.170</td><td>Cap Volume Depth (m)</td><td>0.400</td></tr></table> <u>Porous Car Park Manhole: S98, DS/PN: 23.000</u> <table><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Width (m)</td><td>10.0</td></tr><tr><td>Membrane Percolation (mm/hr)</td><td>1000</td><td>Length (m)</td><td>11.3</td></tr><tr><td>Max Percolation (l/s)</td><td>31.4</td><td>Slope (1:X)</td><td>100.0</td></tr><tr><td>Safety Factor</td><td>2.0</td><td>Depression Storage (mm)</td><td>5</td></tr><tr><td>Porosity</td><td>0.30</td><td>Evaporation (mm/day)</td><td>3</td></tr><tr><td>Invert Level (m)</td><td>6.170</td><td>Cap Volume Depth (m)</td><td>0.400</td></tr></table> <u>Porous Car Park Manhole: S101, DS/PN: 21.009</u> <table><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Width (m)</td><td>10.0</td></tr><tr><td>Membrane Percolation (mm/hr)</td><td>1000</td><td>Length (m)</td><td>27.1</td></tr><tr><td>Max Percolation (l/s)</td><td>75.3</td><td>Slope (1:X)</td><td>100.0</td></tr><tr><td>Safety Factor</td><td>2.0</td><td>Depression Storage (mm)</td><td>5</td></tr><tr><td>Porosity</td><td>0.30</td><td>Evaporation (mm/day)</td><td>3</td></tr><tr><td>Invert Level (m)</td><td>5.820</td><td>Cap Volume Depth (m)</td><td>0.400</td></tr></table> <u>Cellular Storage Manhole: S103, DS/PN: 19.009</u> <table><tr><td>Invert Level (m)</td><td>4.915</td><td>Safety Factor</td><td>2.0</td></tr><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Porosity</td><td>0.95</td></tr><tr><td>Infiltration Coefficient Side (m/hr)</td><td>0.00000</td><td></td><td></td></tr></table> <table><tr><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th></tr><tr><td>0.000</td><td>186.0</td><td>186.0</td><td>0.500</td><td>0.0</td><td>210.5</td></tr><tr><td>0.400</td><td>186.0</td><td>207.8</td><td></td><td></td><td></td></tr></table> <u>Porous Car Park Manhole: S107, DS/PN: 24.001</u> <table><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Width (m)</td><td>10.0</td></tr><tr><td>Membrane Percolation (mm/hr)</td><td>1000</td><td>Length (m)</td><td>28.2</td></tr><tr><td>Max Percolation (l/s)</td><td>78.3</td><td>Slope (1:X)</td><td>100.0</td></tr><tr><td>Safety Factor</td><td>2.0</td><td>Depression Storage (mm)</td><td>5</td></tr><tr><td>Porosity</td><td>0.30</td><td>Evaporation (mm/day)</td><td>3</td></tr><tr><td>Invert Level (m)</td><td>6.590</td><td>Cap Volume Depth (m)</td><td>0.400</td></tr></table>			Width (m)	10.0	Depression Storage (mm)	5	Length (m)	11.9	Evaporation (mm/day)	3	Slope (1:X)	100.0	Cap Volume Depth (m)	0.400	Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0	Membrane Percolation (mm/hr)	1000	Length (m)	15.2	Max Percolation (l/s)	42.2	Slope (1:X)	100.0	Safety Factor	2.0	Depression Storage (mm)	5	Porosity	0.30	Evaporation (mm/day)	3	Invert Level (m)	6.170	Cap Volume Depth (m)	0.400	Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0	Membrane Percolation (mm/hr)	1000	Length (m)	11.3	Max Percolation (l/s)	31.4	Slope (1:X)	100.0	Safety Factor	2.0	Depression Storage (mm)	5	Porosity	0.30	Evaporation (mm/day)	3	Invert Level (m)	6.170	Cap Volume Depth (m)	0.400	Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0	Membrane Percolation (mm/hr)	1000	Length (m)	27.1	Max Percolation (l/s)	75.3	Slope (1:X)	100.0	Safety Factor	2.0	Depression Storage (mm)	5	Porosity	0.30	Evaporation (mm/day)	3	Invert Level (m)	5.820	Cap Volume Depth (m)	0.400	Invert Level (m)	4.915	Safety Factor	2.0	Infiltration Coefficient Base (m/hr)	0.00000	Porosity	0.95	Infiltration Coefficient Side (m/hr)	0.00000			Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)	0.000	186.0	186.0	0.500	0.0	210.5	0.400	186.0	207.8				Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0	Membrane Percolation (mm/hr)	1000	Length (m)	28.2	Max Percolation (l/s)	78.3	Slope (1:X)	100.0	Safety Factor	2.0	Depression Storage (mm)	5	Porosity	0.30	Evaporation (mm/day)	3	Invert Level (m)	6.590	Cap Volume Depth (m)	0.400
Width (m)	10.0	Depression Storage (mm)	5																																																																																																																																									
Length (m)	11.9	Evaporation (mm/day)	3																																																																																																																																									
Slope (1:X)	100.0	Cap Volume Depth (m)	0.400																																																																																																																																									
Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0																																																																																																																																									
Membrane Percolation (mm/hr)	1000	Length (m)	15.2																																																																																																																																									
Max Percolation (l/s)	42.2	Slope (1:X)	100.0																																																																																																																																									
Safety Factor	2.0	Depression Storage (mm)	5																																																																																																																																									
Porosity	0.30	Evaporation (mm/day)	3																																																																																																																																									
Invert Level (m)	6.170	Cap Volume Depth (m)	0.400																																																																																																																																									
Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0																																																																																																																																									
Membrane Percolation (mm/hr)	1000	Length (m)	11.3																																																																																																																																									
Max Percolation (l/s)	31.4	Slope (1:X)	100.0																																																																																																																																									
Safety Factor	2.0	Depression Storage (mm)	5																																																																																																																																									
Porosity	0.30	Evaporation (mm/day)	3																																																																																																																																									
Invert Level (m)	6.170	Cap Volume Depth (m)	0.400																																																																																																																																									
Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0																																																																																																																																									
Membrane Percolation (mm/hr)	1000	Length (m)	27.1																																																																																																																																									
Max Percolation (l/s)	75.3	Slope (1:X)	100.0																																																																																																																																									
Safety Factor	2.0	Depression Storage (mm)	5																																																																																																																																									
Porosity	0.30	Evaporation (mm/day)	3																																																																																																																																									
Invert Level (m)	5.820	Cap Volume Depth (m)	0.400																																																																																																																																									
Invert Level (m)	4.915	Safety Factor	2.0																																																																																																																																									
Infiltration Coefficient Base (m/hr)	0.00000	Porosity	0.95																																																																																																																																									
Infiltration Coefficient Side (m/hr)	0.00000																																																																																																																																											
Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)																																																																																																																																							
0.000	186.0	186.0	0.500	0.0	210.5																																																																																																																																							
0.400	186.0	207.8																																																																																																																																										
Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0																																																																																																																																									
Membrane Percolation (mm/hr)	1000	Length (m)	28.2																																																																																																																																									
Max Percolation (l/s)	78.3	Slope (1:X)	100.0																																																																																																																																									
Safety Factor	2.0	Depression Storage (mm)	5																																																																																																																																									
Porosity	0.30	Evaporation (mm/day)	3																																																																																																																																									
Invert Level (m)	6.590	Cap Volume Depth (m)	0.400																																																																																																																																									
©1982-2018 Innovyze																																																																																																																																												

RSK LDE		Page 63
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions Network 2018.1.1		

Porous Car Park Manhole: S108, DS/PN: 24.002

Infiltration Coefficient Base (m/hr) 0.00000	Width (m) 10.0
Membrane Percolation (mm/hr) 1000	Length (m) 11.5
Max Percolation (l/s) 31.9	Slope (1:X) 100.0
Safety Factor 2.0	Depression Storage (mm) 5
Porosity 0.30	Evaporation (mm/day) 3
Invert Level (m) 6.440	Cap Volume Depth (m) 0.400

Porous Car Park Manhole: S109, DS/PN: 24.003

Infiltration Coefficient Base (m/hr) 0.00000	Width (m) 8.4
Membrane Percolation (mm/hr) 1000	Length (m) 10.0
Max Percolation (l/s) 23.3	Slope (1:X) 100.0
Safety Factor 2.0	Depression Storage (mm) 5
Porosity 0.30	Evaporation (mm/day) 3
Invert Level (m) 6.290	Cap Volume Depth (m) 0.400

Complex Manhole: S110, DS/PN: 19.012

Cellular Storage

Invert Level (m) 4.750	Safety Factor 2.0
Infiltration Coefficient Base (m/hr) 0.00000	Porosity 0.95
Infiltration Coefficient Side (m/hr) 0.00000	

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	180.0	180.0	0.500	0.0	204.1
0.400	180.0	201.5			

Tank or Pond

Invert Level (m) 6.300

Depth (m)	Area (m ²)	Depth (m)	Area (m ²)	Depth (m)	Area (m ²)	Depth (m)	Area (m ²)
0.000	270.3	1.400	0.0	2.800	0.0	4.200	0.0
0.200	315.4	1.600	0.0	3.000	0.0	4.400	0.0
0.400	363.0	1.800	0.0	3.200	0.0	4.600	0.0
0.600	427.1	2.000	0.0	3.400	0.0	4.800	0.0
0.800	0.0	2.200	0.0	3.600	0.0	5.000	0.0
1.000	0.0	2.400	0.0	3.800	0.0		
1.200	0.0	2.600	0.0	4.000	0.0		

Swale Manhole: S116, DS/PN: 25.003

Warning:- Volume should always be included unless the upstream pipe is being used for storage and/or as a carrier

Infiltration Coefficient Base (m/hr) 0.00000	Safety Factor 2.0
Infiltration Coefficient Side (m/hr) 0.00000	Porosity 0.30

©1982-2018 Innovyze

RSK LDE		Page 64
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions Network 2018.1.1		

Swale Manhole: S116, DS/PN: 25.003

Invert Level (m)	5.950	Slope (1:X)	100.0
Base Width (m)	2.4	Cap Volume Depth (m)	6.850
Length (m)	50.3	Cap Infiltration Depth (m)	6.850
Side Slope (1:X)	4.0	Include Swale Volume	Yes

Swale Manhole: S121, DS/PN: 26.000

Warning:- Volume should always be included unless the upstream pipe is being used for storage and/or as a carrier

Infiltration Coefficient Base (m/hr)	0.00000	Length (m)	14.5
Infiltration Coefficient Side (m/hr)	0.00000	Side Slope (1:X)	4.0
Safety Factor	2.0	Slope (1:X)	100.0
Porosity	0.30	Cap Volume Depth (m)	6.850
Invert Level (m)	6.100	Cap Infiltration Depth (m)	6.850
Base Width (m)	2.4	Include Swale Volume	Yes

Porous Car Park Manhole: S126, DS/PN: 27.000

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0
Membrane Percolation (mm/hr)	1000	Length (m)	40.1
Max Percolation (l/s)	111.4	Slope (1:X)	100.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	6.143	Cap Volume Depth (m)	0.400

Swale Manhole: S127, DS/PN: 19.013

Warning:- Volume should always be included unless the upstream pipe is being used for storage and/or as a carrier

Infiltration Coefficient Base (m/hr)	0.00000	Length (m)	50.3
Infiltration Coefficient Side (m/hr)	0.00000	Side Slope (1:X)	4.0
Safety Factor	2.0	Slope (1:X)	100.0
Porosity	0.30	Cap Volume Depth (m)	6.800
Invert Level (m)	5.910	Cap Infiltration Depth (m)	6.800
Base Width (m)	2.4	Include Swale Volume	Yes

Porous Car Park Manhole: S128, DS/PN: 28.000

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0
Membrane Percolation (mm/hr)	1000	Length (m)	17.0
Max Percolation (l/s)	47.2	Slope (1:X)	100.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	6.090	Cap Volume Depth (m)	0.400

Complex Manhole: S130, DS/PN: 19.014

©1982-2018 Innovyze

RSK LDE		Page 65
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions Network 2018.1.1		

Cellular Storage

Invert Level (m) 4.600 Safety Factor 2.0
Infiltration Coefficient Base (m/hr) 0.00000 Porosity 0.95
Infiltration Coefficient Side (m/hr) 0.00000

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	49.0	49.0	0.500	0.0	60.2
0.400	49.0	60.2			

Tank or Pond

Invert Level (m) 6.200

Depth (m)	Area (m ²)	Depth (m)	Area (m ²)
0.000	269.2	0.400	346.7

Porous Car Park Manhole: S131, DS/PN: 29.000

Infiltration Coefficient Base (m/hr) 0.00000 Width (m) 3.7
Membrane Percolation (mm/hr) 1000 Length (m) 10.0
Max Percolation (l/s) 10.3 Slope (1:X) 100.0
Safety Factor 2.0 Depression Storage (mm) 5
Porosity 0.30 Evaporation (mm/day) 3
Invert Level (m) 5.967 Cap Volume Depth (m) 0.400

Porous Car Park Manhole: S133, DS/PN: 29.002

Infiltration Coefficient Base (m/hr) 0.00000 Width (m) 10.0
Membrane Percolation (mm/hr) 1000 Length (m) 26.8
Max Percolation (l/s) 74.4 Slope (1:X) 100.0
Safety Factor 2.0 Depression Storage (mm) 5
Porosity 0.30 Evaporation (mm/day) 3
Invert Level (m) 5.710 Cap Volume Depth (m) 0.400

Complex Manhole: S134, DS/PN: 19.015

Cellular Storage

Invert Level (m) 4.460 Safety Factor 2.0
Infiltration Coefficient Base (m/hr) 0.00000 Porosity 0.95
Infiltration Coefficient Side (m/hr) 0.00000

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	49.0	49.0	0.500	0.0	60.2
0.400	49.0	60.2			

©1982-2018 Innovyze

RSK LDE		Page 66
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions Network 2018.1.1		

Tank or Pond

Invert Level (m) 6.200

Depth (m)	Area (m ²)	Depth (m)	Area (m ²)
0.000	250.5	0.400	329.9

Porous Car Park Manhole: S135, DS/PN: 30.000

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0
Membrane Percolation (mm/hr)	1000	Length (m)	28.6
Max Percolation (l/s)	79.4	Slope (1:X)	100.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	5.760	Cap Volume Depth (m)	0.400

Cellular Storage Manhole: S136, DS/PN: 19.016

Invert Level (m)	4.460	Safety Factor	2.0
Infiltration Coefficient Base (m/hr)	0.00000	Porosity	0.95
Infiltration Coefficient Side (m/hr)	0.00000		

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	36.0	36.0	0.500	0.0	45.6
0.400	36.0	45.6			

Cellular Storage Manhole: S138, DS/PN: 19.017

Invert Level (m)	4.400	Safety Factor	2.0
Infiltration Coefficient Base (m/hr)	0.00000	Porosity	0.95
Infiltration Coefficient Side (m/hr)	0.00000		

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	49.0	49.0	0.500	0.0	60.2
0.400	49.0	60.2			

Porous Car Park Manhole: S139, DS/PN: 32.000

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0
Membrane Percolation (mm/hr)	1000	Length (m)	52.0
Max Percolation (l/s)	144.4	Slope (1:X)	100.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	5.690	Cap Volume Depth (m)	0.400

Porous Car Park Manhole: S140, DS/PN: 32.001

Infiltration Coefficient Base (m/hr)	0.00000	Safety Factor	2.0
Membrane Percolation (mm/hr)	1000	Porosity	0.30
Max Percolation (l/s)	25.3	Invert Level (m)	5.390

©1982-2018 Innovyze

RSK LDE		Page 67
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions Network 2018.1.1		

Porous Car Park Manhole: S140, DS/PN: 32.001

Width (m)	9.1	Depression Storage (mm)	5
Length (m)	10.0	Evaporation (mm/day)	3
Slope (1:X)	100.0	Cap Volume Depth (m)	0.400

Complex Manhole: S144, DS/PN: 19.018

Cellular Storage

Invert Level (m)	4.400	Safety Factor	2.0
Infiltration Coefficient Base (m/hr)	0.00000	Porosity	0.95
Infiltration Coefficient Side (m/hr)	0.00000		

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	49.0	49.0	0.500	0.0	60.2
0.400	49.0	60.2			

Tank or Pond

Invert Level (m) 5.500

Depth (m)	Area (m ²)	Depth (m)	Area (m ²)
0.000	260.0	0.400	345.2

Porous Car Park Manhole: S145, DS/PN: 34.000

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0
Membrane Percolation (mm/hr)	1000	Length (m)	56.7
Max Percolation (l/s)	157.5	Slope (1:X)	100.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	6.007	Cap Volume Depth (m)	0.400

Porous Car Park Manhole: S146, DS/PN: 35.000

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0
Membrane Percolation (mm/hr)	1000	Length (m)	18.8
Max Percolation (l/s)	52.2	Slope (1:X)	100.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	5.700	Cap Volume Depth (m)	0.400

Porous Car Park Manhole: S150, DS/PN: 34.004

Infiltration Coefficient Base (m/hr)	0.00000	Porosity	0.30
Membrane Percolation (mm/hr)	1000	Invert Level (m)	5.172
Max Percolation (l/s)	132.8	Width (m)	10.0
Safety Factor	2.0	Length (m)	47.8

©1982-2018 Innovyze

RSK LDE

Page 68

18 Frogmore Road
Hemel Hempstead
Hertfordshire HP3 9RT

Date 18/03/2021 13:32
File 133981 - Drove Lane, Ya...

XP Solutions

Drove Lane, Yapton
Surface Water Network
Calculations - FEH Data

Designed by AMuthusami
Checked by

Network 2018.1.1

Micro Drainage

Porous Car Park Manhole: S150, DS/PN: 34.004

Slope (1:X) 100.0 Evaporation (mm/day) 3
Depression Storage (mm) 5 Cap Volume Depth (m) 0.400

Porous Car Park Manhole: S151, DS/PN: 36.000

Infiltration Coefficient Base (m/hr) 0.00000 Width (m) 10.0
Membrane Percolation (mm/hr) 1000 Length (m) 18.8
Max Percolation (l/s) 52.2 Slope (1:X) 100.0
Safety Factor 2.0 Depression Storage (mm) 5
Porosity 0.30 Evaporation (mm/day) 3
Invert Level (m) 5.310 Cap Volume Depth (m) 0.400

Porous Car Park Manhole: S153, DS/PN: 37.000

Infiltration Coefficient Base (m/hr) 0.00000 Width (m) 10.0
Membrane Percolation (mm/hr) 1000 Length (m) 13.8
Max Percolation (l/s) 38.3 Slope (1:X) 100.0
Safety Factor 2.0 Depression Storage (mm) 5
Porosity 0.30 Evaporation (mm/day) 3
Invert Level (m) 5.360 Cap Volume Depth (m) 0.400

Porous Car Park Manhole: S154, DS/PN: 38.000

Infiltration Coefficient Base (m/hr) 0.00000 Width (m) 8.3
Membrane Percolation (mm/hr) 1000 Length (m) 10.0
Max Percolation (l/s) 23.1 Slope (1:X) 100.0
Safety Factor 2.0 Depression Storage (mm) 5
Porosity 0.30 Evaporation (mm/day) 3
Invert Level (m) 5.240 Cap Volume Depth (m) 0.400

Cellular Storage Manhole: S156, DS/PN: 19.021

Invert Level (m) 4.120 Safety Factor 2.0
Infiltration Coefficient Base (m/hr) 0.00000 Porosity 0.95
Infiltration Coefficient Side (m/hr) 0.00000

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	80.5	80.5	0.900	0.0	111.0
0.800	80.5	109.2			

Porous Car Park Manhole: S157, DS/PN: 19.022

Infiltration Coefficient Base (m/hr) 0.00000 Width (m) 10.0
Membrane Percolation (mm/hr) 1000 Length (m) 36.5
Max Percolation (l/s) 101.4 Slope (1:X) 100.0
Safety Factor 2.0 Depression Storage (mm) 5
Porosity 0.30 Evaporation (mm/day) 3
Invert Level (m) 5.025 Cap Volume Depth (m) 0.400

©1982-2018 Innovyze

RSK LDE		Page 69
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions Network 2018.1.1		

Porous Car Park Manhole: S158, DS/PN: 39.000

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0
Membrane Percolation (mm/hr)	1000	Length (m)	13.1
Max Percolation (l/s)	36.4	Slope (1:X)	100.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	5.140	Cap Volume Depth (m)	0.400

Complex Manhole: S164, DS/PN: 1.022

Cellular Storage

Invert Level (m)	3.835	Safety Factor	2.0
Infiltration Coefficient Base (m/hr)	0.00000	Porosity	0.95
Infiltration Coefficient Side (m/hr)	0.00000		

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	110.0	110.0	0.500	0.0	128.9
0.400	110.0	126.8			

Tank or Pond

Invert Level (m) 4.420

Depth (m)	Area (m ²)	Depth (m)	Area (m ²)
0.000	115.7	1.000	373.6

Complex Manhole: S166, DS/PN: 1.024

Tank or Pond

Invert Level (m) 4.200

Depth (m)	Area (m ²)	Depth (m)	Area (m ²)
0.000	184.2	1.000	508.0

Cellular Storage

Invert Level (m)	3.835	Safety Factor	2.0
Infiltration Coefficient Base (m/hr)	0.00000	Porosity	0.95
Infiltration Coefficient Side (m/hr)	0.00000		

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	225.5	225.5	0.500	0.0	252.5
0.400	225.5	249.5			

©1982-2018 Innovyze

RSK LDE		Page 70																																																																																																																														
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data																																																																																																																															
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by																																																																																																																															
XP Solutions	Network 2018.1.1																																																																																																																															
<u>Porous Car Park Manhole: S167, DS/PN: 41.000</u> <table><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Width (m)</td><td>8.4</td></tr><tr><td>Membrane Percolation (mm/hr)</td><td>1000</td><td>Length (m)</td><td>10.0</td></tr><tr><td>Max Percolation (l/s)</td><td>23.3</td><td>Slope (1:X)</td><td>100.0</td></tr><tr><td>Safety Factor</td><td>2.0</td><td>Depression Storage (mm)</td><td>5</td></tr><tr><td>Porosity</td><td>0.30</td><td>Evaporation (mm/day)</td><td>3</td></tr><tr><td>Invert Level (m)</td><td>4.992</td><td>Cap Volume Depth (m)</td><td>0.400</td></tr></table> <u>Porous Car Park Manhole: S168, DS/PN: 42.000</u> <table><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Width (m)</td><td>10.0</td></tr><tr><td>Membrane Percolation (mm/hr)</td><td>1000</td><td>Length (m)</td><td>13.1</td></tr><tr><td>Max Percolation (l/s)</td><td>36.4</td><td>Slope (1:X)</td><td>100.0</td></tr><tr><td>Safety Factor</td><td>2.0</td><td>Depression Storage (mm)</td><td>5</td></tr><tr><td>Porosity</td><td>0.30</td><td>Evaporation (mm/day)</td><td>3</td></tr><tr><td>Invert Level (m)</td><td>5.090</td><td>Cap Volume Depth (m)</td><td>0.400</td></tr></table> <u>Porous Car Park Manhole: S170, DS/PN: 43.000</u> <table><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Width (m)</td><td>10.0</td></tr><tr><td>Membrane Percolation (mm/hr)</td><td>1000</td><td>Length (m)</td><td>10.9</td></tr><tr><td>Max Percolation (l/s)</td><td>30.3</td><td>Slope (1:X)</td><td>100.0</td></tr><tr><td>Safety Factor</td><td>2.0</td><td>Depression Storage (mm)</td><td>5</td></tr><tr><td>Porosity</td><td>0.30</td><td>Evaporation (mm/day)</td><td>3</td></tr><tr><td>Invert Level (m)</td><td>5.020</td><td>Cap Volume Depth (m)</td><td>0.400</td></tr></table> <u>Porous Car Park Manhole: S175, DS/PN: 41.004</u> <table><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Width (m)</td><td>10.0</td></tr><tr><td>Membrane Percolation (mm/hr)</td><td>1000</td><td>Length (m)</td><td>23.6</td></tr><tr><td>Max Percolation (l/s)</td><td>65.6</td><td>Slope (1:X)</td><td>100.0</td></tr><tr><td>Safety Factor</td><td>2.0</td><td>Depression Storage (mm)</td><td>5</td></tr><tr><td>Porosity</td><td>0.30</td><td>Evaporation (mm/day)</td><td>3</td></tr><tr><td>Invert Level (m)</td><td>4.440</td><td>Cap Volume Depth (m)</td><td>0.400</td></tr></table> <u>Complex Manhole: S176, DS/PN: 1.025</u> <u>Cellular Storage</u> <table><tr><td>Invert Level (m)</td><td>3.720</td><td>Safety Factor</td><td>2.0</td></tr><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Porosity</td><td>0.95</td></tr><tr><td>Infiltration Coefficient Side (m/hr)</td><td>0.00000</td><td></td><td></td></tr></table> <table><tr><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th></tr><tr><td>0.000</td><td>201.5</td><td>201.5</td><td>0.500</td><td>0.0</td><td>227.1</td></tr><tr><td>0.400</td><td>201.5</td><td>224.2</td><td></td><td></td><td></td></tr></table>			Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	8.4	Membrane Percolation (mm/hr)	1000	Length (m)	10.0	Max Percolation (l/s)	23.3	Slope (1:X)	100.0	Safety Factor	2.0	Depression Storage (mm)	5	Porosity	0.30	Evaporation (mm/day)	3	Invert Level (m)	4.992	Cap Volume Depth (m)	0.400	Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0	Membrane Percolation (mm/hr)	1000	Length (m)	13.1	Max Percolation (l/s)	36.4	Slope (1:X)	100.0	Safety Factor	2.0	Depression Storage (mm)	5	Porosity	0.30	Evaporation (mm/day)	3	Invert Level (m)	5.090	Cap Volume Depth (m)	0.400	Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0	Membrane Percolation (mm/hr)	1000	Length (m)	10.9	Max Percolation (l/s)	30.3	Slope (1:X)	100.0	Safety Factor	2.0	Depression Storage (mm)	5	Porosity	0.30	Evaporation (mm/day)	3	Invert Level (m)	5.020	Cap Volume Depth (m)	0.400	Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0	Membrane Percolation (mm/hr)	1000	Length (m)	23.6	Max Percolation (l/s)	65.6	Slope (1:X)	100.0	Safety Factor	2.0	Depression Storage (mm)	5	Porosity	0.30	Evaporation (mm/day)	3	Invert Level (m)	4.440	Cap Volume Depth (m)	0.400	Invert Level (m)	3.720	Safety Factor	2.0	Infiltration Coefficient Base (m/hr)	0.00000	Porosity	0.95	Infiltration Coefficient Side (m/hr)	0.00000			Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)	0.000	201.5	201.5	0.500	0.0	227.1	0.400	201.5	224.2			
Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	8.4																																																																																																																													
Membrane Percolation (mm/hr)	1000	Length (m)	10.0																																																																																																																													
Max Percolation (l/s)	23.3	Slope (1:X)	100.0																																																																																																																													
Safety Factor	2.0	Depression Storage (mm)	5																																																																																																																													
Porosity	0.30	Evaporation (mm/day)	3																																																																																																																													
Invert Level (m)	4.992	Cap Volume Depth (m)	0.400																																																																																																																													
Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0																																																																																																																													
Membrane Percolation (mm/hr)	1000	Length (m)	13.1																																																																																																																													
Max Percolation (l/s)	36.4	Slope (1:X)	100.0																																																																																																																													
Safety Factor	2.0	Depression Storage (mm)	5																																																																																																																													
Porosity	0.30	Evaporation (mm/day)	3																																																																																																																													
Invert Level (m)	5.090	Cap Volume Depth (m)	0.400																																																																																																																													
Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0																																																																																																																													
Membrane Percolation (mm/hr)	1000	Length (m)	10.9																																																																																																																													
Max Percolation (l/s)	30.3	Slope (1:X)	100.0																																																																																																																													
Safety Factor	2.0	Depression Storage (mm)	5																																																																																																																													
Porosity	0.30	Evaporation (mm/day)	3																																																																																																																													
Invert Level (m)	5.020	Cap Volume Depth (m)	0.400																																																																																																																													
Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0																																																																																																																													
Membrane Percolation (mm/hr)	1000	Length (m)	23.6																																																																																																																													
Max Percolation (l/s)	65.6	Slope (1:X)	100.0																																																																																																																													
Safety Factor	2.0	Depression Storage (mm)	5																																																																																																																													
Porosity	0.30	Evaporation (mm/day)	3																																																																																																																													
Invert Level (m)	4.440	Cap Volume Depth (m)	0.400																																																																																																																													
Invert Level (m)	3.720	Safety Factor	2.0																																																																																																																													
Infiltration Coefficient Base (m/hr)	0.00000	Porosity	0.95																																																																																																																													
Infiltration Coefficient Side (m/hr)	0.00000																																																																																																																															
Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)																																																																																																																											
0.000	201.5	201.5	0.500	0.0	227.1																																																																																																																											
0.400	201.5	224.2																																																																																																																														
©1982-2018 Innovyze																																																																																																																																

RSK LDE		Page 71
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions	Network 2018.1.1	

Tank or Pond

Invert Level (m) 4.200

Depth (m)	Area (m ²)	Depth (m)	Area (m ²)
0.000	106.0	0.750	211.5

Complex Manhole: S177, DS/PN: 1.026

Filter Drain

Infiltration Coefficient Base (m/hr)	0.00000	Pipe Diameter (m)	0.300
Infiltration Coefficient Side (m/hr)	0.00000	Pipe Depth above Invert (m)	0.000
Safety Factor	2.0	Number of Pipes	1
Porosity	0.30	Slope (1:X)	0.0
Invert Level (m)	3.700	Cap Volume Depth (m)	0.450
Trench Width (m)	2.4	Cap Infiltration Depth (m)	0.000
Trench Length (m)	3.7		

Swale

Warning:- Volume should always be included unless the upstream pipe is being used for storage and/or as a carrier

Infiltration Coefficient Base (m/hr)	0.00000	Length (m)	3.7
Infiltration Coefficient Side (m/hr)	0.00000	Side Slope (1:X)	3.0
Safety Factor	2.0	Slope (1:X)	0.0
Porosity	1.00	Cap Volume Depth (m)	0.300
Invert Level (m)	4.150	Cap Infiltration Depth (m)	0.000
Base Width (m)	2.4	Include Swale Volume	Yes

Porous Car Park Manhole: S178, DS/PN: 45.000

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0
Membrane Percolation (mm/hr)	1000	Length (m)	20.9
Max Percolation (l/s)	58.1	Slope (1:X)	100.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	6.290	Cap Volume Depth (m)	0.400

Cellular Storage Manhole: S179, DS/PN: 45.001

Invert Level (m)	5.900	Safety Factor	2.0
Infiltration Coefficient Base (m/hr)	0.00000	Porosity	0.95
Infiltration Coefficient Side (m/hr)	0.00000		

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	55.0	55.0	0.500	0.0	68.3
0.400	55.0	66.9			

©1982-2018 Innovyze

RSK LDE		Page 72
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions Network 2018.1.1		

Porous Car Park Manhole: S183, DS/PN: 46.000

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0
Membrane Percolation (mm/hr)	1000	Length (m)	28.9
Max Percolation (l/s)	80.3	Slope (1:X)	100.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	6.129	Cap Volume Depth (m)	0.400

Porous Car Park Manhole: S186, DS/PN: 45.007

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0
Membrane Percolation (mm/hr)	1000	Length (m)	25.1
Max Percolation (l/s)	69.7	Slope (1:X)	100.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	5.940	Cap Volume Depth (m)	0.400

Complex Manhole: S188, DS/PN: 45.009

Cellular Storage

Invert Level (m)	4.850	Safety Factor	2.0
Infiltration Coefficient Base (m/hr)	0.00000	Porosity	0.95
Infiltration Coefficient Side (m/hr)	0.00000		

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	95.0	95.0	0.500	0.0	110.6
0.400	95.0	110.6			

Tank or Pond

Invert Level (m) 5.750

Depth (m)	Area (m ²)	Depth (m)	Area (m ²)
0.000	77.9	1.000	211.5

Complex Manhole: S190, DS/PN: 45.011

Filter Drain

Infiltration Coefficient Base (m/hr)	0.00000	Pipe Diameter (m)	0.300
Infiltration Coefficient Side (m/hr)	0.00000	Pipe Depth above Invert (m)	0.000
Safety Factor	2.0	Number of Pipes	1
Porosity	0.30	Slope (1:X)	0.0
Invert Level (m)	5.600	Cap Volume Depth (m)	1.000
Trench Width (m)	2.4	Cap Infiltration Depth (m)	0.000
Trench Length (m)	11.4		

©1982-2018 Innovyze

RSK LDE		Page 73
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions Network 2018.1.1		

Swale

Warning:- Volume should always be included unless the upstream pipe is being used for storage and/or as a carrier

Infiltration Coefficient Base (m/hr)	0.00000	Length (m)	11.4
Infiltration Coefficient Side (m/hr)	0.00000	Side Slope (1:X)	3.0
Safety Factor	2.0	Slope (1:X)	0.0
Porosity	1.00	Cap Volume Depth (m)	0.300
Invert Level (m)	6.600	Cap Infiltration Depth (m)	0.000
Base Width (m)	0.8	Include Swale Volume	Yes

Porous Car Park Manhole: S191, DS/PN: 47.000

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0
Membrane Percolation (mm/hr)	1000	Length (m)	17.0
Max Percolation (l/s)	47.2	Slope (1:X)	100.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	5.760	Cap Volume Depth (m)	0.400

Complex Manhole: S193, DS/PN: 45.012

Cellular Storage

Invert Level (m)	4.750	Safety Factor	2.0
Infiltration Coefficient Base (m/hr)	0.00000	Porosity	0.95
Infiltration Coefficient Side (m/hr)	0.00000		

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	25.0	25.0	0.500	0.0	33.0
0.400	25.0	33.0			

Filter Drain

Infiltration Coefficient Base (m/hr)	0.00000	Pipe Diameter (m)	0.300
Infiltration Coefficient Side (m/hr)	0.00000	Pipe Depth above Invert (m)	0.000
Safety Factor	2.0	Number of Pipes	1
Porosity	0.30	Slope (1:X)	0.0
Invert Level (m)	4.750	Cap Volume Depth (m)	1.000
Trench Width (m)	2.4	Cap Infiltration Depth (m)	0.000
Trench Length (m)	11.5		

Swale

Warning:- Volume should always be included unless the upstream pipe is being used for storage and/or as a carrier

Infiltration Coefficient Base (m/hr)	0.00000	Porosity	1.00
Infiltration Coefficient Side (m/hr)	0.00000	Invert Level (m)	5.900
Safety Factor	2.0	Base Width (m)	0.8

©1982-2018 Innovyze

RSK LDE		Page 74
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions Network 2018.1.1		

Swale

Length (m) 11.5 Cap Volume Depth (m) 0.300
 Side Slope (1:X) 3.0 Cap Infiltration Depth (m) 0.000
 Slope (1:X) 0.0 Include Swale Volume Yes

Complex Manhole: S194, DS/PN: 45.013

Filter Drain

Infiltration Coefficient Base (m/hr) 0.00000 Pipe Diameter (m) 0.225
 Infiltration Coefficient Side (m/hr) 0.00000 Pipe Depth above Invert (m) 0.000
 Safety Factor 2.0 Number of Pipes 1
 Porosity 0.30 Slope (1:X) 0.0
 Invert Level (m) 4.630 Cap Volume Depth (m) 1.000
 Trench Width (m) 2.4 Cap Infiltration Depth (m) 0.000
 Trench Length (m) 18.5

Swale

Warning:- Volume should always be included unless the upstream pipe is being used for storage and/or as a carrier

Infiltration Coefficient Base (m/hr) 0.00000 Length (m) 18.5
 Infiltration Coefficient Side (m/hr) 0.00000 Side Slope (1:X) 3.0
 Safety Factor 2.0 Slope (1:X) 0.0
 Porosity 1.00 Cap Volume Depth (m) 0.300
 Invert Level (m) 5.630 Cap Infiltration Depth (m) 0.000
 Base Width (m) 0.8 Include Swale Volume Yes

Porous Car Park Manhole: S195, DS/PN: 48.000

Infiltration Coefficient Base (m/hr) 0.00000 Width (m) 7.3
 Membrane Percolation (mm/hr) 1000 Length (m) 10.0
 Max Percolation (l/s) 20.3 Slope (1:X) 100.0
 Safety Factor 2.0 Depression Storage (mm) 5
 Porosity 0.30 Evaporation (mm/day) 3
 Invert Level (m) 6.004 Cap Volume Depth (m) 0.400

Porous Car Park Manhole: S196, DS/PN: 49.000

Infiltration Coefficient Base (m/hr) 0.00000 Width (m) 3.6
 Membrane Percolation (mm/hr) 1000 Length (m) 10.0
 Max Percolation (l/s) 10.0 Slope (1:X) 100.0
 Safety Factor 2.0 Depression Storage (mm) 5
 Porosity 0.30 Evaporation (mm/day) 3
 Invert Level (m) 6.090 Cap Volume Depth (m) 0.400

©1982-2018 Innovyze

RSK LDE		Page 75
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions Network 2018.1.1		

Complex Manhole: S201, DS/PN: 45.014

Cellular Storage

Invert Level (m) 4.500 Safety Factor 2.0
Infiltration Coefficient Base (m/hr) 0.00000 Porosity 0.95
Infiltration Coefficient Side (m/hr) 0.00000

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	42.0	42.0	0.500	0.0	52.4
0.400	42.0	52.4			

Filter Drain

Infiltration Coefficient Base (m/hr) 0.00000 Pipe Diameter (m) 0.300
Infiltration Coefficient Side (m/hr) 0.00000 Pipe Depth above Invert (m) 0.000
Safety Factor 2.0 Number of Pipes 1
Porosity 0.30 Slope (1:X) 0.0
Invert Level (m) 4.500 Cap Volume Depth (m) 1.350
Trench Width (m) 2.4 Cap Infiltration Depth (m) 0.000
Trench Length (m) 18.6

Swale

Warning:- Volume should always be included unless the upstream pipe is being used for storage and/or as a carrier

Infiltration Coefficient Base (m/hr) 0.00000 Length (m) 18.6
Infiltration Coefficient Side (m/hr) 0.00000 Side Slope (1:X) 3.0
Safety Factor 2.0 Slope (1:X) 0.0
Porosity 1.00 Cap Volume Depth (m) 0.300
Invert Level (m) 5.850 Cap Infiltration Depth (m) 0.000
Base Width (m) 0.8 Include Swale Volume Yes

Porous Car Park Manhole: S203, DS/PN: 50.001

Infiltration Coefficient Base (m/hr) 0.00000 Width (m) 10.0
Membrane Percolation (mm/hr) 1000 Length (m) 17.6
Max Percolation (l/s) 48.9 Slope (1:X) 100.0
Safety Factor 2.0 Depression Storage (mm) 5
Porosity 0.30 Evaporation (mm/day) 3
Invert Level (m) 5.390 Cap Volume Depth (m) 0.400

Complex Manhole: S206, DS/PN: 45.015

Cellular Storage

Invert Level (m) 4.450 Infiltration Coefficient Side (m/hr) 0.00000
Infiltration Coefficient Base (m/hr) 0.00000 Safety Factor 2.0

©1982-2018 Innovyze

RSK LDE		Page 76
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions Network 2018.1.1		

Cellular Storage

Porosity 0.95

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	45.5	45.5	0.500	0.0	56.3
0.400	45.5	56.3			

Filter Drain

Infiltration Coefficient Base (m/hr)	0.00000	Pipe Diameter (m)	0.300
Infiltration Coefficient Side (m/hr)	0.00000	Pipe Depth above Invert (m)	0.000
Safety Factor	2.0	Number of Pipes	1
Porosity	0.30	Slope (1:X)	0.0
Invert Level (m)	4.450	Cap Volume Depth (m)	1.000
Trench Width (m)	2.4	Cap Infiltration Depth (m)	0.000
Trench Length (m)	24.0		

Swale

Warning:- Volume should always be included unless the upstream pipe is being used for storage and/or as a carrier

Infiltration Coefficient Base (m/hr)	0.00000	Length (m)	24.0
Infiltration Coefficient Side (m/hr)	0.00000	Side Slope (1:X)	3.0
Safety Factor	2.0	Slope (1:X)	0.0
Porosity	1.00	Cap Volume Depth (m)	0.300
Invert Level (m)	5.450	Cap Infiltration Depth (m)	0.000
Base Width (m)	0.8	Include Swale Volume	Yes

Porous Car Park Manhole: S208a, DS/PN: 52.000

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0
Membrane Percolation (mm/hr)	1000	Length (m)	20.8
Max Percolation (l/s)	57.8	Slope (1:X)	100.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	6.615	Cap Volume Depth (m)	0.400

Porous Car Park Manhole: S211, DS/PN: 53.000

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0
Membrane Percolation (mm/hr)	1000	Length (m)	10.6
Max Percolation (l/s)	29.4	Slope (1:X)	100.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	6.390	Cap Volume Depth (m)	0.400

Porous Car Park Manhole: S213, DS/PN: 54.000

Infiltration Coefficient Base (m/hr)	0.00000	Max Percolation (l/s)	32.2
Membrane Percolation (mm/hr)	1000	Safety Factor	2.0

©1982-2018 Innovyze

RSK LDE		Page 77																																																																																																																												
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data																																																																																																																													
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by																																																																																																																													
XP Solutions	Network 2018.1.1																																																																																																																													
<u>Porous Car Park Manhole: S213, DS/PN: 54.000</u> <table><tr><td>Porosity</td><td>0.30</td><td>Slope (1:X)</td><td>100.0</td></tr><tr><td>Invert Level (m)</td><td>6.099</td><td>Depression Storage (mm)</td><td>5</td></tr><tr><td>Width (m)</td><td>10.0</td><td>Evaporation (mm/day)</td><td>3</td></tr><tr><td>Length (m)</td><td>11.6</td><td>Cap Volume Depth (m)</td><td>0.400</td></tr></table> <u>Porous Car Park Manhole: S215, DS/PN: 55.000</u> <table><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Width (m)</td><td>10.0</td></tr><tr><td>Membrane Percolation (mm/hr)</td><td>1000</td><td>Length (m)</td><td>33.2</td></tr><tr><td>Max Percolation (l/s)</td><td>92.2</td><td>Slope (1:X)</td><td>100.0</td></tr><tr><td>Safety Factor</td><td>2.0</td><td>Depression Storage (mm)</td><td>5</td></tr><tr><td>Porosity</td><td>0.30</td><td>Evaporation (mm/day)</td><td>3</td></tr><tr><td>Invert Level (m)</td><td>6.070</td><td>Cap Volume Depth (m)</td><td>0.400</td></tr></table> <u>Porous Car Park Manhole: S217, DS/PN: 56.000</u> <table><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Width (m)</td><td>10.0</td></tr><tr><td>Membrane Percolation (mm/hr)</td><td>1000</td><td>Length (m)</td><td>20.3</td></tr><tr><td>Max Percolation (l/s)</td><td>56.4</td><td>Slope (1:X)</td><td>100.0</td></tr><tr><td>Safety Factor</td><td>2.0</td><td>Depression Storage (mm)</td><td>5</td></tr><tr><td>Porosity</td><td>0.30</td><td>Evaporation (mm/day)</td><td>3</td></tr><tr><td>Invert Level (m)</td><td>5.369</td><td>Cap Volume Depth (m)</td><td>0.400</td></tr></table> <u>Porous Car Park Manhole: S218, DS/PN: 51.007</u> <table><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Width (m)</td><td>7.8</td></tr><tr><td>Membrane Percolation (mm/hr)</td><td>1000</td><td>Length (m)</td><td>10.0</td></tr><tr><td>Max Percolation (l/s)</td><td>21.7</td><td>Slope (1:X)</td><td>100.0</td></tr><tr><td>Safety Factor</td><td>2.0</td><td>Depression Storage (mm)</td><td>5</td></tr><tr><td>Porosity</td><td>0.30</td><td>Evaporation (mm/day)</td><td>3</td></tr><tr><td>Invert Level (m)</td><td>5.387</td><td>Cap Volume Depth (m)</td><td>0.400</td></tr></table> <u>Porous Car Park Manhole: S220, DS/PN: 51.009</u> <table><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Width (m)</td><td>10.0</td></tr><tr><td>Membrane Percolation (mm/hr)</td><td>1000</td><td>Length (m)</td><td>17.9</td></tr><tr><td>Max Percolation (l/s)</td><td>49.7</td><td>Slope (1:X)</td><td>100.0</td></tr><tr><td>Safety Factor</td><td>2.0</td><td>Depression Storage (mm)</td><td>5</td></tr><tr><td>Porosity</td><td>0.30</td><td>Evaporation (mm/day)</td><td>3</td></tr><tr><td>Invert Level (m)</td><td>5.056</td><td>Cap Volume Depth (m)</td><td>0.400</td></tr></table> <u>Complex Manhole: S222, DS/PN: 45.016</u> <u>Cellular Storage</u> <table><tr><td>Invert Level (m)</td><td>4.080</td><td>Safety Factor</td><td>2.0</td></tr><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Porosity</td><td>0.95</td></tr><tr><td>Infiltration Coefficient Side (m/hr)</td><td>0.00000</td><td></td><td></td></tr></table>			Porosity	0.30	Slope (1:X)	100.0	Invert Level (m)	6.099	Depression Storage (mm)	5	Width (m)	10.0	Evaporation (mm/day)	3	Length (m)	11.6	Cap Volume Depth (m)	0.400	Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0	Membrane Percolation (mm/hr)	1000	Length (m)	33.2	Max Percolation (l/s)	92.2	Slope (1:X)	100.0	Safety Factor	2.0	Depression Storage (mm)	5	Porosity	0.30	Evaporation (mm/day)	3	Invert Level (m)	6.070	Cap Volume Depth (m)	0.400	Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0	Membrane Percolation (mm/hr)	1000	Length (m)	20.3	Max Percolation (l/s)	56.4	Slope (1:X)	100.0	Safety Factor	2.0	Depression Storage (mm)	5	Porosity	0.30	Evaporation (mm/day)	3	Invert Level (m)	5.369	Cap Volume Depth (m)	0.400	Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	7.8	Membrane Percolation (mm/hr)	1000	Length (m)	10.0	Max Percolation (l/s)	21.7	Slope (1:X)	100.0	Safety Factor	2.0	Depression Storage (mm)	5	Porosity	0.30	Evaporation (mm/day)	3	Invert Level (m)	5.387	Cap Volume Depth (m)	0.400	Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0	Membrane Percolation (mm/hr)	1000	Length (m)	17.9	Max Percolation (l/s)	49.7	Slope (1:X)	100.0	Safety Factor	2.0	Depression Storage (mm)	5	Porosity	0.30	Evaporation (mm/day)	3	Invert Level (m)	5.056	Cap Volume Depth (m)	0.400	Invert Level (m)	4.080	Safety Factor	2.0	Infiltration Coefficient Base (m/hr)	0.00000	Porosity	0.95	Infiltration Coefficient Side (m/hr)	0.00000		
Porosity	0.30	Slope (1:X)	100.0																																																																																																																											
Invert Level (m)	6.099	Depression Storage (mm)	5																																																																																																																											
Width (m)	10.0	Evaporation (mm/day)	3																																																																																																																											
Length (m)	11.6	Cap Volume Depth (m)	0.400																																																																																																																											
Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0																																																																																																																											
Membrane Percolation (mm/hr)	1000	Length (m)	33.2																																																																																																																											
Max Percolation (l/s)	92.2	Slope (1:X)	100.0																																																																																																																											
Safety Factor	2.0	Depression Storage (mm)	5																																																																																																																											
Porosity	0.30	Evaporation (mm/day)	3																																																																																																																											
Invert Level (m)	6.070	Cap Volume Depth (m)	0.400																																																																																																																											
Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0																																																																																																																											
Membrane Percolation (mm/hr)	1000	Length (m)	20.3																																																																																																																											
Max Percolation (l/s)	56.4	Slope (1:X)	100.0																																																																																																																											
Safety Factor	2.0	Depression Storage (mm)	5																																																																																																																											
Porosity	0.30	Evaporation (mm/day)	3																																																																																																																											
Invert Level (m)	5.369	Cap Volume Depth (m)	0.400																																																																																																																											
Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	7.8																																																																																																																											
Membrane Percolation (mm/hr)	1000	Length (m)	10.0																																																																																																																											
Max Percolation (l/s)	21.7	Slope (1:X)	100.0																																																																																																																											
Safety Factor	2.0	Depression Storage (mm)	5																																																																																																																											
Porosity	0.30	Evaporation (mm/day)	3																																																																																																																											
Invert Level (m)	5.387	Cap Volume Depth (m)	0.400																																																																																																																											
Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0																																																																																																																											
Membrane Percolation (mm/hr)	1000	Length (m)	17.9																																																																																																																											
Max Percolation (l/s)	49.7	Slope (1:X)	100.0																																																																																																																											
Safety Factor	2.0	Depression Storage (mm)	5																																																																																																																											
Porosity	0.30	Evaporation (mm/day)	3																																																																																																																											
Invert Level (m)	5.056	Cap Volume Depth (m)	0.400																																																																																																																											
Invert Level (m)	4.080	Safety Factor	2.0																																																																																																																											
Infiltration Coefficient Base (m/hr)	0.00000	Porosity	0.95																																																																																																																											
Infiltration Coefficient Side (m/hr)	0.00000																																																																																																																													
©1982-2018 Innovyze																																																																																																																														

RSK LDE		Page 78
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions Network 2018.1.1		

Cellular Storage

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	54.0	54.0	0.900	0.0	79.0
0.800	54.0	77.5			

Filter Drain

Infiltration Coefficient Base (m/hr)	0.00000	Pipe Diameter (m)	0.300
Infiltration Coefficient Side (m/hr)	0.00000	Pipe Depth above Invert (m)	0.000
Safety Factor	2.0	Number of Pipes	1
Porosity	0.30	Slope (1:X)	0.0
Invert Level (m)	4.080	Cap Volume Depth (m)	1.000
Trench Width (m)	2.4	Cap Infiltration Depth (m)	0.000
Trench Length (m)	22.4		

Swale

Warning:- Volume should always be included unless the upstream pipe is being used for storage and/or as a carrier

Infiltration Coefficient Base (m/hr)	0.00000	Length (m)	22.4
Infiltration Coefficient Side (m/hr)	0.00000	Side Slope (1:X)	3.0
Safety Factor	2.0	Slope (1:X)	0.0
Porosity	1.00	Cap Volume Depth (m)	0.300
Invert Level (m)	5.200	Cap Infiltration Depth (m)	0.000
Base Width (m)	1.0	Include Swale Volume	Yes

Complex Manhole: S225, DS/PN: 45.017

Cellular Storage

Invert Level (m)	4.080	Safety Factor	2.0
Infiltration Coefficient Base (m/hr)	0.00000	Porosity	0.95
Infiltration Coefficient Side (m/hr)	0.00000		

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	54.0	54.0	0.900	0.0	79.0
0.800	54.0	77.5			

Filter Drain

Infiltration Coefficient Base (m/hr)	0.00000	Pipe Diameter (m)	0.300
Infiltration Coefficient Side (m/hr)	0.00000	Pipe Depth above Invert (m)	0.000
Safety Factor	2.0	Number of Pipes	1
Porosity	0.30	Slope (1:X)	0.0
Invert Level (m)	4.080	Cap Volume Depth (m)	1.000
Trench Width (m)	2.4	Cap Infiltration Depth (m)	0.000
Trench Length (m)	22.5		

©1982-2018 Innovyze

RSK LDE		Page 79
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions Network 2018.1.1		

Swale

Warning:- Volume should always be included unless the upstream pipe is being used for storage and/or as a carrier

Infiltration Coefficient Base (m/hr)	0.00000	Length (m)	22.5
Infiltration Coefficient Side (m/hr)	0.00000	Side Slope (1:X)	3.0
Safety Factor	2.0	Slope (1:X)	0.0
Porosity	1.00	Cap Volume Depth (m)	0.300
Invert Level (m)	5.200	Cap Infiltration Depth (m)	0.000
Base Width (m)	0.8	Include Swale Volume	Yes

Porous Car Park Manhole: S227, DS/PN: 58.001

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0
Membrane Percolation (mm/hr)	1000	Length (m)	16.8
Max Percolation (l/s)	46.7	Slope (1:X)	100.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	4.790	Cap Volume Depth (m)	0.400

Porous Car Park Manhole: S228, DS/PN: 58.002

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0
Membrane Percolation (mm/hr)	1000	Length (m)	27.9
Max Percolation (l/s)	77.5	Slope (1:X)	100.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	4.790	Cap Volume Depth (m)	0.400

Complex Manhole: S230, DS/PN: 45.018

Cellular Storage

Invert Level (m)	4.060	Safety Factor	2.0
Infiltration Coefficient Base (m/hr)	0.00000	Porosity	0.95
Infiltration Coefficient Side (m/hr)	0.00000		

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	42.0	42.0	0.500	0.0	53.7
0.400	42.0	52.4			

Filter Drain

Infiltration Coefficient Base (m/hr)	0.00000	Pipe Diameter (m)	0.300
Infiltration Coefficient Side (m/hr)	0.00000	Pipe Depth above Invert (m)	0.000
Safety Factor	2.0	Number of Pipes	1
Porosity	0.30	Slope (1:X)	0.0
Invert Level (m)	4.060	Cap Volume Depth (m)	1.000
Trench Width (m)	2.4	Cap Infiltration Depth (m)	0.000
Trench Length (m)	25.5		

©1982-2018 Innovyze

RSK LDE		Page 80
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions Network 2018.1.1		

Swale

Warning:- Volume should always be included unless the upstream pipe is being used for storage and/or as a carrier

Infiltration Coefficient Base (m/hr)	0.00000	Length (m)	25.5
Infiltration Coefficient Side (m/hr)	0.00000	Side Slope (1:X)	3.0
Safety Factor	2.0	Slope (1:X)	0.0
Porosity	1.00	Cap Volume Depth (m)	0.300
Invert Level (m)	4.950	Cap Infiltration Depth (m)	0.000
Base Width (m)	0.8	Include Swale Volume	Yes

Complex Manhole: S232, DS/PN: 45.020

Filter Drain

Infiltration Coefficient Base (m/hr)	0.00000	Pipe Diameter (m)	0.300
Infiltration Coefficient Side (m/hr)	0.00000	Pipe Depth above Invert (m)	0.000
Safety Factor	2.0	Number of Pipes	1
Porosity	0.30	Slope (1:X)	0.0
Invert Level (m)	3.950	Cap Volume Depth (m)	0.900
Trench Width (m)	2.4	Cap Infiltration Depth (m)	0.000
Trench Length (m)	28.2		

Swale

Warning:- Volume should always be included unless the upstream pipe is being used for storage and/or as a carrier

Infiltration Coefficient Base (m/hr)	0.00000	Length (m)	28.2
Infiltration Coefficient Side (m/hr)	0.00000	Side Slope (1:X)	4.0
Safety Factor	2.0	Slope (1:X)	0.0
Porosity	1.00	Cap Volume Depth (m)	0.300
Invert Level (m)	4.850	Cap Infiltration Depth (m)	0.000
Base Width (m)	0.8	Include Swale Volume	Yes

Complex Manhole: S233, DS/PN: 45.021

Filter Drain

Infiltration Coefficient Base (m/hr)	0.00000	Pipe Diameter (m)	0.300
Infiltration Coefficient Side (m/hr)	0.00000	Pipe Depth above Invert (m)	0.000
Safety Factor	2.0	Number of Pipes	1
Porosity	0.30	Slope (1:X)	0.0
Invert Level (m)	3.900	Cap Volume Depth (m)	0.950
Trench Width (m)	2.4	Cap Infiltration Depth (m)	0.000
Trench Length (m)	10.4		

©1982-2018 Innovyze

RSK LDE		Page 81																																																																																																																								
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data																																																																																																																									
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by																																																																																																																									
XP Solutions	Network 2018.1.1																																																																																																																									
Swale Warning:- Volume should always be included unless the upstream pipe is being used for storage and/or as a carrier <table><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Length (m)</td><td>10.4</td></tr><tr><td>Infiltration Coefficient Side (m/hr)</td><td>0.00000</td><td>Side Slope (1:X)</td><td>3.0</td></tr><tr><td>Safety Factor</td><td>2.0</td><td>Slope (1:X)</td><td>0.0</td></tr><tr><td>Porosity</td><td>1.00</td><td>Cap Volume Depth (m)</td><td>0.300</td></tr><tr><td>Invert Level (m)</td><td>4.850</td><td>Cap Infiltration Depth (m)</td><td>0.000</td></tr><tr><td>Base Width (m)</td><td>0.8</td><td>Include Swale Volume</td><td>Yes</td></tr></table> Porous Car Park Manhole: S235, DS/PN: 59.001 <table><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Width (m)</td><td>10.0</td></tr><tr><td>Membrane Percolation (mm/hr)</td><td>1000</td><td>Length (m)</td><td>14.9</td></tr><tr><td>Max Percolation (l/s)</td><td>41.4</td><td>Slope (1:X)</td><td>100.0</td></tr><tr><td>Safety Factor</td><td>2.0</td><td>Depression Storage (mm)</td><td>5</td></tr><tr><td>Porosity</td><td>0.30</td><td>Evaporation (mm/day)</td><td>3</td></tr><tr><td>Invert Level (m)</td><td>5.440</td><td>Cap Volume Depth (m)</td><td>0.400</td></tr></table> Porous Car Park Manhole: S236, DS/PN: 60.000 <table><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Width (m)</td><td>5.5</td></tr><tr><td>Membrane Percolation (mm/hr)</td><td>1000</td><td>Length (m)</td><td>10.0</td></tr><tr><td>Max Percolation (l/s)</td><td>15.3</td><td>Slope (1:X)</td><td>100.0</td></tr><tr><td>Safety Factor</td><td>2.0</td><td>Depression Storage (mm)</td><td>5</td></tr><tr><td>Porosity</td><td>0.30</td><td>Evaporation (mm/day)</td><td>3</td></tr><tr><td>Invert Level (m)</td><td>5.570</td><td>Cap Volume Depth (m)</td><td>0.400</td></tr></table> Porous Car Park Manhole: S238, DS/PN: 61.000 <table><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Width (m)</td><td>10.0</td></tr><tr><td>Membrane Percolation (mm/hr)</td><td>1000</td><td>Length (m)</td><td>10.0</td></tr><tr><td>Max Percolation (l/s)</td><td>27.8</td><td>Slope (1:X)</td><td>100.0</td></tr><tr><td>Safety Factor</td><td>2.0</td><td>Depression Storage (mm)</td><td>5</td></tr><tr><td>Porosity</td><td>0.30</td><td>Evaporation (mm/day)</td><td>3</td></tr><tr><td>Invert Level (m)</td><td>5.590</td><td>Cap Volume Depth (m)</td><td>0.400</td></tr></table> Porous Car Park Manhole: S242, DS/PN: 62.000 <table><tr><td>Infiltration Coefficient Base (m/hr)</td><td>0.00000</td><td>Width (m)</td><td>10.0</td></tr><tr><td>Membrane Percolation (mm/hr)</td><td>1000</td><td>Length (m)</td><td>11.3</td></tr><tr><td>Max Percolation (l/s)</td><td>31.4</td><td>Slope (1:X)</td><td>100.0</td></tr><tr><td>Safety Factor</td><td>2.0</td><td>Depression Storage (mm)</td><td>5</td></tr><tr><td>Porosity</td><td>0.30</td><td>Evaporation (mm/day)</td><td>3</td></tr><tr><td>Invert Level (m)</td><td>4.840</td><td>Cap Volume Depth (m)</td><td>0.400</td></tr></table> Complex Manhole: S246, DS/PN: 45.022			Infiltration Coefficient Base (m/hr)	0.00000	Length (m)	10.4	Infiltration Coefficient Side (m/hr)	0.00000	Side Slope (1:X)	3.0	Safety Factor	2.0	Slope (1:X)	0.0	Porosity	1.00	Cap Volume Depth (m)	0.300	Invert Level (m)	4.850	Cap Infiltration Depth (m)	0.000	Base Width (m)	0.8	Include Swale Volume	Yes	Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0	Membrane Percolation (mm/hr)	1000	Length (m)	14.9	Max Percolation (l/s)	41.4	Slope (1:X)	100.0	Safety Factor	2.0	Depression Storage (mm)	5	Porosity	0.30	Evaporation (mm/day)	3	Invert Level (m)	5.440	Cap Volume Depth (m)	0.400	Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	5.5	Membrane Percolation (mm/hr)	1000	Length (m)	10.0	Max Percolation (l/s)	15.3	Slope (1:X)	100.0	Safety Factor	2.0	Depression Storage (mm)	5	Porosity	0.30	Evaporation (mm/day)	3	Invert Level (m)	5.570	Cap Volume Depth (m)	0.400	Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0	Membrane Percolation (mm/hr)	1000	Length (m)	10.0	Max Percolation (l/s)	27.8	Slope (1:X)	100.0	Safety Factor	2.0	Depression Storage (mm)	5	Porosity	0.30	Evaporation (mm/day)	3	Invert Level (m)	5.590	Cap Volume Depth (m)	0.400	Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0	Membrane Percolation (mm/hr)	1000	Length (m)	11.3	Max Percolation (l/s)	31.4	Slope (1:X)	100.0	Safety Factor	2.0	Depression Storage (mm)	5	Porosity	0.30	Evaporation (mm/day)	3	Invert Level (m)	4.840	Cap Volume Depth (m)	0.400
Infiltration Coefficient Base (m/hr)	0.00000	Length (m)	10.4																																																																																																																							
Infiltration Coefficient Side (m/hr)	0.00000	Side Slope (1:X)	3.0																																																																																																																							
Safety Factor	2.0	Slope (1:X)	0.0																																																																																																																							
Porosity	1.00	Cap Volume Depth (m)	0.300																																																																																																																							
Invert Level (m)	4.850	Cap Infiltration Depth (m)	0.000																																																																																																																							
Base Width (m)	0.8	Include Swale Volume	Yes																																																																																																																							
Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0																																																																																																																							
Membrane Percolation (mm/hr)	1000	Length (m)	14.9																																																																																																																							
Max Percolation (l/s)	41.4	Slope (1:X)	100.0																																																																																																																							
Safety Factor	2.0	Depression Storage (mm)	5																																																																																																																							
Porosity	0.30	Evaporation (mm/day)	3																																																																																																																							
Invert Level (m)	5.440	Cap Volume Depth (m)	0.400																																																																																																																							
Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	5.5																																																																																																																							
Membrane Percolation (mm/hr)	1000	Length (m)	10.0																																																																																																																							
Max Percolation (l/s)	15.3	Slope (1:X)	100.0																																																																																																																							
Safety Factor	2.0	Depression Storage (mm)	5																																																																																																																							
Porosity	0.30	Evaporation (mm/day)	3																																																																																																																							
Invert Level (m)	5.570	Cap Volume Depth (m)	0.400																																																																																																																							
Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0																																																																																																																							
Membrane Percolation (mm/hr)	1000	Length (m)	10.0																																																																																																																							
Max Percolation (l/s)	27.8	Slope (1:X)	100.0																																																																																																																							
Safety Factor	2.0	Depression Storage (mm)	5																																																																																																																							
Porosity	0.30	Evaporation (mm/day)	3																																																																																																																							
Invert Level (m)	5.590	Cap Volume Depth (m)	0.400																																																																																																																							
Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	10.0																																																																																																																							
Membrane Percolation (mm/hr)	1000	Length (m)	11.3																																																																																																																							
Max Percolation (l/s)	31.4	Slope (1:X)	100.0																																																																																																																							
Safety Factor	2.0	Depression Storage (mm)	5																																																																																																																							
Porosity	0.30	Evaporation (mm/day)	3																																																																																																																							
Invert Level (m)	4.840	Cap Volume Depth (m)	0.400																																																																																																																							
©1982-2018 Innovyze																																																																																																																										

RSK LDE		Page 82
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions Network 2018.1.1		

Cellular Storage

Invert Level (m) 3.750 Safety Factor 2.0
Infiltration Coefficient Base (m/hr) 0.00000 Porosity 0.95
Infiltration Coefficient Side (m/hr) 0.00000

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	102.0	102.0	0.900	0.0	136.3
0.800	102.0	134.3			

Swale

Warning:- Volume should always be included unless the upstream pipe is being used for storage and/or as a carrier

Infiltration Coefficient Base (m/hr) 0.00000 Length (m) 12.6
Infiltration Coefficient Side (m/hr) 0.00000 Side Slope (1:X) 3.0
Safety Factor 2.0 Slope (1:X) 0.0
Porosity 1.00 Cap Volume Depth (m) 0.300
Invert Level (m) 4.700 Cap Infiltration Depth (m) 0.000
Base Width (m) 0.8 Include Swale Volume Yes

Filter Drain

Infiltration Coefficient Base (m/hr) 0.00000 Pipe Diameter (m) 0.300
Infiltration Coefficient Side (m/hr) 0.00000 Pipe Depth above Invert (m) 0.000
Safety Factor 2.0 Number of Pipes 1
Porosity 0.30 Slope (1:X) 0.0
Invert Level (m) 4.750 Cap Volume Depth (m) 0.950
Trench Width (m) 2.4 Cap Infiltration Depth (m) 0.000
Trench Length (m) 12.6

Porous Car Park Manhole: S247, DS/PN: 63.000

Infiltration Coefficient Base (m/hr) 0.00000 Width (m) 10.0
Membrane Percolation (mm/hr) 1000 Length (m) 21.8
Max Percolation (l/s) 60.6 Slope (1:X) 100.0
Safety Factor 2.0 Depression Storage (mm) 5
Porosity 0.30 Evaporation (mm/day) 3
Invert Level (m) 4.640 Cap Volume Depth (m) 0.400

Complex Manhole: S248, DS/PN: 63.001

Cellular Storage

Invert Level (m) 4.250 Safety Factor 2.0
Infiltration Coefficient Base (m/hr) 0.00000 Porosity 0.95
Infiltration Coefficient Side (m/hr) 0.00000

©1982-2018 Innovyze

RSK LDE		Page 83
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by	
XP Solutions Network 2018.1.1		

Cellular Storage

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	20.0	20.0	0.500	0.0	28.0
0.400	20.0	27.2			

Complex Manhole: S249, DS/PN: 45.023

Filter Drain

Infiltration Coefficient Base (m/hr)	0.00000	Pipe Diameter (m)	0.300
Infiltration Coefficient Side (m/hr)	0.00000	Pipe Depth above Invert (m)	0.000
Safety Factor	2.0	Number of Pipes	1
Porosity	0.30	Slope (1:X)	0.0
Invert Level (m)	3.750	Cap Volume Depth (m)	0.450
Trench Width (m)	2.4	Cap Infiltration Depth (m)	0.000
Trench Length (m)	33.0		

Swale

Warning:- Volume should always be included unless the upstream pipe is being used for storage and/or as a carrier

Infiltration Coefficient Base (m/hr)	0.00000	Length (m)	33.0
Infiltration Coefficient Side (m/hr)	0.00000	Side Slope (1:X)	3.0
Safety Factor	2.0	Slope (1:X)	0.0
Porosity	1.00	Cap Volume Depth (m)	0.300
Invert Level (m)	4.200	Cap Infiltration Depth (m)	0.000
Base Width (m)	0.8	Include Swale Volume	Yes

Complex Manhole: S250, DS/PN: 1.027

Tank or Pond

Invert Level (m) 3.700

Depth (m)	Area (m ²)	Depth (m)	Area (m ²)
0.000	178.0	0.750	326.9

Cellular Storage

Invert Level (m)	3.700	Safety Factor	2.0
Infiltration Coefficient Base (m/hr)	0.00000	Porosity	0.95
Infiltration Coefficient Side (m/hr)	0.00000		

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	250.0	0.0	0.400	250.0	0.0

©1982-2018 Innovyze

RSK LDE		Page 84																																																																																																																																									
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT																																																																																																																																											
Drove Lane, Yapton Surface Water Network Calculations - FEH Data																																																																																																																																											
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...																																																																																																																																											
Designed by AMuthusami Checked by																																																																																																																																											
XP Solutions		Network 2018.1.1																																																																																																																																									
Cellular Storage <table><thead><tr><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th></tr></thead><tbody><tr><td>0.500</td><td>0.0</td><td>0.0</td><td></td><td></td><td></td></tr></tbody></table> Time Area Diagram at Pipe Number 2.000 for Surface Network 1 Total Area (ha) 0.044 <table><thead><tr><th>Time (mins)</th><th>Area (ha)</th><th>Time (mins)</th><th>Area (ha)</th><th>Time (mins)</th><th>Area (ha)</th></tr><tr><th>From:</th><th>To:</th><th>From:</th><th>To:</th><th>From:</th><th>To:</th></tr></thead><tbody><tr><td>0</td><td>4</td><td>0.000</td><td>4</td><td>8</td><td>0.000</td></tr><tr><td></td><td></td><td></td><td></td><td>8</td><td>12</td><td>0.044</td></tr></tbody></table> Time Area Diagram at Pipe Number 3.000 for Surface Network 1 Total Area (ha) 0.012 <table><thead><tr><th>Time (mins)</th><th>Area (ha)</th><th>Time (mins)</th><th>Area (ha)</th><th>Time (mins)</th><th>Area (ha)</th></tr><tr><th>From:</th><th>To:</th><th>From:</th><th>To:</th><th>From:</th><th>To:</th></tr></thead><tbody><tr><td>0</td><td>4</td><td>0.000</td><td>4</td><td>8</td><td>0.000</td></tr><tr><td></td><td></td><td></td><td></td><td>8</td><td>12</td><td>0.012</td></tr></tbody></table> Time Area Diagram at Pipe Number 3.006 for Surface Network 1 Total Area (ha) 0.006 <table><thead><tr><th>Time (mins)</th><th>Area (ha)</th><th>Time (mins)</th><th>Area (ha)</th><th>Time (mins)</th><th>Area (ha)</th></tr><tr><th>From:</th><th>To:</th><th>From:</th><th>To:</th><th>From:</th><th>To:</th></tr></thead><tbody><tr><td>0</td><td>4</td><td>0.000</td><td>4</td><td>8</td><td>0.000</td></tr><tr><td></td><td></td><td></td><td></td><td>8</td><td>12</td><td>0.006</td></tr></tbody></table> Time Area Diagram at Pipe Number 5.002 for Surface Network 1 Total Area (ha) 0.028 <table><thead><tr><th>Time (mins)</th><th>Area (ha)</th><th>Time (mins)</th><th>Area (ha)</th><th>Time (mins)</th><th>Area (ha)</th></tr><tr><th>From:</th><th>To:</th><th>From:</th><th>To:</th><th>From:</th><th>To:</th></tr></thead><tbody><tr><td>0</td><td>4</td><td>0.000</td><td>4</td><td>8</td><td>0.000</td></tr><tr><td></td><td></td><td></td><td></td><td>8</td><td>12</td><td>0.028</td></tr></tbody></table> Time Area Diagram at Pipe Number 6.000 for Surface Network 1 Total Area (ha) 0.056 <table><thead><tr><th>Time (mins)</th><th>Area (ha)</th><th>Time (mins)</th><th>Area (ha)</th><th>Time (mins)</th><th>Area (ha)</th></tr><tr><th>From:</th><th>To:</th><th>From:</th><th>To:</th><th>From:</th><th>To:</th></tr></thead><tbody><tr><td>0</td><td>4</td><td>0.000</td><td>4</td><td>8</td><td>0.000</td></tr><tr><td></td><td></td><td></td><td></td><td>8</td><td>12</td><td>0.056</td></tr></tbody></table>			Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)	0.500	0.0	0.0				Time (mins)	Area (ha)	Time (mins)	Area (ha)	Time (mins)	Area (ha)	From:	To:	From:	To:	From:	To:	0	4	0.000	4	8	0.000					8	12	0.044	Time (mins)	Area (ha)	Time (mins)	Area (ha)	Time (mins)	Area (ha)	From:	To:	From:	To:	From:	To:	0	4	0.000	4	8	0.000					8	12	0.012	Time (mins)	Area (ha)	Time (mins)	Area (ha)	Time (mins)	Area (ha)	From:	To:	From:	To:	From:	To:	0	4	0.000	4	8	0.000					8	12	0.006	Time (mins)	Area (ha)	Time (mins)	Area (ha)	Time (mins)	Area (ha)	From:	To:	From:	To:	From:	To:	0	4	0.000	4	8	0.000					8	12	0.028	Time (mins)	Area (ha)	Time (mins)	Area (ha)	Time (mins)	Area (ha)	From:	To:	From:	To:	From:	To:	0	4	0.000	4	8	0.000					8	12	0.056
Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)																																																																																																																																						
0.500	0.0	0.0																																																																																																																																									
Time (mins)	Area (ha)	Time (mins)	Area (ha)	Time (mins)	Area (ha)																																																																																																																																						
From:	To:	From:	To:	From:	To:																																																																																																																																						
0	4	0.000	4	8	0.000																																																																																																																																						
				8	12	0.044																																																																																																																																					
Time (mins)	Area (ha)	Time (mins)	Area (ha)	Time (mins)	Area (ha)																																																																																																																																						
From:	To:	From:	To:	From:	To:																																																																																																																																						
0	4	0.000	4	8	0.000																																																																																																																																						
				8	12	0.012																																																																																																																																					
Time (mins)	Area (ha)	Time (mins)	Area (ha)	Time (mins)	Area (ha)																																																																																																																																						
From:	To:	From:	To:	From:	To:																																																																																																																																						
0	4	0.000	4	8	0.000																																																																																																																																						
				8	12	0.006																																																																																																																																					
Time (mins)	Area (ha)	Time (mins)	Area (ha)	Time (mins)	Area (ha)																																																																																																																																						
From:	To:	From:	To:	From:	To:																																																																																																																																						
0	4	0.000	4	8	0.000																																																																																																																																						
				8	12	0.028																																																																																																																																					
Time (mins)	Area (ha)	Time (mins)	Area (ha)	Time (mins)	Area (ha)																																																																																																																																						
From:	To:	From:	To:	From:	To:																																																																																																																																						
0	4	0.000	4	8	0.000																																																																																																																																						
				8	12	0.056																																																																																																																																					
©1982-2018 Innovyze																																																																																																																																											

RSK LDE		Page 85
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT		Drove Lane, Yapton Surface Water Network Calculations - FEH Data
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...		Designed by AMuthusami Checked by
XP Solutions		Network 2018.1.1

Time Area Diagram at Pipe Number 3.009 for Surface Network 1

Total Area (ha) 0.012

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)
0 4 0.000	4 8 0.000	8 12 0.012			

Time Area Diagram at Pipe Number 3.010 for Surface Network 1

Total Area (ha) 0.013

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)
0 4 0.000	4 8 0.000	8 12 0.013			

Time Area Diagram at Pipe Number 7.000 for Surface Network 1

Total Area (ha) 0.027

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)
0 4 0.000	4 8 0.000	8 12 0.027			

Time Area Diagram at Pipe Number 8.000 for Surface Network 1

Total Area (ha) 0.042

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)
0 4 0.000	4 8 0.000	8 12 0.042			

Time Area Diagram at Pipe Number 9.000 for Surface Network 1

Total Area (ha) 0.043

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)
0 4 0.000	4 8 0.000	8 12 0.043			

Time Area Diagram at Pipe Number 10.007 for Surface Network 1

Total Area (ha) 0.011

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)
0 4 0.000	4 8 0.000	8 12 0.011			

©1982-2018 Innovyze

RSK LDE		Page 86
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT		
Drove Lane, Yapton Surface Water Network Calculations - FEH Data		
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...		
Designed by AMuthusami Checked by		
XP Solutions		Network 2018.1.1

Time Area Diagram at Pipe Number 1.012 for Surface Network 1

Total Area (ha) 0.072

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)
0 4 0.000	4 8 0.036	8 12 0.036			

Time Area Diagram at Pipe Number 12.000 for Surface Network 1

Total Area (ha) 0.022

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)
0 4 0.000	4 8 0.000	8 12 0.022			

Time Area Diagram at Pipe Number 13.000 for Surface Network 1

Total Area (ha) 0.004

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)
0 4 0.000	4 8 0.000	8 12 0.004			

Time Area Diagram at Pipe Number 13.002 for Surface Network 1

Total Area (ha) 0.018

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)
0 4 0.000	4 8 0.000	8 12 0.018			

Time Area Diagram at Pipe Number 14.000 for Surface Network 1

Total Area (ha) 0.035

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)
0 4 0.000	4 8 0.000	8 12 0.035			

Time Area Diagram at Pipe Number 15.000 for Surface Network 1

Total Area (ha) 0.017

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)
0 4 0.000	4 8 0.000	8 12 0.017			

©1982-2018 Innovyze

RSK LDE		Page 87																		
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT																				
Drove Lane, Yapton Surface Water Network Calculations - FEH Data																				
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...																				
Designed by AMuthusami Checked by																				
XP Solutions		Network 2018.1.1																		
<u>Time Area Diagram at Pipe Number 14.002 for Surface Network 1</u>																				
Total Area (ha) 0.040																				
<table><tr><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td></tr><tr><td>From: To:</td><td>(ha)</td><td>From: To:</td><td>(ha)</td><td>From: To:</td><td>(ha)</td></tr><tr><td>0 4</td><td>0.000</td><td>4 8</td><td>0.000</td><td>8 12</td><td>0.040</td></tr></table>			Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To:	(ha)	From: To:	(ha)	From: To:	(ha)	0 4	0.000	4 8	0.000	8 12	0.040
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area															
From: To:	(ha)	From: To:	(ha)	From: To:	(ha)															
0 4	0.000	4 8	0.000	8 12	0.040															
<u>Time Area Diagram at Pipe Number 14.003 for Surface Network 1</u>																				
Total Area (ha) 0.025																				
<table><tr><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td></tr><tr><td>From: To:</td><td>(ha)</td><td>From: To:</td><td>(ha)</td><td>From: To:</td><td>(ha)</td></tr><tr><td>0 4</td><td>0.000</td><td>4 8</td><td>0.000</td><td>8 12</td><td>0.025</td></tr></table>			Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To:	(ha)	From: To:	(ha)	From: To:	(ha)	0 4	0.000	4 8	0.000	8 12	0.025
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area															
From: To:	(ha)	From: To:	(ha)	From: To:	(ha)															
0 4	0.000	4 8	0.000	8 12	0.025															
<u>Time Area Diagram at Pipe Number 14.004 for Surface Network 1</u>																				
Total Area (ha) 0.004																				
<table><tr><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td></tr><tr><td>From: To:</td><td>(ha)</td><td>From: To:</td><td>(ha)</td><td>From: To:</td><td>(ha)</td></tr><tr><td>0 4</td><td>0.000</td><td>4 8</td><td>0.000</td><td>8 12</td><td>0.004</td></tr></table>			Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To:	(ha)	From: To:	(ha)	From: To:	(ha)	0 4	0.000	4 8	0.000	8 12	0.004
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area															
From: To:	(ha)	From: To:	(ha)	From: To:	(ha)															
0 4	0.000	4 8	0.000	8 12	0.004															
<u>Time Area Diagram at Pipe Number 16.000 for Surface Network 1</u>																				
Total Area (ha) 0.023																				
<table><tr><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td></tr><tr><td>From: To:</td><td>(ha)</td><td>From: To:</td><td>(ha)</td><td>From: To:</td><td>(ha)</td></tr><tr><td>0 4</td><td>0.000</td><td>4 8</td><td>0.000</td><td>8 12</td><td>0.023</td></tr></table>			Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To:	(ha)	From: To:	(ha)	From: To:	(ha)	0 4	0.000	4 8	0.000	8 12	0.023
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area															
From: To:	(ha)	From: To:	(ha)	From: To:	(ha)															
0 4	0.000	4 8	0.000	8 12	0.023															
<u>Time Area Diagram at Pipe Number 14.006 for Surface Network 1</u>																				
Total Area (ha) 0.010																				
<table><tr><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td></tr><tr><td>From: To:</td><td>(ha)</td><td>From: To:</td><td>(ha)</td><td>From: To:</td><td>(ha)</td></tr><tr><td>0 4</td><td>0.000</td><td>4 8</td><td>0.000</td><td>8 12</td><td>0.010</td></tr></table>			Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To:	(ha)	From: To:	(ha)	From: To:	(ha)	0 4	0.000	4 8	0.000	8 12	0.010
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area															
From: To:	(ha)	From: To:	(ha)	From: To:	(ha)															
0 4	0.000	4 8	0.000	8 12	0.010															
<u>Time Area Diagram at Pipe Number 18.000 for Surface Network 1</u>																				
Total Area (ha) 0.026																				
<table><tr><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td></tr><tr><td>From: To:</td><td>(ha)</td><td>From: To:</td><td>(ha)</td><td>From: To:</td><td>(ha)</td></tr><tr><td>0 4</td><td>0.000</td><td>4 8</td><td>0.000</td><td>8 12</td><td>0.026</td></tr></table>			Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To:	(ha)	From: To:	(ha)	From: To:	(ha)	0 4	0.000	4 8	0.000	8 12	0.026
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area															
From: To:	(ha)	From: To:	(ha)	From: To:	(ha)															
0 4	0.000	4 8	0.000	8 12	0.026															
©1982-2018 Innovyze																				

RSK LDE		Page 88
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT		
Drove Lane, Yapton Surface Water Network Calculations - FEH Data		
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...		
Designed by AMuthusami Checked by		
XP Solutions		Network 2018.1.1

Time Area Diagram at Pipe Number 17.001 for Surface Network 1

Total Area (ha) 0.025

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)
0 4 0.000	4 8 0.000	8 12 0.025			

Time Area Diagram at Pipe Number 19.000 for Surface Network 1

Total Area (ha) 0.010

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)
0 4 0.000	4 8 0.000	8 12 0.010			

Time Area Diagram at Pipe Number 19.001 for Surface Network 1

Total Area (ha) 0.015

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)
0 4 0.000	4 8 0.000	8 12 0.015			

Time Area Diagram at Pipe Number 20.000 for Surface Network 1

Total Area (ha) 0.028

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)
0 4 0.000	4 8 0.000	8 12 0.028			

Time Area Diagram at Pipe Number 21.000 for Surface Network 1

Total Area (ha) 0.096

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)
0 4 0.000	4 8 0.000	8 12 0.096			

Time Area Diagram at Pipe Number 21.003 for Surface Network 1

Total Area (ha) 0.014

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)
0 4 0.000	4 8 0.000	8 12 0.014			

©1982-2018 Innovyze

RSK LDE		Page 89	
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT		Drove Lane, Yapton Surface Water Network Calculations - FEH Data	
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...		Designed by AMuthusami Checked by	
XP Solutions		Network 2018.1.1	

Time Area Diagram at Pipe Number 21.004 for Surface Network 1

Total Area (ha) 0.005

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)
0 4 0.000	4 8 0.000	8 12 0.005			

Time Area Diagram at Pipe Number 21.005 for Surface Network 1

Total Area (ha) 0.011

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)
0 4 0.000	4 8 0.000	8 12 0.011			

Time Area Diagram at Pipe Number 22.001 for Surface Network 1

Total Area (ha) 0.016

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)
0 4 0.000	4 8 0.000	8 12 0.016			

Time Area Diagram at Pipe Number 23.000 for Surface Network 1

Total Area (ha) 0.013

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)
0 4 0.000	4 8 0.000	8 12 0.013			

Time Area Diagram at Pipe Number 21.009 for Surface Network 1

Total Area (ha) 0.046

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)
0 4 0.000	4 8 0.000	8 12 0.030	12 16 0.016				

Time Area Diagram at Pipe Number 24.000 for Surface Network 1

Total Area (ha) 0.009

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)
0 4 0.000	4 8 0.000	8 12 0.009			

©1982-2018 Innovyze

RSK LDE		Page 90																																																																																																												
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT																																																																																																														
Drove Lane, Yapton Surface Water Network Calculations - FEH Data																																																																																																														
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...																																																																																																														
Designed by AMuthusami Checked by																																																																																																														
XP Solutions		Network 2018.1.1																																																																																																												
<u>Time Area Diagram at Pipe Number 24.001 for Surface Network 1</u> Total Area (ha) 0.014 <table><thead><tr><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th></tr><tr><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th></tr></thead><tbody><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.014</td><td></td><td></td><td></td></tr></tbody></table> <u>Time Area Diagram at Pipe Number 24.003 for Surface Network 1</u> Total Area (ha) 0.009 <table><thead><tr><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th></tr><tr><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th></tr></thead><tbody><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.009</td><td></td><td></td><td></td></tr></tbody></table> <u>Time Area Diagram at Pipe Number 27.000 for Surface Network 1</u> Total Area (ha) 0.056 <table><thead><tr><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th></tr><tr><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th></tr></thead><tbody><tr><td>0 4 0.000</td><td>4 8 0.012</td><td>8 12 0.044</td><td></td><td></td><td></td></tr></tbody></table> <u>Time Area Diagram at Pipe Number 28.000 for Surface Network 1</u> Total Area (ha) 0.017 <table><thead><tr><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th></tr><tr><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th></tr></thead><tbody><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.017</td><td></td><td></td><td></td></tr></tbody></table> <u>Time Area Diagram at Pipe Number 29.000 for Surface Network 1</u> Total Area (ha) 0.004 <table><thead><tr><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th></tr><tr><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th></tr></thead><tbody><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.004</td><td></td><td></td><td></td></tr></tbody></table> <u>Time Area Diagram at Pipe Number 29.002 for Surface Network 1</u> Total Area (ha) 0.027 <table><thead><tr><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th></tr><tr><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th></tr></thead><tbody><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.027</td><td></td><td></td><td></td></tr></tbody></table>			Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	0 4 0.000	4 8 0.000	8 12 0.014				Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	0 4 0.000	4 8 0.000	8 12 0.009				Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	0 4 0.000	4 8 0.012	8 12 0.044				Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	0 4 0.000	4 8 0.000	8 12 0.017				Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	0 4 0.000	4 8 0.000	8 12 0.004				Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	0 4 0.000	4 8 0.000	8 12 0.027			
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area																																																																																																									
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)																																																																																																									
0 4 0.000	4 8 0.000	8 12 0.014																																																																																																												
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area																																																																																																									
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)																																																																																																									
0 4 0.000	4 8 0.000	8 12 0.009																																																																																																												
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area																																																																																																									
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)																																																																																																									
0 4 0.000	4 8 0.012	8 12 0.044																																																																																																												
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area																																																																																																									
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)																																																																																																									
0 4 0.000	4 8 0.000	8 12 0.017																																																																																																												
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area																																																																																																									
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)																																																																																																									
0 4 0.000	4 8 0.000	8 12 0.004																																																																																																												
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area																																																																																																									
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)																																																																																																									
0 4 0.000	4 8 0.000	8 12 0.027																																																																																																												
©1982-2018 Innovyze																																																																																																														

RSK LDE		Page 91																		
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT																				
Drove Lane, Yapton Surface Water Network Calculations - FEH Data																				
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...																				
Designed by AMuthusami Checked by																				
XP Solutions		Network 2018.1.1																		
<u>Time Area Diagram at Pipe Number 32.000 for Surface Network 1</u> Total Area (ha) 0.093 <table><tr><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td></tr><tr><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td></tr><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.093</td><td></td><td></td><td></td></tr></table>			Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	0 4 0.000	4 8 0.000	8 12 0.093			
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area															
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)															
0 4 0.000	4 8 0.000	8 12 0.093																		
<u>Time Area Diagram at Pipe Number 32.001 for Surface Network 1</u> Total Area (ha) 0.011 <table><tr><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td></tr><tr><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td></tr><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.011</td><td></td><td></td><td></td></tr></table>			Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	0 4 0.000	4 8 0.000	8 12 0.011			
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area															
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)															
0 4 0.000	4 8 0.000	8 12 0.011																		
<u>Time Area Diagram at Pipe Number 34.000 for Surface Network 1</u> Total Area (ha) 0.041 <table><tr><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td></tr><tr><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td></tr><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.041</td><td></td><td></td><td></td></tr></table>			Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	0 4 0.000	4 8 0.000	8 12 0.041			
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area															
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)															
0 4 0.000	4 8 0.000	8 12 0.041																		
<u>Time Area Diagram at Pipe Number 35.000 for Surface Network 1</u> Total Area (ha) 0.036 <table><tr><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td></tr><tr><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td></tr><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.036</td><td></td><td></td><td></td></tr></table>			Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	0 4 0.000	4 8 0.000	8 12 0.036			
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area															
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)															
0 4 0.000	4 8 0.000	8 12 0.036																		
<u>Time Area Diagram at Pipe Number 34.004 for Surface Network 1</u> Total Area (ha) 0.036 <table><tr><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td></tr><tr><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td></tr><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.036</td><td></td><td></td><td></td></tr></table>			Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	0 4 0.000	4 8 0.000	8 12 0.036			
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area															
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)															
0 4 0.000	4 8 0.000	8 12 0.036																		
<u>Time Area Diagram at Pipe Number 36.000 for Surface Network 1</u> Total Area (ha) 0.022 <table><tr><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td></tr><tr><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td></tr><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.022</td><td></td><td></td><td></td></tr></table>			Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	0 4 0.000	4 8 0.000	8 12 0.022			
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area															
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)															
0 4 0.000	4 8 0.000	8 12 0.022																		
©1982-2018 Innovyze																				

RSK LDE		Page 92																																																																																																												
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT																																																																																																														
Drove Lane, Yapton Surface Water Network Calculations - FEH Data																																																																																																														
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...																																																																																																														
Designed by AMuthusami Checked by																																																																																																														
XP Solutions		Network 2018.1.1																																																																																																												
<u>Time Area Diagram at Pipe Number 37.000 for Surface Network 1</u> Total Area (ha) 0.015 <table><tr><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td></tr><tr><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td></tr><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.015</td><td></td><td></td><td></td></tr></table> <u>Time Area Diagram at Pipe Number 38.000 for Surface Network 1</u> Total Area (ha) 0.009 <table><tr><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td></tr><tr><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td></tr><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.009</td><td></td><td></td><td></td></tr></table> <u>Time Area Diagram at Pipe Number 19.022 for Surface Network 1</u> Total Area (ha) 0.041 <table><tr><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td></tr><tr><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td></tr><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.041</td><td></td><td></td><td></td></tr></table> <u>Time Area Diagram at Pipe Number 39.000 for Surface Network 1</u> Total Area (ha) 0.014 <table><tr><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td></tr><tr><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td></tr><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.014</td><td></td><td></td><td></td></tr></table> <u>Time Area Diagram at Pipe Number 41.000 for Surface Network 1</u> Total Area (ha) 0.009 <table><tr><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td></tr><tr><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td></tr><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.009</td><td></td><td></td><td></td></tr></table> <u>Time Area Diagram at Pipe Number 42.000 for Surface Network 1</u> Total Area (ha) 0.015 <table><tr><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td></tr><tr><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td></tr><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.015</td><td></td><td></td><td></td></tr></table>			Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	0 4 0.000	4 8 0.000	8 12 0.015				Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	0 4 0.000	4 8 0.000	8 12 0.009				Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	0 4 0.000	4 8 0.000	8 12 0.041				Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	0 4 0.000	4 8 0.000	8 12 0.014				Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	0 4 0.000	4 8 0.000	8 12 0.009				Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	0 4 0.000	4 8 0.000	8 12 0.015			
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area																																																																																																									
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)																																																																																																									
0 4 0.000	4 8 0.000	8 12 0.015																																																																																																												
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area																																																																																																									
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)																																																																																																									
0 4 0.000	4 8 0.000	8 12 0.009																																																																																																												
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area																																																																																																									
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)																																																																																																									
0 4 0.000	4 8 0.000	8 12 0.041																																																																																																												
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area																																																																																																									
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)																																																																																																									
0 4 0.000	4 8 0.000	8 12 0.014																																																																																																												
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area																																																																																																									
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)																																																																																																									
0 4 0.000	4 8 0.000	8 12 0.009																																																																																																												
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area																																																																																																									
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)																																																																																																									
0 4 0.000	4 8 0.000	8 12 0.015																																																																																																												
©1982-2018 Innovyze																																																																																																														

RSK LDE		Page 93
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT		Drove Lane, Yapton Surface Water Network Calculations - FEH Data
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...		Designed by AMuthusami Checked by
XP Solutions		Network 2018.1.1

Time Area Diagram at Pipe Number 44.000 for Surface Network 1

Total Area (ha) 0.026

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To:	(ha)	From: To:	(ha)	From: To:	(ha)
0 4	0.000	4 8	0.000	8 12	0.026

Time Area Diagram at Pipe Number 45.000 for Surface Network 1

Total Area (ha) 0.023

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To:	(ha)	From: To:	(ha)	From: To:	(ha)
0 4	0.000	4 8	0.000	8 12	0.023

Time Area Diagram at Pipe Number 46.000 for Surface Network 1

Total Area (ha) 0.032

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To:	(ha)	From: To:	(ha)	From: To:	(ha)
0 4	0.000	4 8	0.000	8 12	0.032

Time Area Diagram at Pipe Number 45.006 for Surface Network 1

Total Area (ha) 0.028

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To:	(ha)	From: To:	(ha)	From: To:	(ha)
0 4	0.000	4 8	0.000	8 12	0.028

Time Area Diagram at Pipe Number 47.000 for Surface Network 1

Total Area (ha) 0.019

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To:	(ha)	From: To:	(ha)	From: To:	(ha)
0 4	0.000	4 8	0.000	8 12	0.019

Time Area Diagram at Pipe Number 48.000 for Surface Network 1

Total Area (ha) 0.008

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From: To:	(ha)	From: To:	(ha)	From: To:	(ha)
0 4	0.000	4 8	0.000	8 12	0.008

©1982-2018 Innovyze

RSK LDE		Page 94																		
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT																				
Drove Lane, Yapton Surface Water Network Calculations - FEH Data																				
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...																				
Designed by AMuthusami Checked by																				
XP Solutions		Network 2018.1.1																		
<u>Time Area Diagram at Pipe Number 49.000 for Surface Network 1</u> Total Area (ha) 0.004 <table><tr><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td></tr><tr><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td></td><td></td><td></td></tr><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.004</td><td></td><td></td><td></td></tr></table>			Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)				0 4 0.000	4 8 0.000	8 12 0.004			
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area															
From: To: (ha)	From: To: (ha)	From: To: (ha)																		
0 4 0.000	4 8 0.000	8 12 0.004																		
<u>Time Area Diagram at Pipe Number 50.002 for Surface Network 1</u> Total Area (ha) 0.019 <table><tr><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td></tr><tr><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td></td><td></td><td></td></tr><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.019</td><td></td><td></td><td></td></tr></table>			Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)				0 4 0.000	4 8 0.000	8 12 0.019			
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area															
From: To: (ha)	From: To: (ha)	From: To: (ha)																		
0 4 0.000	4 8 0.000	8 12 0.019																		
<u>Time Area Diagram at Pipe Number 52.000 for Surface Network 1</u> Total Area (ha) 0.022 <table><tr><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td></tr><tr><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td></td><td></td><td></td></tr><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.022</td><td></td><td></td><td></td></tr></table>			Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)				0 4 0.000	4 8 0.000	8 12 0.022			
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area															
From: To: (ha)	From: To: (ha)	From: To: (ha)																		
0 4 0.000	4 8 0.000	8 12 0.022																		
<u>Time Area Diagram at Pipe Number 51.004 for Surface Network 1</u> Total Area (ha) 0.012 <table><tr><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td></tr><tr><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td></td><td></td><td></td></tr><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.012</td><td></td><td></td><td></td></tr></table>			Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)				0 4 0.000	4 8 0.000	8 12 0.012			
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area															
From: To: (ha)	From: To: (ha)	From: To: (ha)																		
0 4 0.000	4 8 0.000	8 12 0.012																		
<u>Time Area Diagram at Pipe Number 54.000 for Surface Network 1</u> Total Area (ha) 0.013 <table><tr><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td></tr><tr><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td></td><td></td><td></td></tr><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.013</td><td></td><td></td><td></td></tr></table>			Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)				0 4 0.000	4 8 0.000	8 12 0.013			
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area															
From: To: (ha)	From: To: (ha)	From: To: (ha)																		
0 4 0.000	4 8 0.000	8 12 0.013																		
<u>Time Area Diagram at Pipe Number 55.000 for Surface Network 1</u> Total Area (ha) 0.039 <table><tr><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td><td>Time (mins)</td><td>Area</td></tr><tr><td>From: To: (ha)</td><td>From: To: (ha)</td><td>From: To: (ha)</td><td></td><td></td><td></td></tr><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.039</td><td></td><td></td><td></td></tr></table>			Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)				0 4 0.000	4 8 0.000	8 12 0.039			
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area															
From: To: (ha)	From: To: (ha)	From: To: (ha)																		
0 4 0.000	4 8 0.000	8 12 0.039																		
©1982-2018 Innovyze																				

RSK LDE		Page 95																																																																																																												
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT																																																																																																														
Drove Lane, Yapton Surface Water Network Calculations - FEH Data																																																																																																														
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...																																																																																																														
Designed by AMuthusami Checked by																																																																																																														
XP Solutions		Network 2018.1.1																																																																																																												
<u>Time Area Diagram at Pipe Number 56.000 for Surface Network 1</u> Total Area (ha) 0.022 <table><thead><tr><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th></tr><tr><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th></tr></thead><tbody><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.022</td><td></td><td></td><td></td></tr></tbody></table> <u>Time Area Diagram at Pipe Number 51.007 for Surface Network 1</u> Total Area (ha) 0.009 <table><thead><tr><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th></tr><tr><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th></tr></thead><tbody><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.009</td><td></td><td></td><td></td></tr></tbody></table> <u>Time Area Diagram at Pipe Number 51.009 for Surface Network 1</u> Total Area (ha) 0.020 <table><thead><tr><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th></tr><tr><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th></tr></thead><tbody><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.020</td><td></td><td></td><td></td></tr></tbody></table> <u>Time Area Diagram at Pipe Number 58.001 for Surface Network 1</u> Total Area (ha) 0.018 <table><thead><tr><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th></tr><tr><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th></tr></thead><tbody><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.018</td><td></td><td></td><td></td></tr></tbody></table> <u>Time Area Diagram at Pipe Number 58.002 for Surface Network 1</u> Total Area (ha) 0.031 <table><thead><tr><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th></tr><tr><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th></tr></thead><tbody><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.031</td><td></td><td></td><td></td></tr></tbody></table> <u>Time Area Diagram at Pipe Number 59.001 for Surface Network 1</u> Total Area (ha) 0.016 <table><thead><tr><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th></tr><tr><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th><th>From: To: (ha)</th></tr></thead><tbody><tr><td>0 4 0.000</td><td>4 8 0.000</td><td>8 12 0.016</td><td></td><td></td><td></td></tr></tbody></table>			Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	0 4 0.000	4 8 0.000	8 12 0.022				Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	0 4 0.000	4 8 0.000	8 12 0.009				Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	0 4 0.000	4 8 0.000	8 12 0.020				Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	0 4 0.000	4 8 0.000	8 12 0.018				Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	0 4 0.000	4 8 0.000	8 12 0.031				Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	0 4 0.000	4 8 0.000	8 12 0.016			
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area																																																																																																									
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)																																																																																																									
0 4 0.000	4 8 0.000	8 12 0.022																																																																																																												
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area																																																																																																									
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)																																																																																																									
0 4 0.000	4 8 0.000	8 12 0.009																																																																																																												
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area																																																																																																									
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)																																																																																																									
0 4 0.000	4 8 0.000	8 12 0.020																																																																																																												
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area																																																																																																									
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)																																																																																																									
0 4 0.000	4 8 0.000	8 12 0.018																																																																																																												
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area																																																																																																									
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)																																																																																																									
0 4 0.000	4 8 0.000	8 12 0.031																																																																																																												
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area																																																																																																									
From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)	From: To: (ha)																																																																																																									
0 4 0.000	4 8 0.000	8 12 0.016																																																																																																												
©1982-2018 Innovyze																																																																																																														

RSK LDE		Page 96																																																						
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT	Drove Lane, Yapton Surface Water Network Calculations - FEH Data																																																							
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...	Designed by AMuthusami Checked by																																																							
XP Solutions Network 2018.1.1																																																								
<u>Time Area Diagram at Pipe Number 60.000 for Surface Network 1</u> Total Area (ha) 0.006 <table><tr><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th></tr><tr><th>From: To:</th><th>(ha)</th><th>From: To:</th><th>(ha)</th><th>From: To:</th><th>(ha)</th></tr><tr><td>0 4</td><td>0.000</td><td>4 8</td><td>0.000</td><td>8 12</td><td>0.006</td></tr></table> <u>Time Area Diagram at Pipe Number 61.000 for Surface Network 1</u> Total Area (ha) 0.011 <table><tr><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th></tr><tr><th>From: To:</th><th>(ha)</th><th>From: To:</th><th>(ha)</th><th>From: To:</th><th>(ha)</th></tr><tr><td>0 4</td><td>0.000</td><td>4 8</td><td>0.000</td><td>8 12</td><td>0.011</td></tr></table> <u>Time Area Diagram at Pipe Number 63.000 for Surface Network 1</u> Total Area (ha) 0.024 <table><tr><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th><th>Time (mins)</th><th>Area</th></tr><tr><th>From: To:</th><th>(ha)</th><th>From: To:</th><th>(ha)</th><th>From: To:</th><th>(ha)</th></tr><tr><td>0 4</td><td>0.000</td><td>4 8</td><td>0.000</td><td>8 12</td><td>0.024</td></tr></table>			Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To:	(ha)	From: To:	(ha)	From: To:	(ha)	0 4	0.000	4 8	0.000	8 12	0.006	Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To:	(ha)	From: To:	(ha)	From: To:	(ha)	0 4	0.000	4 8	0.000	8 12	0.011	Time (mins)	Area	Time (mins)	Area	Time (mins)	Area	From: To:	(ha)	From: To:	(ha)	From: To:	(ha)	0 4	0.000	4 8	0.000	8 12	0.024
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area																																																			
From: To:	(ha)	From: To:	(ha)	From: To:	(ha)																																																			
0 4	0.000	4 8	0.000	8 12	0.006																																																			
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area																																																			
From: To:	(ha)	From: To:	(ha)	From: To:	(ha)																																																			
0 4	0.000	4 8	0.000	8 12	0.011																																																			
Time (mins)	Area	Time (mins)	Area	Time (mins)	Area																																																			
From: To:	(ha)	From: To:	(ha)	From: To:	(ha)																																																			
0 4	0.000	4 8	0.000	8 12	0.024																																																			
©1982-2018 Innovyze																																																								

RSK LDE		Page 97				
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT		Drove Lane, Yapton Surface Water Network Calculations - FEH Data				
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...		Designed by AMuthusami Checked by				
XP Solutions		Network 2018.1.1				
Summary of Critical Results by Maximum Level (Rank 1) for Surface Network 1						
Simulation Criteria						
Areal Reduction Factor 1.000 Additional Flow - % of Total Flow 0.000						
Hot Start (mins) 0 MADD Factor * 10m³/ha Storage 2.000						
Hot Start Level (mm) 0 Inlet Coefficient 0.800						
Manhole Headloss Coeff (Global) 0.500 Flow per Person per Day (l/per/day) 0.000						
Foul Sewage per hectare (l/s) 0.000						
Number of Input Hydrographs 0 Number of Storage Structures 114						
Number of Online Controls 23 Number of Time/Area Diagrams 74						
Number of Offline Controls 0 Number of Real Time Controls 0						
Synthetic Rainfall Details						
Rainfall Model FEH						
FEH Rainfall Version 1999						
Site Location GB 497500 102350 SU 97500 02350						
C (1km) -0.025						
D1 (1km) 0.390						
D2 (1km) 0.245						
D3 (1km) 0.403						
E (1km) 0.310						
F (1km) 2.321						
Cv (Summer) 0.750						
Cv (Winter) 0.840						
Margin for Flood Risk Warning (mm) 300.0						
Analysis Timestep 2.5 Second Increment (Extended)						
DTS Status OFF						
DVD Status ON						
Inertia Status ON						
Profile(s) Summer and Winter						
Duration(s) (mins) 15, 30, 60, 120, 240, 360, 480, 960, 1440						
Return Period(s) (years) 100						
Climate Change (%) 40						
US/MH	Return	Climate	First (X)	First (Y)	First (Z)	Overflow
PN Name Storm Period Change Surcharge Flood Overflow Act.						
1.000 S1 480 Winter 100 +40% 100/15 Summer						
1.001 S2 480 Winter 100 +40% 100/360 Winter						
1.002 S3 480 Winter 100 +40% 100/240 Winter						
1.003 S4 480 Winter 100 +40% 100/30 Winter						
1.004 S5 480 Winter 100 +40% 100/15 Summer						
2.000 S6 15 Winter 100 +40% 100/15 Summer						
2.001 S7 15 Winter 100 +40% 100/15 Summer						
2.002 S8 15 Winter 100 +40% 100/15 Summer						
2.003 S9 15 Winter 100 +40% 100/15 Summer 100/15 Summer						
2.004 S10 480 Winter 100 +40% 100/15 Summer						
2.005 S11 480 Winter 100 +40% 100/15 Summer						
1.005 S12 480 Winter 100 +40% 100/15 Summer						
©1982-2018 Innovyze						

RSK LDE							Page 98		
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT				Drove Lane, Yapton Surface Water Network Calculations - FEH Data					
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...				Designed by AMuthusami Checked by					
XP Solutions				Network 2018.1.1					
<u>Summary of Critical Results by Maximum Level (Rank 1) for Surface Network 1</u>									

RSK LDE						Page 99		
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT				Drove Lane, Yapton Surface Water Network Calculations - FEH Data				
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...				Designed by AMuthusami Checked by				
XP Solutions				Network 2018.1.1				
<u>Summary of Critical Results by Maximum Level (Rank 1) for Surface Network 1</u>								
PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surcharge	First (Y) Flood	First (Z) Overflow	Overflow Act.
3.000	S13	15 Winter	100	+40%	100/15 Summer			
3.001	S14	15 Winter	100	+40%	100/15 Summer			
3.002	S15	15 Winter	100	+40%	100/15 Summer			
3.003	S16	60 Winter	100	+40%	100/15 Summer			
3.004	S17	60 Winter	100	+40%	100/15 Summer			
3.005	S18	60 Winter	100	+40%	100/15 Summer			
4.000	S19	60 Winter	100	+40%	100/15 Summer			
3.006	S20	60 Winter	100	+40%	100/15 Summer			
3.007	S21	30 Winter	100	+40%	100/15 Summer			
5.000	S255	960 Winter	100	+40%	100/15 Summer			
5.001	S254	960 Winter	100	+40%	100/15 Summer			
5.002	S22	960 Winter	100	+40%	100/15 Summer			
6.000	S23	15 Winter	100	+40%	100/15 Summer			
3.008	S24	30 Winter	100	+40%	100/15 Summer			
3.009	S26	480 Winter	100	+40%	100/15 Summer			
3.010	S27	480 Winter	100	+40%	100/15 Summer			
3.011	S28	480 Winter	100	+40%	100/15 Summer			
7.000	S29	480 Winter	100	+40%	100/15 Summer			
3.012	S30	480 Winter	100	+40%	100/15 Summer			
3.013	S31	480 Winter	100	+40%	100/15 Summer			
1.006	S32	480 Winter	100	+40%	100/15 Summer			
8.000	S33	960 Winter	100	+40%	100/15 Summer			
9.000	S34	960 Winter	100	+40%	100/15 Summer			
8.001	S35	960 Winter	100	+40%	100/15 Summer			
1.007	S36	960 Winter	100	+40%	100/15 Summer			
1.008	S37	960 Winter	100	+40%	100/15 Summer			
1.009	S38	960 Winter	100	+40%	100/15 Summer			
1.010	S39	360 Winter	100	+40%	100/15 Summer			
10.000	S112	15 Winter	100	+40%	100/15 Summer			
10.001	S111	15 Winter	100	+40%	100/15 Summer			
10.002	S40	15 Winter	100	+40%	100/15 Summer			
10.003	S41	30 Winter	100	+40%	100/15 Summer			
10.004	S42	15 Winter	100	+40%	100/15 Summer			
11.000	S256	15 Winter	100	+40%	100/15 Summer			
10.005	S43	15 Winter	100	+40%	100/15 Summer			
10.006	S44	15 Winter	100	+40%	100/15 Summer			
10.007	S45	15 Winter	100	+40%	100/15 Summer			
10.008	S46	240 Winter	100	+40%	100/15 Summer			
10.009	S47	240 Winter	100	+40%	100/15 Summer			
1.011	S48	360 Winter	100	+40%	100/15 Summer			
1.012	S49	960 Winter	100	+40%	100/15 Summer			
1.013	S50	960 Winter	100	+40%	100/15 Summer			
12.000	S51	15 Winter	100	+40%	100/15 Summer			
12.001	S52	1440 Winter	100	+40%	100/15 Summer			
1.014	S53	1440 Winter	100	+40%	100/120 Winter			
1.015	S54	1440 Winter	100	+40%	100/60 Summer			
1.016	S55	1440 Winter	100	+40%	100/15 Summer			
13.000	S56	1440 Winter	100	+40%	100/240 Summer			
13.001	S57	1440 Winter	100	+40%	100/15 Summer			
©1982-2018 Innovyze								

RSK LDE							Page 100		
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT				Drove Lane, Yapton Surface Water Network Calculations - FEH Data					
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...				Designed by AMuthusami Checked by					
XP Solutions				Network 2018.1.1					
<u>Summary of Critical Results by Maximum Level (Rank 1) for Surface Network 1</u>									
PN	US/MH Name	Water Level (m)	Surcharged Depth (m)	Flooded Volume (m³)	Flow / Cap.	Overflow (l/s)	Pipe Flow (l/s)	Status	Level Exceeded
3.000	S13	6.692	0.662	0.000	0.81		11.3	SURCHARGED	
3.001	S14	6.741	0.771	0.000	1.45		25.8	SURCHARGED	
3.002	S15	6.614	0.724	0.000	1.81		22.7	SURCHARGED	
3.003	S16	6.546	0.696	0.000	3.47		15.4	SURCHARGED	
3.004	S17	6.486	0.221	0.000	0.77		10.1	SURCHARGED	
3.005	S18	6.464	0.274	0.000	0.79		10.3	SURCHARGED	
4.000	S19	6.463	0.213	0.000	0.50		7.1	SURCHARGED	
3.006	S20	6.454	0.314	0.000	0.81		11.4	SURCHARGED	
3.007	S21	6.435	0.405	0.000	0.49		12.0	SURCHARGED	
5.000	S255	6.334	0.564	0.000	0.07		0.7	SURCHARGED	
5.001	S254	6.335	0.565	0.000	0.07		0.7	SURCHARGED	
5.002	S22	6.335	0.490	0.000	0.02		0.7	SURCHARGED	
6.000	S23	6.657	0.653	0.000	1.15		30.1	SURCHARGED	
3.008	S24	6.428	0.628	0.000	0.51		30.3	SURCHARGED	
3.009	S26	6.369	0.666	0.000	0.24		13.0	SURCHARGED	
3.010	S27	6.377	0.718	0.000	0.26		13.8	SURCHARGED	
3.011	S28	6.389	0.769	0.000	0.19		13.7	FLOOD RISK	
7.000	S29	6.358	0.751	0.000	0.19		2.6	FLOOD RISK	
3.012	S30	6.402	0.882	0.000	0.29		16.8	FLOOD RISK	
3.013	S31	6.404	0.924	0.000	0.29		16.7	FLOOD RISK	
1.006	S32	6.404	0.954	0.000	0.15		5.0	FLOOD RISK	
8.000	S33	5.953	0.253	0.000	0.10		1.8	SURCHARGED	
9.000	S34	5.953	0.453	0.000	0.14		1.9	SURCHARGED	
8.001	S35	5.953	0.513	0.000	0.33		3.6	SURCHARGED	
1.007	S36	5.953	0.533	0.000	0.27		7.2	SURCHARGED	
1.008	S37	6.004	0.584	0.000	0.12		6.4	SURCHARGED	
1.009	S38	6.012	0.742	0.000	0.34		5.6	SURCHARGED	
1.010	S39	5.787	0.677	0.000	0.41		6.0	SURCHARGED	
10.000	S112	6.714	0.514	0.000	0.61		8.9	FLOOD RISK	
10.001	S111	6.660	0.610	0.000	0.68		9.7	FLOOD RISK	
10.002	S40	6.629	0.679	0.000	2.05		25.4	FLOOD RISK	
10.003	S41	6.262	0.432	0.000	0.76		12.1	SURCHARGED	
10.004	S42	6.272	0.512	0.000	0.60		12.9	SURCHARGED	
11.000	S256	6.567	1.027	0.000	0.97		15.7	FLOOD RISK	
10.005	S43	6.440	1.030	0.000	0.86		13.5	FLOOD RISK	
10.006	S44	6.451	1.151	0.000	1.59		22.5	FLOOD RISK	
10.007	S45	6.124	0.974	0.000	3.06		21.9	FLOOD RISK	
10.008	S46	5.807	0.707	0.000	1.22		14.6	FLOOD RISK	
10.009	S47	5.789	0.739	0.000	0.51		6.0	SURCHARGED	
1.011	S48	5.772	0.772	0.000	0.61		8.3	SURCHARGED	
1.012	S49	5.579	0.554	0.000	0.27		8.7	FLOOD RISK	
1.013	S50	5.632	0.693	0.000	0.29		8.7	FLOOD RISK	
12.000	S51	5.525	0.125	0.000	1.13		15.7	SURCHARGED	
12.001	S52	5.325	0.115	0.000	0.06		0.7	SURCHARGED	
1.014	S53	5.325	0.432	0.000	0.30		8.9	SURCHARGED	
1.015	S54	5.310	0.543	0.000	0.22		8.9	SURCHARGED	
1.016	S55	5.297	0.720	0.000	0.22		8.8	SURCHARGED	
13.000	S56	5.288	0.348	0.000	0.01		0.1	SURCHARGED	
©1982-2018 Innovyze									

RSK LDE							Page 101	
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT				Drove Lane, Yapton Surface Water Network Calculations - FEH Data				
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...				Designed by AMuthusami Checked by				
XP Solutions				Network 2018.1.1				
<u>Summary of Critical Results by Maximum Level (Rank 1) for Surface Network 1</u>								
		Water	Surcharged	Flooded			Pipe	
	US/MH	Level	Depth	Volume	Flow / Overflow	Pipe	Flow	Level
PN	Name	(m)	(m)	(m³)	Cap.	(l/s)	(l/s)	Exceeded
13.001	S57	5.288	0.488	0.000	0.03		0.5	SURCHARGED
©1982-2018 Innovyze								

RSK LDE						Page 102		
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT				Drove Lane, Yapton Surface Water Network Calculations - FEH Data				
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...				Designed by AMuthusami Checked by				
XP Solutions				Network 2018.1.1				
<u>Summary of Critical Results by Maximum Level (Rank 1) for Surface Network 1</u>								
PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surcharge	First (Y) Flood	First (Z) Overflow	Overflow Act.
13.002	S58	1440 Winter	100	+40%	100/15 Summer			
13.003	S59	1440 Winter	100	+40%	100/15 Summer			
1.017	S60	1440 Winter	100	+40%	100/15 Summer			
14.000	S61	15 Winter	100	+40%	100/15 Summer			
15.000	S62	15 Winter	100	+40%	100/15 Summer			
14.001	S63	15 Winter	100	+40%	100/15 Summer			
14.002	S64	15 Winter	100	+40%	100/15 Summer			
14.003	S65	1440 Winter	100	+40%				
14.004	S66	1440 Winter	100	+40%	100/15 Summer			
16.000	S67	1440 Winter	100	+40%	100/15 Summer			
16.001	S68	1440 Winter	100	+40%	100/15 Summer			
14.005	S69	1440 Winter	100	+40%	100/15 Summer			
14.006	S70	1440 Winter	100	+40%	100/15 Summer			
14.007	S71	1440 Winter	100	+40%	100/15 Summer			
17.000	S72	15 Winter	100	+40%				
18.000	S73	15 Winter	100	+40%	100/15 Summer			
17.001	S74	15 Winter	100	+40%	100/15 Summer			
17.002	S75	1440 Winter	100	+40%	100/15 Summer			
1.018	S76	1440 Winter	100	+40%	100/15 Summer			
1.019	S77	1440 Winter	100	+40%	100/15 Summer			
1.020	S78	1440 Winter	100	+40%	100/15 Summer			
1.021	S79	1440 Winter	100	+40%	100/15 Summer			
19.000	S80	960 Winter	100	+40%	100/120 Summer			
19.001	S81	960 Winter	100	+40%	100/120 Summer			
20.000	S82	960 Winter	100	+40%	100/15 Summer			
19.002	S83	960 Winter	100	+40%	100/30 Winter			
19.003	S84	960 Winter	100	+40%	100/30 Winter			
19.004	S85	960 Winter	100	+40%	100/30 Winter			
19.005	S86	960 Winter	100	+40%	100/15 Winter			
19.006	S87	960 Winter	100	+40%	100/15 Summer			
19.007	S88	960 Winter	100	+40%	100/15 Summer			
19.008	S89	960 Winter	100	+40%	100/15 Winter			
21.000	S253	960 Winter	100	+40%	100/15 Summer			
21.001	S90	960 Winter	100	+40%	100/15 Summer			
21.002	S91	960 Winter	100	+40%	100/15 Winter			
21.003	S92	960 Winter	100	+40%	100/15 Summer			
21.004	S93	960 Winter	100	+40%	100/15 Summer			
21.005	S94	960 Winter	100	+40%	100/15 Summer			
21.006	S95	960 Winter	100	+40%	100/15 Summer			
22.000	S96	960 Winter	100	+40%	100/240 Winter			
22.001	S97	960 Winter	100	+40%	100/15 Winter			
23.000	S98	960 Winter	100	+40%	100/60 Winter			
21.007	S99	960 Winter	100	+40%	100/15 Summer			
21.008	S100	960 Winter	100	+40%	100/15 Summer			
21.009	S101	960 Winter	100	+40%	100/15 Summer			
21.010	S102	960 Winter	100	+40%	100/15 Summer			
19.009	S103	960 Winter	100	+40%	100/15 Summer			
19.010	S104	960 Winter	100	+40%	100/15 Winter			
19.011	S105	960 Winter	100	+40%	100/60 Summer			
©1982-2018 Innovyze								

RSK LDE							Page 103	
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT				Drove Lane, Yapton Surface Water Network Calculations - FEH Data				
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...				Designed by AMuthusami Checked by				
XP Solutions				Network 2018.1.1				
<u>Summary of Critical Results by Maximum Level (Rank 1) for Surface Network 1</u>								
PN	US/MH Name	Water Level (m)	Surcharged Depth (m)	Flooded Volume (m³)	Flow / Overflow Cap. (l/s)	Pipe Flow (l/s)	Status	Level Exceeded
13.002	S58	5.288	0.578	0.000	0.07	1.1	SURCHARGED	
13.003	S59	5.288	0.688	0.000	0.10	1.8	SURCHARGED	
1.017	S60	5.288	0.738	0.000	0.29	9.8	SURCHARGED	
14.000	S61	6.976	0.641	0.000	1.22	18.6	FLOOD RISK	
15.000	S62	6.418	0.228	0.000	0.71	10.8	SURCHARGED	
14.001	S63	6.329	0.469	0.000	1.75	26.7	SURCHARGED	
14.002	S64	5.877	0.217	0.000	1.28	46.1	SURCHARGED	
14.003	S65	5.280	-0.050	0.000	0.04	3.7	OK	
14.004	S66	5.280	0.240	0.000	0.04	3.8	SURCHARGED	
16.000	S67	5.280	0.170	0.000	0.05	0.7	SURCHARGED	
16.001	S68	5.280	0.330	0.000	0.02	0.7	SURCHARGED	
14.005	S69	5.280	0.590	0.000	0.09	5.8	SURCHARGED	
14.006	S70	5.280	0.690	0.000	0.11	6.1	SURCHARGED	
14.007	S71	5.280	0.720	0.000	0.10	6.0	SURCHARGED	
17.000	S72	5.491	-0.059	0.000	0.66	16.6	OK	
18.000	S73	5.514	0.234	0.000	0.68	16.5	SURCHARGED	
17.001	S74	5.476	0.476	0.000	1.76	25.1	SURCHARGED	
17.002	S75	5.280	0.360	0.000	0.12	2.3	FLOOD RISK	
1.018	S76	5.280	0.780	0.000	0.11	6.9	FLOOD RISK	
1.019	S77	5.288	0.838	0.000	0.11	6.5	FLOOD RISK	
1.020	S78	5.137	0.737	0.000	0.16	6.5	SURCHARGED	
1.021	S79	5.133	0.783	0.000	0.08	6.6	FLOOD RISK	
19.000	S80	6.377	0.492	0.000	0.01	0.5	SURCHARGED	
19.001	S81	6.377	0.559	0.000	0.03	1.1	SURCHARGED	
20.000	S82	6.377	0.604	0.000	0.09	1.3	SURCHARGED	
19.002	S83	6.379	0.667	0.000	0.06	3.6	FLOOD RISK	
19.003	S84	6.379	0.722	0.000	0.06	3.5	FLOOD RISK	
19.004	S85	6.379	0.797	0.000	0.08	4.6	FLOOD RISK	
19.005	S86	6.383	0.900	0.000	0.11	6.8	FLOOD RISK	
19.006	S87	6.438	1.063	0.000	0.09	5.2	FLOOD RISK	
19.007	S88	6.446	1.116	0.000	0.04	2.4	FLOOD RISK	
19.008	S89	6.384	1.141	0.000	0.05	2.4	FLOOD RISK	
21.000	S253	6.398	0.348	0.000	0.45	4.2	SURCHARGED	
21.001	S90	6.397	0.347	0.000	0.24	4.2	SURCHARGED	
21.002	S91	6.394	0.504	0.000	0.12	4.2	SURCHARGED	
21.003	S92	6.393	0.619	0.000	0.14	4.7	SURCHARGED	
21.004	S93	6.391	0.716	0.000	0.16	4.9	SURCHARGED	
21.005	S94	6.390	0.765	0.000	0.16	5.4	SURCHARGED	
21.006	S95	6.388	0.868	0.000	0.16	5.2	SURCHARGED	
22.000	S96	6.387	0.207	0.000	0.04	0.9	SURCHARGED	
22.001	S97	6.386	0.736	0.000	0.05	1.6	SURCHARGED	
23.000	S98	6.386	0.586	0.000	0.02	0.6	SURCHARGED	
21.007	S99	6.386	0.967	0.000	0.25	8.5	SURCHARGED	
21.008	S100	6.384	1.097	0.000	0.27	8.4	FLOOD RISK	
21.009	S101	6.382	1.147	0.000	0.41	10.2	FLOOD RISK	
21.010	S102	6.383	1.168	0.000	0.20	10.2	FLOOD RISK	
19.009	S103	6.384	1.169	0.000	0.12	4.3	FLOOD RISK	
19.010	S104	6.383	1.168	0.000	0.05	4.1	FLOOD RISK	
©1982-2018 Innovyze								

RSK LDE							Page 104	
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT				Drove Lane, Yapton Surface Water Network Calculations - FEH Data				
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...				Designed by AMuthusami Checked by				
XP Solutions				Network 2018.1.1				
<u>Summary of Critical Results by Maximum Level (Rank 1) for Surface Network 1</u>								
		Water	Surcharged	Flooded			Pipe	
	US/MH	Level	Depth	Volume	Flow / Overflow	Pipe	Flow	Level
PN	Name	(m)	(m)	(m³)	Cap.	(l/s)	(l/s)	Exceeded
19.011	S105	6.337	1.287	0.000	0.15		4.0	SURCHARGED
©1982-2018 Innovyze								

RSK LDE						Page 105		
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT				Drove Lane, Yapton Surface Water Network Calculations - FEH Data				
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...				Designed by AMuthusami Checked by				
XP Solutions				Network 2018.1.1				
<u>Summary of Critical Results by Maximum Level (Rank 1) for Surface Network 1</u>								
PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surcharge	First (Y) Flood	First (Z) Overflow	Overflow Act.
24.000	S106	15 Winter	100	+40%				
24.001	S107	15 Winter	100	+40%	100/15 Summer			
24.002	S108	960 Winter	100	+40%	100/120 Winter			
24.003	S109	960 Winter	100	+40%	100/60 Winter			
19.012	S110	960 Winter	100	+40%	100/60 Summer			
25.000	S113	15 Winter	100	+40%	100/15 Summer	100/15 Summer		
25.001	S114	30 Winter	100	+40%	100/15 Summer	100/15 Summer		
25.002	S115	15 Winter	100	+40%	100/15 Summer	100/15 Summer		
25.003	S116	120 Winter	100	+40%	100/15 Summer			
25.004	S117	120 Winter	100	+40%	100/15 Summer			
25.005	S118	120 Winter	100	+40%	100/15 Summer			
25.006	S119	120 Winter	100	+40%	100/15 Summer			
25.007	S120	120 Winter	100	+40%	100/15 Summer			
26.000	S121	30 Winter	100	+40%	100/15 Summer			
26.001	S122	30 Winter	100	+40%	100/15 Summer			
26.002	S123	30 Winter	100	+40%	100/15 Summer			
26.003	S124	15 Winter	100	+40%	100/15 Summer			
26.004	S125	15 Winter	100	+40%	100/15 Summer			
27.000	S126	120 Winter	100	+40%	100/15 Summer			
19.013	S127	120 Winter	100	+40%	100/15 Summer			
28.000	S128	240 Winter	100	+40%	100/60 Summer			
28.001	S129	240 Winter	100	+40%	100/60 Summer			
19.014	S130	240 Winter	100	+40%	100/15 Summer			
29.000	S131	480 Winter	100	+40%	100/60 Summer			
29.001	S132	480 Winter	100	+40%	100/30 Winter			
29.002	S133	480 Winter	100	+40%	100/30 Winter			
19.015	S134	480 Winter	100	+40%	100/15 Summer			
30.000	S135	480 Winter	100	+40%	100/60 Summer			
19.016	S136	480 Winter	100	+40%	100/15 Summer			
31.000	S137	480 Winter	100	+40%	100/60 Summer			
19.017	S138	480 Winter	100	+40%	100/15 Summer			
32.000	S139	15 Winter	100	+40%	100/15 Summer			
32.001	S140	60 Winter	100	+40%	100/15 Summer			
32.002	S141	480 Winter	100	+40%	100/15 Summer			
33.000	S142	480 Winter	100	+40%	100/60 Summer			
32.003	S143	480 Winter	100	+40%	100/15 Summer			
19.018	S144	480 Winter	100	+40%	100/15 Summer			
34.000	S145	15 Winter	100	+40%	100/15 Summer			
35.000	S146	15 Winter	100	+40%	100/15 Summer			
34.001	S147	1440 Winter	100	+40%	100/15 Summer			
34.002	S148	1440 Winter	100	+40%	100/15 Summer			
34.003	S149	1440 Winter	100	+40%	100/15 Summer			
34.004	S150	1440 Winter	100	+40%	100/15 Summer			
36.000	S151	1440 Winter	100	+40%	100/15 Summer			
19.019	S152	1440 Winter	100	+40%	100/15 Summer			
37.000	S153	1440 Winter	100	+40%	100/30 Winter			
38.000	S154	1440 Winter	100	+40%	100/15 Winter			
19.020	S155	1440 Winter	100	+40%	100/15 Summer			
19.021	S156	1440 Winter	100	+40%	100/15 Summer			
©1982-2018 Innovyze								

RSK LDE							Page 106		
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT				Drove Lane, Yapton Surface Water Network Calculations - FEH Data					
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...				Designed by AMuthusami Checked by					
XP Solutions				Network 2018.1.1					
<u>Summary of Critical Results by Maximum Level (Rank 1) for Surface Network 1</u>									
PN	US/MH Name	Water Level (m)	Surcharged Depth (m)	Flooded Volume (m³)	Flow / Cap.	Overflow (l/s)	Pipe Flow (l/s)	Status	Level Exceeded
24.000	S106	6.382	-0.078	0.000	0.47		7.0	OK	
24.001	S107	6.344	0.034	0.000	1.09		16.6	SURCHARGED	
24.002	S108	6.338	0.218	0.000	0.04		1.5	SURCHARGED	
24.003	S109	6.337	0.687	0.000	0.05		1.8	SURCHARGED	
19.012	S110	6.336	1.286	0.000	0.06		3.7	SURCHARGED	
25.000	S113	7.004	0.804	4.082	1.98		17.2	FLOOD	5
25.001	S114	6.818	0.668	13.935	2.78		12.2	FLOOD	8
25.002	S115	6.853	0.723	3.823	4.37		22.3	FLOOD	4
25.003	S116	6.638	0.538	0.000	0.93		7.6	SURCHARGED	
25.004	S117	6.619	0.519	0.000	2.02		8.5	SURCHARGED	
25.005	S118	6.569	0.479	0.000	1.36		8.4	SURCHARGED	
25.006	S119	6.542	0.452	0.000	1.96		8.4	SURCHARGED	
25.007	S120	6.494	0.424	0.000	1.00		8.3	FLOOD RISK	
26.000	S121	6.689	0.289	0.000	0.34		11.4	FLOOD RISK	
26.001	S122	6.670	0.320	0.000	0.53		10.6	SURCHARGED	
26.002	S123	6.634	0.434	0.000	1.20		10.7	SURCHARGED	
26.003	S124	6.623	0.473	0.000	2.01		12.8	FLOOD RISK	
26.004	S125	6.647	0.497	0.000	2.45		33.0	FLOOD RISK	
27.000	S126	6.484	0.309	0.000	0.35		4.7	FLOOD RISK	
19.013	S127	6.474	1.534	0.000	0.26		10.8	FLOOD RISK	
28.000	S128	6.225	0.195	0.000	0.14		2.2	SURCHARGED	
28.001	S129	6.225	0.285	0.000	0.10		2.2	SURCHARGED	
19.014	S130	6.224	1.324	0.000	0.15		9.8	SURCHARGED	
29.000	S131	6.039	0.579	0.000	0.01		0.3	SURCHARGED	
29.001	S132	6.039	0.769	0.000	0.02		0.3	SURCHARGED	
29.002	S133	6.039	0.889	0.000	0.07		2.1	FLOOD RISK	
19.015	S134	6.038	1.278	0.000	0.39		8.2	SURCHARGED	
30.000	S135	6.030	0.330	0.000	0.03		1.3	SURCHARGED	
19.016	S136	6.030	1.270	0.000	0.13		7.5	SURCHARGED	
31.000	S137	5.686	0.436	0.000	0.06		2.2	SURCHARGED	
19.017	S138	5.685	0.985	0.000	0.44		9.5	FLOOD RISK	
32.000	S139	5.975	0.545	0.000	1.67		24.6	SURCHARGED	
32.001	S140	5.708	0.428	0.000	1.41		20.6	FLOOD RISK	
32.002	S141	5.690	0.570	0.000	0.49		7.0	FLOOD RISK	
33.000	S142	5.687	0.249	0.000	0.08		1.8	SURCHARGED	
32.003	S143	5.685	0.625	0.000	0.38		10.7	SURCHARGED	
19.018	S144	5.678	0.978	0.000	0.09		10.7	FLOOD RISK	
34.000	S145	6.079	0.659	0.000	1.41		22.3	SURCHARGED	
35.000	S146	5.306	0.056	0.000	0.64		27.0	SURCHARGED	
34.001	S147	5.161	0.211	0.000	0.03		2.9	SURCHARGED	
34.002	S148	5.161	0.431	0.000	0.05		3.5	SURCHARGED	
34.003	S149	5.160	0.500	0.000	0.06		4.2	SURCHARGED	
34.004	S150	5.160	0.590	0.000	0.07		5.3	SURCHARGED	
36.000	S151	5.160	0.440	0.000	0.03		0.6	SURCHARGED	
19.019	S152	5.159	0.709	0.000	0.28		16.2	SURCHARGED	
37.000	S153	5.156	0.431	0.000	0.01		0.4	SURCHARGED	
38.000	S154	5.156	0.556	0.000	0.01		0.2	SURCHARGED	
19.020	S155	5.156	0.736	0.000	0.64		16.8	SURCHARGED	
©1982-2018 Innovyze									

RSK LDE							Page 107	
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT				Drove Lane, Yapton Surface Water Network Calculations - FEH Data				
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...				Designed by AMuthusami Checked by				
XP Solutions				Network 2018.1.1				
<u>Summary of Critical Results by Maximum Level (Rank 1) for Surface Network 1</u>								
						</		

RSK LDE						Page 108		
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT				Drove Lane, Yapton Surface Water Network Calculations - FEH Data				
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...				Designed by AMuthusami Checked by				
XP Solutions				Network 2018.1.1				
<u>Summary of Critical Results by Maximum Level (Rank 1) for Surface Network 1</u>								
PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surcharge	First (Y) Flood	First (Z) Overflow	Overflow Act.
19.022	S157	1440 Winter	100	+40%	100/15 Summer			
39.000	S158	1440 Winter	100	+40%	100/60 Winter			
39.001	S159	1440 Winter	100	+40%	100/15 Summer			
39.002	S160	1440 Winter	100	+40%	100/15 Summer			
40.000	S161	1440 Winter	100	+40%	100/15 Summer			
19.023	S162	1440 Winter	100	+40%	100/15 Summer			
19.024	S163	1440 Winter	100	+40%	100/15 Summer			
1.022	S164	1440 Winter	100	+40%	100/15 Summer			
1.023	S165	1440 Winter	100	+40%	100/120 Summer			
1.024	S166	1440 Winter	100	+40%	100/120 Summer			
41.000	S167	15 Winter	100	+40%	100/15 Summer			
42.000	S168	15 Winter	100	+40%				
41.001	S169	15 Winter	100	+40%	100/15 Summer			
43.000	S170	15 Winter	100	+40%	100/15 Summer			
43.001	S171	15 Winter	100	+40%	100/15 Summer			
41.002	S172	1440 Winter	100	+40%	100/15 Summer			
41.003	S173	1440 Winter	100	+40%	100/15 Summer			
44.000	S174	1440 Winter	100	+40%	100/15 Summer			
41.004	S175	1440 Winter	100	+40%	100/15 Summer			
1.025	S176	1440 Winter	100	+40%	100/60 Winter			
1.026	S177	1440 Winter	100	+40%	100/120 Summer	100/960 Winter		
45.000	S178	15 Summer	100	+40%				
45.001	S179	60 Winter	100	+40%	100/15 Winter			
45.002	S180	15 Winter	100	+40%	100/15 Summer			
45.003	S181	480 Winter	100	+40%	100/360 Winter			
45.004	S182	480 Winter	100	+40%	100/240 Winter			
46.000	S183	15 Winter	100	+40%	100/15 Summer			
45.005	S184	480 Winter	100	+40%	100/15 Summer			
45.006	S185	480 Winter	100	+40%	100/15 Summer			
45.007	S186	480 Winter	100	+40%	100/15 Summer			
45.008	S187	480 Winter	100	+40%	100/15 Summer			
45.009	S188	480 Winter	100	+40%	100/15 Winter			
45.010	S189	480 Winter	100	+40%	100/15 Summer			
45.011	S190	480 Winter	100	+40%	100/30 Winter			
47.000	S191	480 Winter	100	+40%	100/480 Winter			
47.001	S192	480 Winter	100	+40%	100/240 Winter			
45.012	S193	480 Winter	100	+40%	100/30 Winter			
45.013	S194	480 Winter	100	+40%	100/60 Summer			
48.000	S195	15 Winter	100	+40%	100/15 Summer			
49.000	S196	15 Winter	100	+40%				
48.001	S197	15 Winter	100	+40%	100/15 Summer			
48.002	S198	15 Winter	100	+40%	100/15 Summer			
48.003	S199	480 Winter	100	+40%	100/15 Summer			
48.004	S200	480 Winter	100	+40%	100/15 Summer			
45.014	S201	480 Winter	100	+40%	100/15 Winter			
50.000	S202	480 Winter	100	+40%	100/360 Winter			
50.001	S203	480 Winter	100	+40%	100/120 Winter			
50.002	S204	480 Winter	100	+40%	100/120 Summer			
50.003	S205	480 Winter	100	+40%	100/15 Summer			
©1982-2018 Innovyze								

RSK LDE							Page 109		
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT				Drove Lane, Yapton Surface Water Network Calculations - FEH Data					
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...				Designed by AMuthusami Checked by					
XP Solutions				Network 2018.1.1					
<u>Summary of Critical Results by Maximum Level (Rank 1) for Surface Network 1</u>									

RSK LDE							Page 110	
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT				Drove Lane, Yapton Surface Water Network Calculations - FEH Data				
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...				Designed by AMuthusami Checked by				
XP Solutions				Network 2018.1.1				
<u>Summary of Critical Results by Maximum Level (Rank 1) for Surface Network 1</u>								
		Water	Surcharged	Flooded			Pipe	
	US/MH	Level	Depth	Volume	Flow / Overflow	Pipe	Flow	Level
PN	Name	(m)	(m)	(m³)	Cap.	(l/s)	(l/s)	Exceeded
50.003	S205	5.401	0.751	0.000	0.23		3.1	FLOOD RISK
©1982-2018 Innovyze								

RSK LDE						Page 111	
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT				Drove Lane, Yapton Surface Water Network Calculations - FEH Data			
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...				Designed by AMuthusami Checked by			
XP Solutions				Network 2018.1.1			
<u>Summary of Critical Results by Maximum Level (Rank 1) for Surface Network 1</u>							
PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surcharge	First (Y) Flood	First (Z) Overflow Overflow Act.
45.015	S206	480 Winter	100	+40%	100/30 Winter		
51.000	S207	15 Winter	100	+40%	100/15 Summer		
52.000	S208a	15 Winter	100	+40%	100/15 Winter		
51.001	S208	15 Winter	100	+40%	100/15 Summer		
51.002	S209	15 Winter	100	+40%	100/15 Summer		
51.003	S210	15 Winter	100	+40%	100/15 Summer		
53.000	S211	15 Winter	100	+40%			
51.004	S212	15 Winter	100	+40%	100/15 Summer		
54.000	S213	15 Winter	100	+40%			
51.005	S214	15 Winter	100	+40%	100/15 Winter		
55.000	S215	15 Winter	100	+40%	100/15 Summer		
51.006	S216	480 Winter	100	+40%	100/15 Winter		
56.000	S217	480 Winter	100	+40%	100/15 Summer		
51.007	S218	480 Winter	100	+40%	100/15 Summer		
51.008	S219	480 Winter	100	+40%	100/15 Summer		
51.009	S220	480 Winter	100	+40%	100/15 Summer		
51.010	S221	480 Winter	100	+40%	100/15 Summer		
45.016	S222	480 Winter	100	+40%	100/15 Summer		
57.000	S223	480 Winter	100	+40%	100/15 Summer		
57.001	S224	480 Winter	100	+40%	100/15 Summer		
45.017	S225	480 Winter	100	+40%	100/15 Summer		
58.000	S226	15 Winter	100	+40%			
58.001	S227	15 Winter	100	+40%	100/15 Summer		
58.002	S228	15 Winter	100	+40%	100/15 Summer		
58.003	S229	960 Winter	100	+40%	100/15 Summer		
45.018	S230	960 Winter	100	+40%	100/60 Summer		
45.019	S231	960 Winter	100	+40%	100/60 Summer		
45.020	S232	960 Winter	100	+40%	100/30 Summer		
45.021	S233	960 Winter	100	+40%	100/15 Summer		
59.000	S234	15 Winter	100	+40%	100/15 Summer		
59.001	S235	15 Winter	100	+40%	100/15 Summer		
60.000	S236	15 Winter	100	+40%			
59.002	S237	15 Winter	100	+40%	100/15 Summer		
61.000	S238	15 Winter	100	+40%			
61.001	S239	15 Winter	100	+40%	100/15 Summer		
59.003	S240	15 Winter	100	+40%	100/15 Summer		
59.004	S241	15 Winter	100	+40%	100/15 Summer		
62.000	S242	960 Winter	100	+40%	100/15 Summer		
59.005	S243	960 Winter	100	+40%	100/15 Summer		
59.006	S244	960 Winter	100	+40%	100/15 Summer		
59.007	S245	960 Winter	100	+40%	100/15 Summer		
45.022	S246	960 Winter	100	+40%	100/15 Summer		
63.000	S247	15 Summer	100	+40%	100/15 Summer		
63.001	S248	1440 Winter	100	+40%	100/960 Winter		
45.023	S249	1440 Winter	100	+40%	100/120 Summer		
1.027	S250	1440 Winter	100	+40%	100/120 Summer	100/1440 Winter	
1.028	S251	1440 Winter	100	+40%	100/120 Summer		
©1982-2018 Innovyze							

RSK LDE							Page 112		
18 Frogmore Road Hemel Hempstead Hertfordshire HP3 9RT				Drove Lane, Yapton Surface Water Network Calculations - FEH Data					
Date 18/03/2021 13:32 File 133981 - Drove Lane, Ya...				Designed by AMuthusami Checked by					
XP Solutions				Network 2018.1.1					
<u>Summary of Critical Results by Maximum Level (Rank 1) for Surface Network 1</u>									
PN	US/MH Name	Water Level (m)	Surcharged Depth (m)	Flooded Volume (m³)	Flow / Cap.	Overflow (l/s)	Pipe Flow (l/s)	Status	Level Exceeded
45.015	S206	5.400	0.650	0.000	0.05		6.0	FLOOD RISK	
51.000	S207	6.136	0.336	0.000	0.87		12.5	SURCHARGED	
52.000	S208a	6.050	0.025	0.000	0.89		16.7	SURCHARGED	
51.001	S208	6.064	0.354	0.000	1.50		17.6	SURCHARGED	
51.002	S209	6.023	0.363	0.000	0.64		19.3	SURCHARGED	
51.003	S210	6.015	0.390	0.000	1.08		38.9	SURCHARGED	
53.000	S211	6.103	-0.067	0.000	0.58		28.4	OK	
51.004	S212	5.864	0.359	0.000	1.90		66.6	SURCHARGED	
54.000	S213	5.460	-0.020	0.000	0.54		9.8	OK	
51.005	S214	5.433	0.063	0.000	1.00		84.4	SURCHARGED	
55.000	S215	5.549	0.169	0.000	1.32		29.0	SURCHARGED	
51.006	S216	5.409	0.159	0.000	0.15		17.6	SURCHARGED	
56.000	S217	5.405	0.555	0.000	0.13		1.7	SURCHARGED	
51.007	S218	5.404	0.594	0.000	0.20		19.9	SURCHARGED	
51.008	S219	5.399	0.839	0.000	0.32		19.7	SURCHARGED	
51.009	S220	5.397	0.897	0.000	0.27		21.1	FLOOD RISK	
51.010	S221	5.395	0.995	0.000	0.44		21.0	FLOOD RISK	
45.016	S222	5.393	1.013	0.000	0.78		15.8	FLOOD RISK	
57.000	S223	5.382	0.942	0.000	0.02		1.1	FLOOD RISK	
57.001	S224	5.382	0.982	0.000	0.02		1.0	FLOOD RISK	
45.017	S225	5.382	1.002	0.000	0.48		10.5	FLOOD RISK	
58.000	S226	5.212	-0.118	0.000	0.10		2.9	OK	
58.001	S227	4.889	0.089	0.000	0.92		14.1	SURCHARGED	
58.002	S228	4.859	0.159	0.000	1.35		25.5	SURCHARGED	
58.003	S229	4.717	0.217	0.000	0.19		2.4	SURCHARGED	
45.018	S230	4.716	0.356	0.000	0.24		10.7	SURCHARGED	
45.019	S231	4.712	0.372	0.000	0.17		10.7	SURCHARGED	
45.020	S232	4.700	0.450	0.000	0.17		10.5	SURCHARGED	
45.021	S233	4.693	0.493	0.000	0.11		10.6	SURCHARGED	
59.000	S234	5.387	0.377	0.000	1.22		19.0	SURCHARGED	
59.001	S235	5.170	0.350	0.000	1.23		18.6	SURCHARGED	
60.000	S236	5.103	-0.117	0.000	0.11		4.7	OK	
59.002	S237	5.055	0.325	0.000	1.10		22.0	SURCHARGED	
61.000	S238	5.358	-0.107	0.000	0.18		8.6	OK	
61.001	S239	4.996	0.246	0.000	0.62		16.9	SURCHARGED	
59.003	S240	4.913	0.463	0.000	0.47		33.5	SURCHARGED	
59.004	S241	4.823	0.453	0.000	1.00		75.4	SURCHARGED	
62.000	S242	4.691	0.141	0.000	0.03		1.2	SURCHARGED	
59.005	S243	4.690	0.570	0.000	0.15		8.6	SURCHARGED	
59.006	S244	4.688	0.618	0.000	0.22		9.7	SURCHARGED	
59.007	S245	4.686	0.636	0.000	0.20		9.7	SURCHARGED	
45.022	S246	4.685	0.635	0.000	0.56		14.4	SURCHARGED	
63.000	S247	4.549	0.054	0.000	1.27		18.7	SURCHARGED	
63.001	S248	4.456	0.056	0.000	0.04		0.8	SURCHARGED	
45.023	S249	4.456	0.406	0.000	0.19		11.9	FLOOD RISK	
1.027	S250	4.452	0.452	0.634	0.30		18.2	FLOOD	1
1.028	S251	4.440	0.490	0.000	0.30		18.2	FLOOD RISK	
©1982-2018 Innovyze									