

Amanda Scholes | Receptionist, Department, Arun District Council | Location: Ground Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37736 | External: +44 (0) 1903 737500 ext 37736 | E-mail: amanda.scholes@arun.gov.uk



Visit Arun's web site at [Error! Hyperlink reference not valid.](#)



Save the environment - think before you print.

From: Sarah Burrow <Sarah.Burrow@arun.gov.uk>

Sent: 03 July 2020 14:01

To: Planning.Responses <Planning.Responses@arun.gov.uk>

Cc: Amber Willard <Amber.Willard@arun.gov.uk>

Subject: RE: Planning Consultation on: Y/50/20/DOC

Engineers Comments Regarding Surface Water Drainage

Please amend the inspection chamber to a catch pit (provide a sump). Once this is done I will be happy to recommend discharge of condition 3.

Kind Regards

Sarah Burrow

Engineering Assistant, Engineers

T: 01903 737815

E: sarah.burrow@arun.gov.uk



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

Sign up to our newsletter [here](#)



From: Planning.Responses <Planning.Responses@arun.gov.uk>
Sent: 11 June 2020 12:04
To: Land Drainage [REDACTED]
Subject: Planning Consultation on: Y/50/20/DOC

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

Application No: Y/50/20/DOC
Registered: 10th June 2020
Site Address: Rookery Cottage Hoe Lane Flansham PO22 8NT
Description of Works: Approval of details reserved by condition imposed under ref Y/72/19/HH relating to Condition No 3 - surface water drainage.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you wish to make any comments click on the link www.arun.gov.uk/planning and click into ?Enter Comment? or if this is not possible email your response to planning.responses@arun.gov.uk by **25th June 2020**.

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

Yours sincerely

Amber Willard

Planning Case Officer- Arun District Council

Telephone: 01903 737500 x37445

Email: amber.willard@arun.gov.uk

FLCOND00 (ODS) 2020