



Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex BN17 5LF
Planning General Enquiries
Tel: (01903) 737756 Fax: (01903) 730442
Dx: 57406 Littlehampton
Minicom: 01903 732765
e-mail: planning@arun.gov.uk

Mr R Hawks
Yapton Free Church
The Old Church Building
Main Road
Yapton
BN18 0EA

Your Ref: Y/51/17/DOC

Please ask for:

Mr Z Denton

15 February 2018

Dear Mr Hawks

Town & Country Planning Act 1990 (as amended)
Town and Country Planning (Development Management Procedure) (England) Order 2015
Application for approval of details reserved by conditions imposed under planning application
Y/11/16/PL relating to Condition No. 3 (Surface water drainage details) & 4 (Schedule & samples
materials and finishes for external walls and roofs)
Yapton Free Church The Old Church Building, Main Road, Yapton

Notification regarding the above application:

Condition Number 3

Development shall not commence until full details of the proposed surface water drainage scheme have been submitted to and approved in writing by the Local Planning Authority.

The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, the recommendations of the SUDS Manual produced by CIRIA.

Winter groundwater monitoring to establish highest annual ground water levels and Percolation testing to BRE 365, or similar approved, will be required to support the design of any Infiltration drainage.

No building shall be occupied until the complete surface water drainage system serving the property has been implemented in accordance with the agreed details and the details so agreed shall be maintained in good working order in perpetuity.

Reason: To ensure that the proposed development is satisfactorily drained in accordance with policies GEN7 and GEN9 of the Arun District Council Local Plan.

Decision:

Arun District Council have decided to **APPROVE details reserved by this condition**
The Council's Drainage Engineers have been consulted and the details submitted are considered to meet the aims and requirements of the condition.

The approved details are hereby:

- Proposed Drainage & consultation Details - June 2017 - 22815 - 201 - Rev A
- Appendix 3 Micro Drainage Report ref 22811 Yapton Free Church - 12/01/18

The condition is therefore fully discharged insofar as the submission of details relates and on docdeci

the understanding that the surface water drainage scheme will be implemented in accordance with the approved scheme and permanently retained in good working order thereafter.

Please do not hesitate to contact the above officer if you require any further assistance.

Yours sincerely

A handwritten signature in black ink, appearing to be 'NC' followed by a flourish and a period.

Neil Crowther
Group Head of Planning