

Arun District Council, Civic Centre, Maltravers Rd
Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

To register to receive notifications of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>



From: FRS Water and Access [REDACTED]
Sent: 30 March 2023 11:36
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: Planning consultation - Y/60/22/PL - Longacre Maypole Lane Yapton BN18 0DR

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

FAO: Amber Willard


Dear Amber,

I am writing to inform you that the fire hydrant condition for this planning application has been met. A new development adjacent to this site is nearing completion and in consultation

and agreement with Portsmouth Water two additional fire hydrants will be installed. One of these fire hydrants will be within either 50m or 145m depending on the access route available to the new build property, either of which will be within the required distance. Therefore the fire hydrant condition raised for this planning application can be discharged.

Regards

Ian



Ian Stocks
Water & Access Manager - Protection
West Sussex Fire & Rescue Service

[REDACTED]
Web www.westsussex.gov.uk/fire

[REDACTED]
Bognor Regis Fire Station, West Meads Drive, West Sussex, PO21 5TB

My pronouns are **he/him/his** A small icon representing pronouns, showing a grid of letters.

[Click here to find out why we use pronouns in our signatures](#)

LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.
