

[REDACTED]

From: Simon Davis
Sent: 31 July 2019 11:25
To: Rebecca Redford [REDACTED]
Subject: Y/61/19/PL - Yapton Metal Company

Dear Rebecca,

I have identified a couple of issues with the plans (the elevations when compared to the block plan) and these need to be fixed:

- Unit 3 has no bins shown on the block plan
- The unit 1 elevations are missing a GF kitchen window on the east elevation
- Unit 3 has a window shown on the GF south elevation where the block plan indicates a door.

I would also like to take this opportunity to request that you change the rear garden fencing to hedging for units 1 & 2. I understand that full height hedges can be purchased.

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk
Please note that I typically work from home on Thursdays when I am unreachable on my work phone

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.