





Please upload the below to the above application; Correspondence



Visit Arun's web site at [www.arun.gov.uk](http://www.arun.gov.uk)



Save the environment - think before you print.



Dear Susan,

Please see below the comments of Environmental Health Officer:

I refer to the above application for discharge of conditions and make the following comments;

- Our database suggests there may be fuel tanks on site but this does not feature in the risk assessment. This should be checked, the authors can check with West Sussex County Council
- The report needs to include a requirement for a watching brief so that if anything previously unidentified is encountered, it is suitably addressed.

The full condition cannot be discharged until all groundworks have been completed (to account for any previously unidentified contamination), however if the above issues are addressed and submitted for approval stages 1 and 2 of the condition can be signed off and the full condition discharged when all groundworks have been completed and a verification report has been submitted and approved.

Kind regards

Maria



**ARUN**  
DISTRICT COUNCIL

Community  
Infrastructure  
Levy

CIL is coming  
find out more...  
[www.arun.gov.uk/CIL](http://www.arun.gov.uk/CIL)

Visit Arun's web site at [www.arun.gov.uk](http://www.arun.gov.uk)



Save the environment - think before you print.