






From: Matthew Kennett

Sent: 22 December 2017 10:53

To: Richard Temple

Subject: RE: Y/68/17/PL Former Neptune/central Garage Premises, Main Road,Yapton Y/68/17/PL

Environmental Health advise;

Please apply the below conditions due to the previous use of the site thanks. Fuel tanks may exist onsite.

ENV3 Universal condition for development on land affected by contamination

Environmental Health position

We consider that planning permission should only be granted to the proposed development as submitted if the following planning condition is imposed as set out below. Without this condition, the proposed development on this site poses an unacceptable risk to the environment and we would wish to object to the application.

Condition: Prior to the commencement of development (parts 1, 2) and prior to occupation (parts 3, 4) approved by this planning permission (or such other date or stage in development as may be agreed in writing with the Local Planning Authority), the following components of a scheme to deal with the risks associated with contamination of the site shall each be submitted to and approved, in writing, by the local planning authority:

1. A preliminary risk assessment which has identified:
 - all previous uses
 - potential contaminants associated with those uses
 - a conceptual model of the site indicating sources, pathways and receptors
 - potentially unacceptable risks arising from contamination at the site.
2. A site investigation scheme, based on (1) to provide information for a detailed assessment of the risk to all receptors that may be affected, including those off site.
3. The site investigation results and the detailed risk assessment (2) and, based on these, an options appraisal and remediation strategy giving full details of the remediation measures required and how they are to be undertaken.
4. A verification plan providing details of the data that will be collected in order to demonstrate that the works set out in (3) are complete and identifying any requirements for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action.

Any changes to these components require the express consent of the local planning authority. The scheme shall be implemented as approved.

Reason

To ensure that the development complies with approved details in the interests of protection of the environment and prevention of harm to human health in accordance with policies GEN7 and GEN31 of the Arun District Local Plan .

ENV 5 Unsuspected contamination

Environmental Health position

We consider that planning permission should only be granted to the proposed development as submitted if the following planning condition is imposed as set out below. Without this condition, the proposed development on this site poses an unacceptable risk to the environment and we would wish to object to the application.

Condition: If, during development, contamination not previously identified is found to be present at the site then no further development (unless otherwise agreed in writing with the Local Planning Authority) shall be carried out until the developer has submitted, and obtained written approval from the Local Planning Authority for, an amendment to the remediation strategy detailing how this unsuspected contamination shall be dealt with.

Reason

To ensure that the development complies with approved details in the interests of protection of the environment and prevention of harm to human health in accordance with policies GEN7 and GEN31 of the Arun District Local Plan

ENV 6 Verification report

Environmental Health position

We consider that planning permission should only be granted to the proposed development as submitted if the following planning condition is imposed as set out below. Without this condition, the proposed development on this site poses an unacceptable risk to the environment and we would wish to object to the application.

Condition: Prior to occupation of any part of the permitted development, a verification report demonstrating completion of the works set out in the approved remediation strategy and the effectiveness of the remediation shall be submitted to and approved, in writing, by the local planning authority. The report shall include results of sampling and monitoring carried out in accordance with the approved verification plan to demonstrate that the site remediation criteria have been met. It shall also include any plan (a "long-term monitoring and maintenance plan") for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action, as identified in the verification plan, and for the reporting of this to the local planning authority.

REASON

To ensure that the development complies with approved details in the interests of protection of the environment and prevention of harm to human health in accordance with policies GEN7 and GEN31 of the Arun District Local Plan.

thanks

Matthew Kennett
Snr. Pollution Officer
Environmental Health Department
01903 737696 (direct line)
Arun Civic Centre, Maltravers Road, Littlehampton BN17 5LF
<http://www.arun.gov.uk/eh>



From: Richard Temple
Sent: 22 December 2017 10:49
To: Matthew Kennett
Subject: RE: Y/68/17/PL Former Neptune/central Garage Premises, Main Road,Yapton Y/68/17/PL

Thanks Matt,

We'd like to make a recommendation today if possible so which conditions would you suggest?

Regards,

Richard Temple | Senior Planning Officer, Directorate of Place, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37591 | External: +44 (0) 1903 737591 | E-mail: Richard.temple@arun.gov.uk

Please note this information is given without prejudice and represents the informal view of the officer and not an official opinion of Arun District Council.

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Matthew Kennett
Sent: 22 December 2017 10:48
To: Richard Temple
Subject: RE: Y/68/17/PL Fromer Neptune/central Garage Premises, Main Road,Yapton Y/68/17/PL

Hi Richard,

Definitely one for a contam condition,

Thanks for the heads up.

Happy Christmas

Matthew Kennett
Snr. Pollution Officer
Environmental Health Department
01903 737696 (direct line)
Arun Civic Centre, Maltravers Road, Littlehampton BN17 5LF
<http://www.arun.gov.uk/eh>




From: Richard Temple
Sent: 22 December 2017 10:46
To: Matthew Kennett
Subject: Y/68/17/PL Fromer Neptune/central Garage Premises, Main Road,Yapton Y/68/17/PL

Hi Matt,

I am consulting EH (have done formally also) on the above as the application is to convert the former garage (vacant and derelict, fire damaged building, see photos attached) to a dwelling. The garage was car repair so we feel the land could be contaminated. Pemrission was granted for a 5000 gallon petrol storage tank to be installed in 1963 and although this may not have been installed, it seems there were definitely petrol pumps on site previously.

Please see map below:-



Regards and have a good xmas,

Richard Temple | Senior Planning Officer, Directorate of Place, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37591 | External: +44 (0) 1903 737591 | E-mail: Richard.temple@arun.gov.uk

Please note this information is given without prejudice and represents the informal view of the officer and not an official opinion of Arun District Council.

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.