

[REDACTED]

From: Simon Davis

Sent: 15 February 2022 13:57

To: David Linton-Clowes [REDACTED] Peter Cleveland [REDACTED]

Cc: Katherine Child [REDACTED]

Subject: RE: Planning Consultation on: Y/6/22/DOC

Dear David,

Advice received today:

The condition was worded to state the verification report needed to be completed by an independent engineer. However, we've accepted it not being an independent company on another site where we had significant push back where the engineer personally was not involved in design. So if the author personally did not have involvement with design, I think we could agree to Odyssey being the author IF the report contents were robust.

As detailed in my formal response we have a number of issues regarding the report contents and how the verification has been completed, namely:

- 1. "Odyssey did not have site presence during construction to be able to verify the SuDS elements of the drainage scheme were installed as per the approved design". A verification report must be completed by an independent engineer who has visited site during construction to inspect the works.*
- 2. The report also acknowledges that no inspections of catchpits have been completed and that the base course had not yet been drilled on the roadway.*
- 3. Survey information is missing for some of the infiltration blankets.*
- 4. Some considerable differences to design have been noted, with no comments provided as to how these may impact upon the functionality of the system.*

Please confirm that the author of the report had no involvement in the design and then also respond to the other 3 points. Please respond by 01 February.

Kind Regards

Simon J Davis MRTPI
Principal Planning Officer
Directorate of Place

T: 01903 737874

E: simon.davis@arun.gov.uk



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

To register to receive notification of planning applications in your area please go to <https://www1.arun.gov.uk/planning-application-finder>

Arun is a CIL Charging Authority, for more information go to www.arun.gov.uk/cil

Sign up to our newsletter [here](#)



From: David Linton-Clowes [REDACTED]
Sent: 15 February 2022 13:45
To: Simon Davis <Simon.Davis@arun.gov.uk>; Peter Cleveland [REDACTED]
Cc: Katherine Child [REDACTED]
Subject: RE: Planning Consultation on: Y/6/22/DOC

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Hello Simon,

Have you managed to discuss this with Laura yet today?

David Linton-Clowes
Technical Manager

 dandara

Direct: Mobile: [REDACTED] • **HQ:** [REDACTED] • **E-mail:** [REDACTED] • **Web:** www.dandara.com
Dandara Ltd, Roman House, South Hampshire Industrial Estate, Eddystone Road, Totton, Southampton, SO40 3SA