



from
**Southern
Water**

Planning and Development Services
Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Your ref
Y/71/20/RES

Our ref
PLAN-034695

Date
23/09/2020



Dear Sir/Madam,

Proposal: Approval of reserved matters following outline consent Y/88/18/OUT for the erection of 38 No. dwellings. This application affects Public Rights of Way.

Site: Y/71/20/RES: - Land North of Yapton Church of England Primary School, North End Road, Yapton, BN18 0DU.

Thank you for your letter dated 20/08/2020.

Southern Water shall have no objections to the reserved matters application for appearance, landscaping, layout and scale.

Southern Water shall have no objections to discharge condition 08 relating to foul drainage as indicated in drawing YAP-130-20 Rev: A. An approval for the connection to the public sewer should be submitted under Section 106 of the Water Industry Act.

Any adoption proposals (under Section 104) should be agreed and approved by Southern Water. The drainage design should comply with the Sewerage Sector Guidance (water.org.uk/sewerage-sector-guidance-approved-documents/) standards and Southern Water's requirements. Please note that non-compliance with the Sewerage Sector Guidance standards will preclude future adoption of the foul sewerage network on site.

The Council's Building Control officers/technical staff and the Environment Agency should be consulted regarding condition 09 surface water drainage.

The applicant proposes to retain the surface water drainage within private ownership and maintenance.

Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX
southernwater.co.uk

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366670

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing,
West Sussex, BN13 3NX [REDACTED]

[REDACTED]

Yours faithfully,

[REDACTED]

Joff Edevane
Growth Planning Lead
Business Channels

Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX
southernwater.co.uk

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2368670

SOUTHERN WATER



The positions of pipes shown on this plan are believed to be correct, but Southern Water Services Ltd accept no responsibility in the event of inaccuracy. The actual positions should be determined on site.

Based upon Ordnance Survey Digital Data with the permission of the controller of H.M.S.O. Crown Copyright Reserved Licence No. WU 298530

O.S. REF: SU9703NE

Scale: 1:1250

Screen Print

WARNING: BAC pipes are constructed of Bonded Asbestos Cement

WARNING: Unknown (UNK) materials may include Bonded Asbestos Cement

ARUN DISTRICT COUNCIL Y/71/20/RES



Printed By: HMSHeth

Date: 18-9-2020

Southern Water MapGuide Browser

Requested By: