

Simon Davis

From: Daniel Medrow [REDACTED]
Sent: 17 September 2021 15:20
To: Simon Davis
Cc: Hannah Curry; Luke Hart; Alex Jordan
Subject: RE: Vistry Yapton - Y/72/21/DOC - Y/19/16/OUT
Attachments: 18-070 Drainage Note 17.09.21.pdf

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Simon,

Please find attached updated drainage note updating section 3.5.2 and including in appendix D, the extent of ditch regrading works.

To clarify:

- There will be no additional increase of SW flows into the ditch.
- The drainage system and pumping stations will be adopted by ICOSA who have the same powers as Southern water, all maintenance will be dealt with by them.
- The Drainage and pumping stations have been technically approved with the NAV agreement approved by OFFWAT.

I trust this is acceptable.

Regards

Daniel Medrow
Senior Technical Manager



Vistry South East
Linden House | Guards Avenue | Caterham
Surrey | CR3 5XL | 01883 334400



Part of the Vistry Group

From: Simon Davis <Simon.Davis@arun.gov.uk>
Sent: 24 August 2021 18:13
To: Daniel Medrow <[REDACTED]>
Cc: Hannah Curry <[REDACTED]>; Luke Hart <[REDACTED]>; Alex Jordan <[REDACTED]>
Subject: RE: Vistry Yapton - Y/72/21/DOC - Y/19/16/OUT