

From: Amanda Scholes on behalf of Planning.Responses
Sent: 19 September 2019 13:00
To: Planning Scanning
Subject: FW: Planning Consultation on: Y/74/19/PL

From: Laura Gibbons <[REDACTED]>
Sent: 19 September 2019 08:57
To: Planning.Responses <[REDACTED]>
Subject: RE: Planning Consultation on: Y/74/19/PL

Engineers Comments Regarding Surface Water Drainage

The application is within the Lidsey Catchment, surface water drainage should therefore be carefully designed and controlled.

If you are minded to approve the application please apply the following condition to ensure the development is adequately drained and does not increase flood risk elsewhere:

PCENG D2

"Development shall not commence, other than works of site survey and investigation, until full details of the proposed surface water drainage scheme have been submitted to and approved in writing by the Local Planning Authority. The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, and the recommendations of the SuDS Manual produced by CIRIA. Winter groundwater monitoring to establish highest annual ground water levels and winter Percolation testing to BRE 365, or similar approved, will be required to support the design of any Infiltration drainage. No building / No part of the extended building shall be occupied until the complete surface water drainage system serving the property has been implemented in accordance with the agreed details and the details so agreed shall be maintained in good working order in perpetuity."

Reason: To ensure that the proposed development is satisfactorily drained in accordance with policies W SP1, W DM1, W DM2 and W DM3 of the Arun Local Plan. This is required to be a pre-commencement condition because it is necessary to implement the surface water drainage system prior to commencing any building works.

And the accompanying informative:

INFORM D

"Infiltration rates for soakage structures are to be based on percolation tests undertaken in the winter period and at the location and depth of the proposed structures. The percolation tests must be carried out in accordance with BRE365, CIRIA R156 or a similar approved method and cater for the 1 in 10 year storm between the invert of the entry pipe to the soakaway, and the base of the structure. It must also have provision to ensure that there is capacity in the system to contain below ground level the 1 in 100 year event plus 40% on stored volumes, as an allowance for climate change. Adequate freeboard must be provided between the base of the soakaway structure and the highest recorded annual groundwater level identified in that location. Any SuDS or soakaway design must include adequate groundwater monitoring data to determine the highest winter groundwater table in support of the design. The applicant is advised to discuss the extent of groundwater monitoring with the Council's Engineers. Supplementary guidance notes regarding surface water drainage are located here <https://www.arun.gov.uk/surfacewater> on Arun District Councils website. A surface water drainage checklist is available here <https://www.arun.gov.uk/drainagechecklist> on Arun District Councils website, this should be submitted with a Discharge of Conditions Application."

Regards,

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: [planning.responses](#)
Sent: 05 September 2019 11:21
To: Land Drainage <Land.Drainage@arun.gov.uk>
Subject: Planning Consultation on: Y/74/19/PL

To: Engineers (Drainage)

NOTIFICATION FROM ARUN DISTRICT COUNCIL
Town & Country Planning Act 1990 (as amended)
Town and Country Planning (Development Management Procedure) (England) Order 2015
Planning Permission

APPLICATION NO: Y/74/19/PL

Registered: 2nd September
2019

Site Address: The Crickets Hoe Lane Flansham Bognor Regis PO22 8NT

Grid Reference: 495844 101360

Description of Works: Extension & alterations to main dwelling. Conversion of existing
annexe to three holiday letting units

The Council have received the above application. I shall be pleased to receive any
observations you may wish to make.

[Click here to view the application details](#)

**Should you have any comments to make, these should be sent by [replying to this email](#)
by 10-OCT-19.**

You can also monitor the progress of this application through the Council web site:
www.arun.gov.uk/planning

**Please be aware that any comments you may make will be available on our website so
please do not insert personal details or signatures on your reply.**

In the absence of a reply within the period stated, I shall assume that you have no observations
to make.

The application will be determined having regard to the development plan policies (if any are
relevant) and other material considerations. The development plan can be accessed via the
website as can the leaflet which deals with material planning considerations.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website: www.planningportal.gov.uk/planning/appeals/ but they will protect personal details.

The officer dealing with this application is Maria Tomalova who can be contacted on telephone number [REDACTED]

Regards
Planning Officer

consultee_email
