

From: Martyn White <Martyn.White@arun.gov.uk>

Sent: 21 July 2021 11:18

To: Simon Davis <Simon.Davis@arun.gov.uk>

Subject: Y/76/21/DOC

Y/76/21/DOC

Land at Street Buildings North End Road Yapton BN18 0DT

Approval of details reserved by condition imposed under ref Y/146/20/RES relating to Condition No 5 -full details(materials/appearance) of any required works to flint wall along North End Road frontage

The design of the flint wall seems to be generally acceptable and appears to replicate the existing wall. However, it is not clear how the southern end of the new section of flint walling will connect back to the neighbouring walling. At present, it looks as though the new section of wall terminates in front of, but not connected to, the neighbouring flint wall. Is this correct. If so, it will leave a section without any walling. Please can this be clarified.

Martyn White
Principal Conservation Officer,
Planning Services



Please note: I work on Conservation for half of the working Week (all day Monday and Friday and Tuesday Afternoons)

T: 01903 737717

E: Martyn.White@arun.gov.uk or Conservation.officer@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)

To register to receive notification of planning applications in your area please visit
www.arun.gov.uk/planning



