

From: Laura Gibbons <Laura.Gibbons@arun.gov.uk>
Sent: 22 June 2021 15:34
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Amy Myer <Amy.Myer@arun.gov.uk>
Subject: RE: Planning Consultation on: Y/80/21/DOC

Dear Amy,

Thank you for consulting us on this discharge of conditions application, we have the following comments.

Condition 7

1. Please can the applicant confirm the date of infiltration testing. Please also confirm the location at which infiltration testing was completed.
2. Infiltration testing was completed at 1.6m deep, yet permeable paving formation is proposed at only 430mm depth. Please provide infiltration testing results at shallow depth, or provide linkages to the deeper tested strata.
3. Please detail finish and formation level of permeable paving on plan.

Condition 8

It is not suitable to recommend discharge of this condition until drainage design has been agreed.

Please re-consult us once further information has been supplied.

Kind regards,

Laura Gibbons

Drainage Engineer

Engineering Services

Please note that I work Tuesdays 08:00-16:00 for Arun only.



T: 01903 221374

E: laura.gibbons@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

From: Planning.Responses <Planning.Responses@arun.gov.uk>

Sent: 11 June 2021 16:04

To: Land Drainage

Subject: Planning Consultation on: Y/80/21/DOC

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

Application No: Y/80/21/DOC
Registered: 8th June 2021
Site Address: Land East of North End Road and West of Church Lane Nursery Yapton BN18 0GA
Description of Works: Approval of details reserved by condition imposed under ref Y/18/20/PL relating to Condition Nos 7 - surface water drainage and 8 - maintenance & management of surface water drainage.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you wish to make any comments click on the link www.arun.gov.uk/planning and click into ?Enter Comment? or if this is not possible email your response to planning.responses@arun.gov.uk by **25th June 2021**.

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

Yours sincerely

Amy Myer

Planning Case Officer- Arun District Council

Telephone: 01903 737776

Email: amy.myer@arun.gov.uk

