




From: Fiona Fitzgerald
Sent: 02 March 2018 16:42
To: David Easton
Subject: Fwd: Y/91/17/O?UT & Y/92/17/OUT

Hi David,

Environmental Health has no objection in principle to these two applications. However I note that no Air Quality assessment has been submitted, and would request that this is done.

Environmental Health now has a requirement that each home should have an Electric Vehicle charge point. Reason: petrol and diesel cars will not be sold beyond 2040 and to mitigate against any potential adverse impact of the development on local Air Quality.

Please put a standard CEMP condition on any permissions given for these applications.

Matt Kennett will send comments on Contaminated Land separately.

Regards

Fiona

Sent from my iPad

Begin forwarded message:

From: Anna Appleton <Anna.Appleton@arun.gov.uk>
Date: 1 March 2018 at 10:18:35 GMT
To: Fiona Fitzgerald <Fiona.Fitzgerald@arun.gov.uk>
Cc: David Easton <David.Easton@arun.gov.uk>
Subject: FW: Y/91/17/O?UT & Y/92/17/OUT

Hi Fiona

Please could you respond. C no 222241.

Thanks

Anna

From: David Easton
Sent: 01 March 2018 09:32
To: Sue Howell; Anna Appleton
Subject: Y/91/17/OUT & Y/92/17/OUT

Dear Sue and Anna,

We consulted on the above applications on the 22nd December 2017 and we are still awaiting comments from Parks & Landscapes and Environmental Health.

Are you able to action this work as the consultation period for these applications has ended.

Many thanks,
David

David Easton | Principal Planning Officer, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road,
Littlehampton, BN17 5LF
Internal: 37619 | External: +44 (0) 1903 737619 | E-mail: David.Easton@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.