

From: Simon Davis
Sent: 25 January 2019 14:29
To: [REDACTED]
Cc: Daniel Vick <Daniel.Vick@arun.gov.uk>
Subject: FW: Y/92/18/DOC- Further Drainage Supporting Info

Dear Rosie,

Please see below further drainage comments. As the permission expires tomorrow and we are unable to discharge these pre-commencement conditions, I can't see any way around this other than by a fresh planning application to essentially renew the planning permission.

Please note that I am not available by phone today, back on Monday.

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk
Please note that I typically work from home on Thursdays when I am unreachable on my work phone

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Laura Gibbons
Sent: 25 January 2019 11:33
To: Simon Davis <Simon.Davis@arun.gov.uk>
Subject: RE: Y/92/18/DOC- Further Drainage Supporting Info

Hi Simon,

I have reviewed the document and have the following comments.

1. You are proposing on using permeable paving in areas where infiltration at 1m depth does not work. There is no proof submitted that demonstrates the drainage for the road has a point of discharge. You will need to complete infiltration testing at the formation level of permeable paving to determine if infiltration is viable. If it isn't a point of discharge to watercourse will be required.
2. Calculations regarding the permeable paving and swale will need to be submitted based on these results.
3. The swale is currently modelled with a free outflow point, this isn't the case in reality. Calculations need to be based on reality.
4. No quantification of the duration of flood events within maypole lane has been provided. I.e. please detail how long water will be held within the attenuation basin for before discharge to watercourse is possible. Without this the efficacy of design cannot be reviewed.

5. Insufficient details of the flood barrier have been provided. Please provide site specific drawings which include the concrete slab base and connectivity to the barrier.
6. You again mistakenly state that the attenuation basin will fall under the reservoirs act, it's volume above ground level means it will not. Therefore, the reassurances you provide are unjustified and your argument regarding overlapping legislation is flawed.
7. Full details of the attenuation basin will therefore need to be provided.
8. No dimensions have been provided on the attenuation basin and siphon drawings. This needs to be detailed.
9. The permeable paving construction details need to show permeable membranes are being provided. No details of the permeable surface course have been provided, and need to be.
10. Please detail what material will be used for the 150mm permeable base layer.
11. Sufficient construction detail drawings haven't been provided.
12. Sufficient details on layout plans have not been provided.

To summarise, it has not been demonstrated that the surface water drainage proposals will not increase flood risk elsewhere now or in the future. Therefore, I cannot recommend the discharge of these conditions.

Kind Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: Simon Davis
Sent: 24 January 2019 09:21
To: Laura Gibbons
Subject: FW: Y/92/18/DOC- Further Drainage Supporting Info

Laura,

Please see below and attached for your further consideration please. They are correct that Y/92/15/PL expires on 26 January.

From: Rosie Foreman [REDACTED]
Sent: 24 January 2019 08:54
To: Simon Davis <Simon.Davis@arun.gov.uk>
Subject: Y/92/18/DOC- Further Drainage Supporting Info

Dear Simon

Further to the latest comments we have from the Council's drainage engineer, please find attached a response from the applicant's drainage consultants, setting out the results of further winter infiltration testing which has been carried out over December and January, and includes further details of the reservoir and outflows. It follows the Council's 'Supplementary Requirements for Surface Water Drainage Proposals', published on the Council's website, which unfortunately was not referred to in the pre-application discussions between the applicant's drainage consultants and the Council's drainage engineer.

I realise that this is very late in the day for receipt, given that the permission expires 26 Jan, but I hope the Council will be able to review the latest submission in time, particularly as the submission has been based on pre-application discussion with the drainage team and we have responded as quickly as possible to additional requirements for winter infiltration testing on site.

I look forward to hearing from you

Kind regards,

Rosie Foreman
BSc (Hons) MSc MRTPI
Senior Planner



DOWSETTMAYHEW Planning Partnership
63a Ship Street | Brighton | BN1 1AE



This email is confidential and may contain legally privileged information. If you are not the intended recipient it may be unlawful for you to read, copy, distribute, disclose or otherwise make use of the information herein. If you have received this email in error please contact us immediately. DOWSETTMAYHEW PLANNING PARTNERSHIP LTD will accept no liability for the mis-transmission, interference or interception of any email and you are reminded that email is not a secure method of communication.