

From: Simon Davis
Sent: 11 March 2019 16:51
To: Planning.Responses
Subject: FW: Y/9818/RES and Y/97/18/DOC

Drainage Engineer comments – please add to both applications.

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk
Please note that I typically work from home on Thursdays when I am unreachable on my work phone

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Laura Gibbons
Sent: 11 March 2019 16:11
To: Simon Davis <Simon.Davis@arun.gov.uk>
Cc: Mark Warwick <Mark.Warwick@arun.gov.uk>
Subject: RE: Y/9818/RES and Y/97/18/DOC

Hi Simon,

There are still trees located in close proximity and in some instances over the attenuation tanks. These need to be removed. Attenuation tanks must not conflict with potential root areas of proposed trees.

I have seen the drainage technical note previously and provided comments to this.

Thanks,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF



From:
Simon

Davis

Sent: 27 February 2019 17:46

To: Laura Gibbons

Cc: Mark Warwick

Subject: FW: Y/9818/RES and Y/97/18/DOC

Dear Laura,

Regarding these applications, we have received a new Technical Drainage Note and also the layout has been changed in part due to your concern regarding the r'ship of trees to attenuation pond. The plans may not be on the website until next week so I attach those that I think are relevant to you.

Mark - FYI

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |

Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk

Please note that I typically work from home on Thursdays when I am unreachable on my work phone

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.