

**From:** Laura Gibbons <[laura.gibbons@arun.gov.uk](mailto:laura.gibbons@arun.gov.uk)>

**Sent:** 06 August 2019 08:07

**To:** Simon Davis <[Simon.Davis@arun.gov.uk](mailto:Simon.Davis@arun.gov.uk)>

**Subject:** RE: Y/98/18/RES and Y/97/18/DOC

Hi Simon,

Details are sufficient.

Thanks,

Laura Gibbons, MEng, GMICE  
Engineer (Drainage & Coastal)

[Laura Gibbons](#) | Engineer (Drainage & Coastal), Engineering Services, [Arun District Council](#) | Location: First Floor, Arun Civic Centre,  
Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: [laura.gibbons@arun.gov.uk](mailto:laura.gibbons@arun.gov.uk)

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and [www.chichester.gov.uk](http://www.chichester.gov.uk)



Save the environment - think before you print.

**From:** Simon Davis

**Sent:** 05 August 2019 17:03

**To:** Laura Gibbons <[laura.gibbons@arun.gov.uk](mailto:laura.gibbons@arun.gov.uk)>

**Subject:** FW: Y/98/18/RES and Y/97/18/DOC

Hey.

Is this any better?

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |  
Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF  
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: [simon.davis@arun.gov.uk](mailto:simon.davis@arun.gov.uk)  
Please note that I typically work from home on Thursdays when I am unreachable on my work phone

Visit Arun's web site at [www.arun.gov.uk](http://www.arun.gov.uk)



Save the environment - think before you print.

**From:** Kathryn Block [REDACTED]  
**Sent:** 05 August 2019 16:23  
**To:** Simon Davis <[Simon.Davis@arun.gov.uk](mailto:Simon.Davis@arun.gov.uk)>  
**Cc:** Zoe Knott [REDACTED]  
**Subject:** RE: Y/98/18/RES and Y/97/18/DOC

Good afternoon Simon,

Thank you for providing Laura's comments on the demountable fencing.

The demountable fence details plan (ref.18-1065-084 Rev A) has been revised to show that the major fences now have concrete posts with stainless steel bolts, washers and nuts as required.

The lower fence has been amended to show the stainless steel bolt fixings for the rails.

We would be most grateful if you could now confirm that this is sufficient.


Kind regards

Kathryn

Kathryn Block  
Planner

[REDACTED]

Nexus Planning is pleased to have been commended by the RTPI for Planning Consultancy of the Year 2019



[nexusplanning.co.uk](http://nexusplanning.co.uk)

